

**TABLE 5 – Non-Detected CCR Contaminants**

CONTAMINANT	UNITS	CCR		CA	CDL
		MCL	PHG (MCLG)	DHL DHS	MDL
Aluminum	ppm	1	0.6	0.050	0.002
Antimony	ppb	6	20	6	0.5
Arsenic	ppb	50	n/a	2	1
Barium	ppm	1	(2)	0.1	0.001
Beryllium	ppb	4	(4)	1	0.2
Cadmium	ppb	5	0.07	1	0.5
Chromium [Total Cr]	ppb	50	(100)	10	1
Copper	ppm	AL = 1.3	0.17	0.050	0.001
Cyanide	ppb	200	150	100	15
Iron	ppb	300	n/a	100	50
Lead	ppb	AL = 15	2	5	0.5
Manganese	ppb	50	n/a	20	0.5
Mercury	ppb	2	1.2	1	0.2
Nickel	ppb	100	12	10	1
Nitrate (as N)	ppm	10	10	2	0.2
Nitrite (as N)	ppm	1	1	1.75	0.008
Selenium	ppb	50	(50)	5	2
Silver	ppb	100	n/a	10	0.5
Thallium	ppb	2	0.1	1	0.2
Zinc	ppm	5	n/a	0.050	0.002
Foaming Agents [MBAS]	ppb	500	n/a	n/a	0.05
2,4-D	ppb	70	70	10	0.5
2,4,5-P [Silvex]	ppb	50	(50)	1	0.3
Acetochlor	ppb	n/a	n/a	n/a	0.5
Aalachlor [ALANEX]	ppb	2	4	1	0.5
Aldicarb [TEMIK]	ppb	n/a	n/a	3	0.2
Aldicarb sulfone	ppb	n/a	n/a	4	0.2
Aldicarb sulfoxide	ppb	n/a	n/a	3	0.2
Aldrin	ppb	n/a	n/a	0.075	0.2
tert-Amyl-Methyl Ether [TAME]	ppb	n/a	n/a	n/a	0.2
Atrazine [AATREX]	ppb	3	0.15	1	0.5
Bentazon [BASAGRAN]	ppb	18	200	2	2
Benzene	ppb	1	0.15	0.5	0.2
Benzo(a)pyrene [PAH]	ppt	200	4	100	0.1
Bromocil [HYVAR]	ppb	n/a	n/a	10	0.5
Bromobenzene	ppb	n/a	n/a	0.5	0.2
Bromochloromethane	ppb	n/a	n/a	0.5	0.2
Bromomethane	ppb	n/a	n/a	0.5	0.2
Butachlor	ppb	n/a	n/a	0.38	0.2
sec-Butylbenzene	ppb	n/a	n/a	0.5	0.2
n-Butylbenzene	ppb	n/a	n/a	0.5	0.2
tert-Butylbenzene	ppb	n/a	n/a	0.5	0.2
Carbaryl [SEVIN]	ppb	n/a	n/a	5	0.2
Carbofuran [FURADAN]	ppb	18	1.7	5	0.4
Carbon tetrachloride	ppt	500	100	0.5	200
Chlordane	ppt	100	30	100	100
Chloroethane	ppb	n/a	n/a	0.5	0.2
Chloromethane	ppb	n/a	n/a	0.5	0.2
o-Chlorotoluene	ppb	n/a	n/a	0.5	0.2
p-Chlorotoluene	ppb	n/a	n/a	0.5	0.2
Dalapon	ppb	200	790	10	1
Di(2-ethylhexyl) adipate	ppb	400	(400)	5	2
Di(2-ethylhexyl)phthalate [DEHP]	ppb	4	12	3	1
Dibromochloropropane [DBCP]	ppt	200	1.7	10	10
DBCP mono-acid degradate	ppb	n/a	n/a	n/a	1
DBCP di-acid degradate	ppb	n/a	n/a	n/a	1
4,4-DDE	ppb	n/a	n/a	n/a	0.1
Diazinon	ppb	n/a	n/a	n/a	0.2
Dibromomethane	ppb	n/a	n/a	0.5	0.2
Dicamba [BANVEL]	ppb	n/a	n/a	1.5	0.2
1,2-Dichlorobenzene [o-DCB]	ppb	600	600	0.5	0.2
1,3-Dichlorobenzene [m-DCB]	ppb	n/a	n/a	0.5	0.2
1,4-Dichlorobenzene [p-DCB]	ppb	5	6	0.5	0.2
1,1-Dichloroethane [1,1-DCA]	ppb	5	n/a	0.5	0.2
1,2-Dichloroethane [1,2-DCA]	ppt	500	400	500	200
1,1-Dichloroethylene [1,1-DCE]	ppb	6	10	0.5	0.2

CONTAMINANT	UNITS	CCR		CA	CDL
		MCL	PHG (MCLG)	DHL DHS	MDL
Dichloroethylene [c-1,2-DCE]	ppb	6	(70)	0.5	0.2
trans-1,2-Dichloroethylene [t-1,2-DCE]	ppb	10	(100)	0.5	0.2
Dichlorodifluoromethane	ppb	n/a	n/a	1	0.2
Dichloromethane	ppb	5	4	0.5	0.2
1,2-Dichloropropane	ppb	5	0.5	0.5	0.2
1,3-Dichloropropane	ppb	n/a	n/a	0.5	0.2
2,2-Dichloropropane	ppb	n/a	n/a	0.5	0.2
1,1-Dichloropropene	ppb	n/a	n/a	0.5	0.2
1,3-Dichloropropene	ppt	500	200	500	200
Dieldrin	ppb	n/a	n/a	0.02	0.2
2,4-Dinitrotoluene	ppb	n/a	n/a	n/a	0.2
2,6-Dinitrotoluene	ppb	n/a	n/a	n/a	0.2
Dinoseb [DNBP]	ppb	/	14	2	2
Diquat	ppb	20	15	4	3
Endothall	ppb	100	580	45	5
Endrin	ppb	2	1.8	0.1	0.1
EPTC	ppb	n/a	n/a	n/a	0.3
Ethylbenzene	ppb	700	300	0.5	0.2
Ethylene dibromide [EDB]	ppt	50	(0)	20	20
Ethyl-tert-butyl-ether [ETBE]	ppb	n/a	n/a	n/a	0.2
Glyphosate	ppb	700	1000	25	10
Heptachlor	ppt	10	8	10	10
Heptachlor Epoxide	ppt	10	6	10	10
Hexachlorobenzene	ppb	1	(0)	0.5	0.5
Hexachlorobutadiene	ppb	n/a	n/a	0.5	0.2
3-Hydroxycarbofuran	ppb	n/a	n/a	3	0.2
Hexachloropentadiene	ppb	50	50	1	0.5
Isopropylbenzene [CUMENE]	ppb	n/a	n/a	0.5	0.2
p-Isopropyltoluene	ppb	n/a	n/a	0.5	0.2
Lindane [gamma-BHC]	ppt	200	32	200	200
Methoxychlor	ppb	40	30	10	10
Methomyl	ppb	n/a	n/a	2	0.2
Metolachlor	ppb	n/a	n/a	n/a	0.2
Methyl-tertbutyl ether [MTBE]	ppb	13	13	3	0.2
Metribuzin	ppb	n/a	n/a	n/a	0.2
Molinate [ORDRAM]	ppb	20	n/a	2	0.3
Monochlorobenzene	ppb	70	(100)	0.5	0.2
Naphthalene	ppb	n/a	n/a	0.5	0.2
Nitrobenzene	ppb	n/a	n/a	n/a	5
Oxamyl [Vydate]	ppb	200	50	20	1
Polychlorinated biphenyls [Total PCBs]	ppt	500	(0)	500	500
Pentachlorophenol [PCP]	ppb	1	0.4	0.2	0.2
1-Phenylpropane	ppb	n/a	n/a	0.5	0.2
Picloram	ppb	500	500	1	1
Prometryn [CAPAROL]	ppb	n/a	n/a	2	0.2
Propachlor	ppb	n/a	n/a	0.5	0.2
Simazine [PRINCEP]	ppb	4	(4)	1	0.5
Styrene	ppb	100	(100)	0.5	0.2
Terbacil	ppb	n/a	n/a	n/a	0.5
1,1,1,2-Tetrachloroethane	ppb	n/a	n/a	0.5	0.2
1,1,2,2-Tetrachloroethane	ppb	1	n/a	0.5	0.2
Tetrachloroethylene [PCE]	ppb	5	0.06	0.5	0.2
Thiobencarb [BOLERO]	ppb	70	70	1	1
1,2,3-Trichlorobenzene	ppb	n/a	n/a	0.5	0.2
1,2,4-Trichlorobenzene	ppb	70	5	0.5	0.2
1,1,1-Trichloroethane [1,1,1-TCA]	ppb	200	(200)	0.5	0.2
1,1,2-Trichloroethane [1,1,2-TCA]	ppb	5	(3)	0.5	0.2
Trichloroethylene [TCE]	ppb	5	0.8	0.5	0.2
Trichlorofluoromethane [FREON 11]	ppb	150	700	5	0.2
1,2,3-Trichloropropane	ppb	n/a	n/a	0.5	0.2
1,2,4-Trimethylbenzene	ppb	n/a	n/a	n/a	0.2
1,3,5-Trimethylbenzene	ppb	n/a	n/a	0.5	0.2
Trichlorotrifluoroethane [FREON 113]	ppm	1.2	1.2	10	0.0002
Toluene	ppb	150	150	0.5	0.2
Toxaphene	ppb	3	(0)	1	1
Vinyl Chloride	ppt	500	50	500	200
Xylenes [TOTAL m,p & o]	ppm	1.75	1.8	0.5	0.0006

**Abbreviations**

- A/P:** Absent/Present
- AL:** Action Level
- CCR:** Consumer Confidence Report
- CSD WQL MDL:** City of San Diego Water Quality Laboratory Method Detection Limit
- CU:** Color Units
- DLR:** Detection Limit for Reporting
- gr/Gal:** Grains per Gallon
- MCL:** Maximum Contaminant Level
- MCLG:** Maximum Contaminant Level Goal
- MDL:** Method Detection Limit
- n/a:** not applicable
- nd:** <WQL MDL
- NTU:** Nephelometric Turbidity Units
- OU:** Odor Units
- pCi/L:** picocuries per liter (a measure of radiation)
- PDWS:** Primary Drinking Water Standard
- PHG:** Public Health Goal
- ppb:** parts per billion or micrograms per liter (µg/L) -- [1 ppb = 1,000 ppt]
- ppm:** parts per million or milligrams per liter (mg/L) -- [1 ppm = 1,000 ppb]
- ppt:** parts per trillion or nanograms per liter (ng/L) -- [1 ppt = 0.001 ppb]
- Sample Year:** This column is to record the last time a contaminant was analyzed.
- TOX:** Total Organic Halides
- TT:** A required treatment technique process intended to reduce the level of a contaminant in drinking water.
- µg/l:** micrograms per liter (ppb)
- µmhos/cm:** measurement of conductivity
- <:** Less than
- >:** Greater than