

TABLE 5 – NON-DETECTED CONTAMINANTS

Primary Standards (Mandatory Health Related Standards) Chemical Contaminants

CONTAMINANT	CCR			CA DHS DLR	CONTAMINANT	CCR			CA DHS DLR	CONTAMINANT	CCR			CA DHS DLR
	UNITS	MCL	PHG (MCLG)			UNITS	MCL	PHG (MCLG)			UNITS	MCL	PHG (MCLG)	
Dichlorobenzene [o-DCB]	ppb	600	600	0.5	Manganese	ppb	50	n/a	20	Dichloromethane	ppb	5	4	0.5
Dichlorobenzene [m-DCB]	ppb	n/a	n/a	0.5	Mercury	ppb	2	1.2	1	Dieldrin	ppb	n/a	n/a	0.02
Dichlorobenzene [p-DCB]	ppb	5	6	0.5	n-Butylbenzene	ppb	n/a	n/a	0.5	Di-Isopropyl-Ether [DIPE]	ppb	n/a	n/a	n/a
TP [Silvex]	ppb	50	25	1	Nickel	ppb	100	12	10	Dinoseb [DNBP]	ppb	7	14	2
D	ppb	70	70	10	Nitrate (NO3)	ppm	45	10	2	Diquat	ppb	20	15	4
Acenaphthylene	ppb	n/a	n/a	5	Nitrite (as N)	ppm	1	1	0.4	Endothall	ppb	100	580	45
Alachlor [ALANEX]	ppb	2	4	1	n-Propylbenzene	ppb	n/a	n/a	0.5	Endrin	ppb	2	1.8	0.1
Aldicarb [TEMIK]	ppb	n/a	n/a	3	o-Chlorotoluene	ppb	n/a	n/a	0.5	Ethylbenzene	ppb	300	300	0.5
Aldicarb sulfone	ppb	n/a	n/a	4	p-Chlorotoluene	ppb	n/a	n/a	0.5	Ethylene dibromide [EDB]	ppt	50	10	20
Aldicarb sulfoxide	ppb	n/a	n/a	3	Perchlorate	ppb	n/a	n/a	4	Ethyl-tert-butyl-ether [ETBE]	ppb	n/a	n/a	3
Aldrin	ppb	n/a	n/a	0.075	Radium 226 (a)	pCi/L	3	n/a	1	Glyphosate	ppt	700	1,000	25
Aluminum	ppm	1	0.6	0.050	sec-Butylbenzene	ppb	n/a	n/a	0.5	Heptachlor	ppt	10	8	10
Anthracene	ppb	n/a	n/a	5	Selenium	ppb	50	(50)	5	Heptachlor Epoxide	ppt	10	6	10
Antimony	ppb	6	20	6	Silver	ppb	100	n/a	10	Hexachlorobenzene	ppt	1	0.03	0.5
Arsenic	ppb	50	n/a	2	Strontium - 90 (a)	pCi/L	8	n/a	2	Hexachlorobutadiene	ppb	n/a	n/a	0.5
Atrazine [AATREX]	ppb	1	0.15	0.5	tert-Amyl-Methyl Ether [TAME]	ppb	n/a	n/a	3	Hexachlorocyclopentadiene	ppb	50	50	1
Bentazon [BASAGRAN]	ppb	18	200	2	Tert-Butyl alcohol (TBA)	ppb	n/a	n/a	2	Indeno(1,2,3-CD)pyrene	ppb	n/a	n/a	10
Benzene	ppb	1	0.15	0.5	tert-Butyl Alcohol [TBA]	ppb	AL=12	n/a	2	Isopropylbenzene [CUMENE]	ppb	n/a	n/a	0.5
Benzo(A)anthracene	ppb	n/a	n/a	10	tert-Butylbenzene	ppb	n/a	n/a	0.5	Lindane [gamma-BHC]	ppt	200	32	200
Benzo(a)pyrene [PAH]	ppt	200	4	100	Thallium	ppb	2	0.1	1	MCPA	ppb	n/a	n/a	n/a
Benzo(b)fluoranthene	ppb	n/a	n/a	10	Total Coliform Bacteria	% P	<5% P	(0)	n/a	MCCP	ppb	n/a	n/a	n/a
Benzo(G,H,I)perylene	ppb	n/a	n/a	10	Tritium (a)	pCi/L	20,000	n/a	1,000	Methiocarb	ppb	n/a	n/a	n/a
Benzo(K)fluoranthene	ppb	n/a	n/a	10	Vanadium	ppb	n/a	n/a	3	Methomyl	ppb	n/a	n/a	2
Beryllium	ppb	4	(1)	1	Vinyl Chloride	ppt	500	50	0.5	Methoxychlor	ppb	30	30	10
BHC, Gamma isomer	ppb	n/a	n/a	n/a	Zinc	ppm	5	n/a	0.05	Methyl-tertbutyl ether [MTBE]	ppb	5	13	3
Bromobenzene	ppb	n/a	n/a	0.5	Trifluralin	ppb	n/a	n/a	n/a	Metolachlor	ppb	n/a	n/a	n/a
Bromochloromethane	ppb	n/a	n/a	0.5	Tetrachloroethane [1,1,1,2]	ppb	n/a	n/a	0.5	Metribuzin	ppb	n/a	n/a	n/a
Bromomethane	ppb	n/a	n/a	0.5	Trichloroethane [1,1,1-TCA]	ppb	200	(200)	0.5	Molinate [ORDRAM]	ppb	20	n/a	2
Butyl benzyl phthalate	ppb	n/a	n/a	n/a	Tetrachloroethane [1,1,2,2]	ppb	1	0.1	0.5	Monochlorobenzene	ppb	70	200	0.5
Cadmium	ppb	5	0.07	1	Trichloroethane [1,1,2-TCA]	ppb	5	(3)	0.5	Naphthalene	ppb	n/a	n/a	0.5
Carbaryl [SEVIN]PPB	ppb	n/a	n/a	5	Dichloroethane [1,1-DCA]	ppb	5	3	0.5	Oxamyl [Vydate]	ppb	50	50	20
Carbofuran [FURADAN]	ppb	18	1.7	5	Dichloroethylene [1,1-DCE]	ppb	6	10	0.5	Paraquat	ppb	n/a	n/a	20
Carbon tetrachloride	ppt	500	100	500	Dichloropropene	ppb	n/a	n/a	0.5	Pentachlorophenol [PCP]	ppb	1	0.4	0.2
Chlordane	ppt	100	30	100	Trichlorobenzene	ppb	n/a	n/a	0.5	Phenanthrene	ppb	n/a	n/a	5
Chloroethane	ppb	n/a	n/a	0.5	Trichloropropane [TCP]	ppb	n/a	n/a	0.005	Picloram	ppb	500	500	1
Chloromethane	ppb	n/a	n/a	0.5	Trichlorobenzene	ppb	5	5	0.5	p-Isopropyltoluene	ppb	n/a	n/a	0.5
Chromium [Total Cr]ppb	ppb	50	(100)	10	Trimethylbenzene	ppb	n/a	n/a	0.5	Polychlorinated biphenyls [Total PCBs]	ppb	500	(0)	500
Chrysene	ppb	n/a	n/a	5	Dichloroethane [1,2-DCA]	ppt	500	400	500	Prometryn [CAPAROL]	ppb	n/a	n/a	2
Copper	ppm	AL=1.3	0.17	0.05	Dichloropropane	ppb	5	0.5	0.5	Propachlor	ppb	n/a	n/a	0.5
<i>Cryptosporidium</i>	Oocysts / L	n/a	(0)	n/a	Trimethylbenzene	ppb	n/a	n/a	0.5	Pyrene	ppb	n/a	n/a	5
Cyanide	ppb	150	150	100	Dichloropropane	ppb	n/a	n/a	0.5	Simazine [PRINCEP]	ppb	4	4	1
Dalapon	ppb	200	790	10	Dichloropropene	ppt	500	200	500	Styrene	ppb	100	(100)	0.5
Di(2-ethylhexyl) adipate	ppb	400	(200)	5	Phenylpropane	ppt	n/a	n/a	0.5	Tert-Amyl-Methyl-Ether (TAME)	ppb	n/a	n/a	3
Di(2-ethylhexyl)phthalate [DEHP]	ppb	4	12	3	Dichloropropane	ppb	n/a	n/a	0.5	Tetrachloroethylene [PCE]	ppb	5	0.06	0.5
Diazinon	ppb	n/a	n/a	0.25	2,4,5-T	ppb	n/a	n/a	n/a	Thiobencarb [BOLERO]	ppb	70	70	1
Dibenzo(A,H)anthracene	ppb	n/a	n/a	5	2,4-DB	ppb	n/a	n/a	n/a	Toluene	ppb	150	150	0.5
Dibromochloropropane [DBCP]	ppt	200	1.7	10	3,5-Dichlorobenzoic Acid	ppb	n/a	n/a	n/a	Toxaphene	ppm	3	0.3	1
Dibromomethane	ppb	n/a	n/a	0.5	Hydroxycarbofuran	ppb	n/a	n/a	3	trans-1,2-Dichloroethylene [t-1,2-DCE]	ppb	10	(100)	0.5
Dicamba [BANVEL]	ppb	n/a	n/a	1.5	4-nitrophenol	ppb	n/a	n/a	5	Trichloroethylene [TCE]	ppb	5	0.8	0.5
Diethyl phthalate	ppb	n/a	n/a	5	Acifluorfen	ppb	n/a	n/a	n/a	Trichlorofluoromethane [FREON 11]	ppb	150	700	5
Dimethyl phthalate	ppb	n/a	n/a	5	Baygon	ppb	n/a	n/a	n/a	Trichlorotrifluoroethane [FREON 113]	ppb	1,200	4	10
Di-n-butyl phthalate	ppb	n/a	n/a	5	Chloramben	ppb	n/a	n/a	n/a	Trifluralin	ppb	n/a	n/a	n/a
Fluorene	ppb	n/a	n/a	5	Chromium VI	ppb	n/a	n/a	1	Xylenes [TOTAL m, p & o]	ppb	1,750	1.8	0.5
<i>Giardia Lamblia</i>	Cysts / L	n/a	n/a	n/a	cis-1,2-Dichloroethylene [c-1,2-DCE]	ppb	6	(70)	0.5					
Lead	ppb	AL=15	2	5	Dichlorodifluoromethane [Freon 12]	ppb	n/a	n/a	0.5					

(A) RADIUM-226, STRONTIUM-90 & TRITIUM DATA ARE FROM CY2002. THIS IS THE LAST TIME THAT RADIOLOGICAL ANALYSIS WAS CONDUCTED. CCR CONTAMINANTS *