

TABLE 6 – NON-DETECTED CCR CONTAMINANTS
Primary Standards (Mandatory Health Related Standards) – CHEMICAL CONTAMINANTS

CONTAMINANT	CCR			CA DHS DLR	CONTAMINANT	CCR			CA DHS DLR
	UNITS	MCL	PHG (MCLG)			UNITS	MCL	PHG (MCLG)	
Aluminum	ppm	1	0.6	0.050	1,1-Dichloroethane [1,1-DCA]	ppb	5	3	0.5
Antimony	ppb	6	20	6	1,2-Dichloroethane [1,2-DCA]	ppt	500	400	500
Arsenic	ppb	50	n/a	2	1,1-Dichloroethylene [1,1-DCE]	ppb	6	10	0.5
Barium	ppm	1	(2)	0.1	cis-1,2-Dichloroethylene [c-1,2-DCE]	ppb	6	(70)	0.5
Beryllium	ppb	4	(1)	1	trans-1,2-Dichloroethylene [t-1,2-DCE]	ppb	10	(100)	0.5
Cadmium	ppb	5	0.07	1	Dichlorodifluoromethane [Freon 12]	ppb	n/a	n/a	1
Chromium [Total Cr]	ppb	50	(100)	10	Dichloromethane	ppb	5	4	0.5
Copper	ppm	AL=1.3	0.17	0.5	1,2-Dichloropropane	ppb	5	0.5	0.5
Cyanide	ppb	150	150	100	1,3-Dichloropropane	ppb	n/a	n/a	0.5
Iron	ppb	300	n/a	100	2,2-Dichloropropane	ppb	n/a	n/a	0.5
Lead	ppb	AL=15	2	5	1,1-Dichloropropene	ppb	n/a	n/a	0.5
Manganese	ppb	50	n/a	20	1,3-Dichloropropene	ppt	500	200	500
Mercury	ppb	2	1.2	1	Dieldrin	ppb	n/a	n/a	0.02
Nickel	ppb	100	12	10	Dinoseb [DNBP]	ppb	7	14	2
Nitrate (as N)	ppm	10	10	2	Diquat	ppb	20	15	4
Nitrite (as N)	ppm	1	1	0.4	Endothall	ppb	100	580	45
Radium 226 (a)	pCi/L	3	n/a	1	Endrin	ppb	2	1.8	0.1
Selenium	ppb	50	(50)	5	Ethylbenzene	ppb	300	300	0.5
Silver	ppb	100	n/a	10	Ethylene dibromide [EDB]	ppt	50	10	20
Strontium - 90 (a)	pCi/L	8	n/a	2	Ethyl-tert-butyl-ether [ETBE]	ppb	n/a	n/a	3
Thallium	ppb	2	0.1	1	Glyphosate	ppb	700	1000	25
Tritium (a)	pCi/L	20,000	n/a	1,000	Heptachlor	ppt	10	8	10
Zinc	ppm	5	n/a	0.050	Heptachlor Epoxide	ppt	10	6	10
Total Coliform Bacteria	% P	<5% P	(0)	n/a	Hexachlorobenzene	ppb	1	0.03	0.5
E. coli (b)	P/A	see notes	(0)	n/a	Hexachlorobutadiene	ppb	n/a	n/a	0.5
Cryptosporidium	Oocysts / L	n/a	(0)	n/a	3-Hydroxycarbofuran	ppb	n/a	n/a	3
Giardia Lamblia	Cysts / L	n/a	n/a	n/a	Hexachlorocyclopentadiene	ppb	50	50	1
2,4-D	ppb	70	70	10	Isopropylbenzene [CUMENE]	ppb	n/a	n/a	0.5
2,4,5-TP [Silvex]	ppb	50	25	1	p-Isopropyltoluene	ppb	n/a	n/a	0.5
2,4-D	ppb	70	70	10	Lindane [gamma-BHC]	ppt	200	32	200
2,4,5-TP [Silvex]	ppb	50	25	1	Methoxychlor	ppb	30	30	10
Alachlor [ALANEX]	ppb	2	4	1	Methomyl	ppb	n/a	n/a	2
Aldicarb [TEMIK]	ppb	n/a	n/a	3	Metolachlor	ppb	n/a	n/a	n/a
Aldicarb sulfone	ppb	n/a	n/a	4	Methyl-tertbutyl ether [MTBE]	ppb	13	13	3
Aldicarb sulfoxide	ppb	n/a	n/a	3	Metribuzin	ppb	n/a	n/a	n/a
Aldrin	ppb	n/a	n/a	0.075	Molinate [ORDRAM]	ppb	20	n/a	2
tert-Amyl-Methyl Ether [TAME]	ppb	n/a	n/a	3	Monochlorobenzene	ppb	70	200	0.5
Atrazine [AATREX]	ppb	1	0.15	0.5	Naphthalene	ppb	n/a	n/a	0.5
Bentazon [BASAGRAN]	ppb	18	200	2	Oxamyl [Vydate]	ppb	50	50	20
Benzene	ppb	1	0.15	0.5	Polychlorinated biphenyls [Total PCBs]	ppt	500	(0)	500
Benzo(a)pyrene [PAH]	ppt	200	4	100	Pentachlorophenol [PCP]	ppb	1	0.4	0.2
Bromobenzene	ppb	n/a	n/a	0.5	1-Phenylpropane	ppb	n/a	n/a	0.5
Bromochloromethane	ppb	n/a	n/a	0.5	Picloram	ppb	500	500	1
Bromomethane	ppb	n/a	n/a	0.5	Prometryn [CAPAROL]	ppb	n/a	n/a	2
n-Butylbenzene	ppb	n/a	n/a	0.5	Propachlor	ppb	n/a	n/a	0.5
sec-Butylbenzene	ppb	n/a	n/a	0.5	Simazine [PRINCEP]	ppb	4	4	1
tert-Butylbenzene	ppb	n/a	n/a	0.5	Styrene	ppb	100	(100)	0.5
tert-Butyl Alcohol [TBA]	ppb	AL = 12	n/a	2	1,1,1,2-Tetrachloroethane	ppb	n/a	n/a	0.5
Carbaryl [SEVIN]	ppb	n/a	n/a	5	1,1,2,2-Tetrachloroethane	ppb	1	0.1	0.5
Carbofuran [FURADAN]	ppb	18	1.7	5	Tetrachloroethylene [PCE]	ppb	5	0.06	0.5
Carbon tetrachloride	ppt	500	100	500	Thiobencarb [BOLERO]	ppb	70	70	1
Chlordane	ppt	100	30	100	1,2,3-Trichlorobenzene	ppb	n/a	n/a	0.5
Chloroethane	ppb	n/a	n/a	0.5	1,2,4-Trichlorobenzene	ppb	5	5	0.5
Chloromethane	ppb	n/a	n/a	0.5	1,1,1-Trichloroethane [1,1,1-TCA]	ppb	200	(200)	0.5
o-Chlorotoluene	ppb	n/a	n/a	0.5	1,1,2-Trichloroethane [1,1,2-TCA]	ppb	5	(3)	0.5
p-Chlorotoluene	ppb	n/a	n/a	0.5	Trichloroethylene [TCE]	ppb	5	0.8	0.5
Dalapon	ppb	200	790	10	Trichlorofluoromethane [FREON 11]	ppb	150	700	5
Di(2-ethylhexyl) adipate	ppb	400	(200)	5	1,2,3-Trichloropropane [TCP]	ppb	n/a	n/a	0.005
Di(2-ethylhexyl)phthalate [DEHP]	ppb	4	12	3	1,2,4-Trimethylbenzene	ppb	n/a	n/a	n/a
Dibromochloropropane [DBCP]	ppt	200	1.7	10	1,3,5-Trimethylbenzene	ppb	n/a	n/a	0.5
Diazinon	ppb	n/a	n/a	0.25	Trichlorotrifluoroethane [FREON 113]	ppm	1.2	4	10
Dibromomethane	ppb	n/a	n/a	0.5	Toluene	ppb	150	150	0.5
Dicamba [BANVEL]	ppb	n/a	n/a	1.5	Toxaphene	ppb	3	0.3	1
1,2-Dichlorobenzene [o-DCB]	ppb	600	600	0.5	Vinyl Chloride	ppt	500	50	0.5
1,3-Dichlorobenzene [m-DCB]	ppb	n/a	n/a	0.5	Xylenes [TOTAL m,p & o]	ppm	1.75	1.8	0.5
1,4-Dichlorobenzene [p-DCB]	ppb	5	6	0.5					

NOTES: (a) Radium-226, Strontium-90 & Tritium data are from CY2002. This is the last time that Radiological analysis was conducted.

(b) The occurrence of 2 consecutive total coliform positive samples, one of which contains fecal coliform/E. coli, constitutes an acute MCL violation. The MCL was not violated in 2003.