



STATE OF CALIFORNIA—HEALTH AND HUMAN SERVICES AGENCY
Department of Health Services
Drinking Water Program



ANNUAL COMPLIANCE REPORT

FOR

CALIFORNIA PUBLIC WATER SYSTEMS

CALENDAR YEAR 2005



STATE OF CALIFORNIA—HEALTH AND HUMAN SERVICES AGENCY

Department of Health Services Drinking Water Program



TABLE OF CONTENTS

REPORT DESCRIPTION	PAGE
Section I - Introduction.....	1
Section II - Definitions.....	3
Section III - Violation Category Summary.....	5
Section IV - Enforcement Activity.....	12
Section V - Conclusion.....	13
APPENDIX A - Summary of Public Water System Violations (By Contaminant)	
APPENDIX B - Summary of Public Water System Violations (By Contaminant Category)	
APPENDIX C - Summary of Public Water System Violations (By Water System Number and County)	
APPENDIX D - Local Primacy Agencies	

**CALIFORNIA DEPARTMENT OF HEALTH SERVICES
DRINKING WATER PROGRAM
ANNUAL COMPLIANCE REPORT
FOR
PUBLIC WATER SYSTEMS
CALENDAR YEAR 2005**

SECTION I INTRODUCTION

There were an estimated 7,742 public water systems in California during the 2005 calendar year. These water systems served approximately 36.1 million of the estimated 37.2 million people in California. The remaining estimated 1.1 million people in the state received their drinking water from private wells serving individual residences, and from other sources. Public water systems are regulated and monitored through the State Drinking Water Program.

THE DRINKING WATER PROGRAM OVERVIEW

Under the 1974 Federal Safe Drinking Water Act (SDWA) and subsequent amendments in 1986 and 1996, the US Environmental Protection Agency (USEPA) set national limits on contaminant levels in drinking water for human consumption to provide public safety. These limits are known as Maximum Contaminant Levels (MCLs) and Maximum Residual Disinfectant Levels (MRDLs). For some regulations, treatment techniques were established in lieu of an MCL to control unacceptable levels of contaminants in water. To assist in providing data for future regulatory development, Public Water Systems (PWSs) are also required to monitor for unregulated contaminants. PWSs are also regulated as to the frequency for monitoring and reporting of results for contaminants to the states or USEPA. PWSs must notify their consumers when they have violated these regulations by including a clear and understandable explanation of the nature of the violation, its potential adverse health effects, steps that the PWS is undertaking to correct the violation and the possibility of alternative water supplies available during the violation.

The USEPA designated the California Department of Health Services (Department) as the primacy agency responsible for the administration and enforcement of the SDWA requirements in California. The State of California and Department have adopted statutes and regulations to implement the requirements of the SDWA. The Department's regulatory responsibility over public water systems include: issuance of operating permits, conducting inspections, monitoring for compliance with regulations, and taking enforcement action to compel compliance when violations are identified.

The Department has delegated (given primacy of) the drinking water program regulatory authority for small public water systems serving less than 200 service connections to 36 counties in California. The delegated counties (Local Primacy Agencies) are responsible for regulating approximately 4,575 small public water systems statewide. The Department retains the regulatory authority over the remaining public water systems statewide with 200 or more service connections and the small public water systems in the remaining 22 non-delegated counties. A list of the delegated counties is included in the appendices to this report.

Each quarter, the Department submits data to the Safe Drinking Water Information System (SDWIS/FED), an automated database maintained by the USEPA. The data submitted includes: PWSs inventory information; incidences of Maximum Contaminant Level, Maximum Residual Disinfectant Level, monitoring, reporting, and treatment technique violations; violations concerning public and consumer notification; and information on enforcement activity related to these violations. In addition, the Department provides the USEPA with this annual report of violations of the primary drinking water standards. This report, the Annual Compliance Report, provides the numbers of violations in each of six areas: MCLs, MRDLs, treatment techniques, variances and exemptions, significant monitoring violations, and significant consumer notification violations.

During the calendar year 2005, the Department experienced technical problems in the electronic transmittal of water quality and violations data into the SDWIS for use in the 2005 Annual Compliance Report. As a result, the information available from the federal SDWIS is considered incomplete and does not accurately reflect the status of drinking water compliance in California. The Department is working with the USEPA to resolve the data transfer issues and problems to ensure the completeness and accuracy of the SDWIS data in the future. Consequently, violation information included in this Annual Compliance Report is derived from the data available from the Department's independent drinking water program database system for the period of January 1, 2005 through December 31, 2005.

A copy of this 2005 Annual Compliance Report is available to the public by contacting the Department at (916) 449-5600. The 2005 Annual Compliance Report is also available on the Department's website at:
www.dhs.ca.gov/ps/ddwem/publications/pubindex.htm.

PURPOSE AND AUTHORITY

The SDWA requires States with primacy to prepare and publish an annual report of the compliance of public water systems. Specifically, Section 1414(c)(3)(A)(i) states:

“Not later than January 1, 1998, and annually thereafter, each State that has primary enforcement responsibility under section 1413 shall prepare, make readily available to the public, and submit to the Administrator an annual report

on violations of national primary drinking water regulations by public water systems in the State [the Annual Compliance Report], including violations with respect to (I) maximum contaminant levels, (II) treatment requirements, (III) variances and exemptions, and (IV) monitoring requirements determined to be significant by the Administrator after consultation with the States.”

Section 1414(c)(3)(A)(ii) further states:

“The State shall publish and distribute summaries of the report and indicate where the full report is available for review.”

SECTION II DEFINITIONS

Specific words and phrases used in this Annual Compliance Report have specific meanings. These are defined as follows.

▪ PUBLIC WATER SYSTEM

A Public Water System (PWS) is defined as a system that provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are three types of PWSs. PWSs can be community (such as towns), nontransient noncommunity (such as schools or factories), or transient noncommunity systems (such as rest stops or parks). For purposes in this report, a PWS means systems of all types unless specified in greater detail.

▪ MAXIMUM CONTAMINANT LEVEL

Primary drinking water standards have been adopted by the Department for contaminants that may be found in drinking water supplies in California. The standards are set at levels necessary to protect the public from acute and chronic health risks associated with consuming the contaminants in the drinking water supplies. These limits are known as Maximum Contaminant Levels (MCLs). Public water systems are required to serve drinking water that meets all drinking water standards, and to conduct routine sampling and analysis of their drinking water supplies to certify compliance. Further, all water quality analysis must be conducted by laboratories that are certified by the Department and the analytical results transmitted electronically to the Department. The water quality analytical results are reviewed and evaluated by the Department to determine compliance with drinking water standards. The Department identifies and reports violations when public water systems submit water quality analytical results that exceed the established drinking water standards.

- **MAXIMUM RESIDUAL DISINFECTANT LEVEL**

Limits have also been set for residual disinfectant levels in drinking water to reduce the risk of exposure to disinfectant byproducts formed, when public water systems add chemical disinfectant for either primary or residual treatment. These limits are known as Maximum Residual Disinfectant Levels (MRDLs).

- **TREATMENT TECHNIQUES**

For some regulations, treatment techniques (TTs) were established in lieu of an MCL to control unacceptable levels of certain contaminants. For example, treatment techniques have been established for viruses, some bacteria, and turbidity.

- **VARIANCES AND EXEMPTIONS**

The Department is authorized under the federal SDWA to issue variances and exemptions from meeting drinking water standards to public water systems under special circumstances.

A variance is allowed in situations where the characteristics of a raw water source make it impossible for a public water system to meet the MCL with the installation of the best available technology, treatment techniques, or other approved method. The approval of any variance must ensure adequate protection of human health. Additionally, the variance is reviewed by the Department not less than every five years to determine whether continuation of the variance is appropriate and necessary.

An exemption from an MCL and/or treatment technique is allowed in situations where a public water system is in noncompliance as the result of compelling factors and the exemption will not result in an unreasonable risk to public health. Any public water systems that receive an exemption must achieve compliance with the MCL or treatment technique as expeditiously as practicable, but not later than three years after the applicable compliance date.

Note: There were no variances or exemptions issued by the Department during the 2005 calendar year.

- **MONITORING AND REPORTING**

A PWS is required to monitor and verify the levels of contaminants present in the water do not exceed the MCL. A monitoring violation occurs when a PWS fails to have its water tested as required or fails to report test results correctly to the primacy agent.

- **SIGNIFICANT MONITORING OR REPORTING VIOLATIONS**

For this report, significant monitoring violations are defined as any significant monitoring violation that occurred during the 2005 calendar year. A Significant monitoring violation, with rare exceptions, occurs when no samples were taken or no results were reported.

- **PUBLIC NOTIFICATION VIOLATIONS**

Unless otherwise directed by the Department, water suppliers are required to notify the Department and the persons served by the water system whenever any of the following occurs: the water supplied to the consumers exceeds the MCLs for coliform bacteria, inorganic chemicals, nitrate, turbidity, trihalomethanes, radioactivity, organic chemicals; or the water supplier fails to comply with a prescribed treatment technique established in lieu of an MCL; or the water supplier violates any schedule prescribed pursuant to a variance or exemption. A violation occurs when there is a failure to provide the required notification.

- **CONSUMER NOTIFICATION**

All Community Water Systems are required to deliver to their customers a brief annual water quality report. The report is to include educational material, provide information on the source water(s), levels of any detected contaminants, and any compliance issues with the drinking water regulations.

- **SIGNIFICANT CONSUMER NOTIFICATION VIOLATIONS**

For this report, a significant consumer notification violation occurred if a community water system completely failed to provide its customers the required annual Consumer Confidence Report, also known as the Annual Water Quality Report.

SECTION III VIOLATION CATEGORY SUMMARY

The 2005 Annual Compliance Report lists individual violations by the following categories and in the following order: Inorganic Contaminants; Synthetic Organic Contaminants; Volatile Organic Contaminants; Radionuclide Contaminants; Total Coliform Rule (TCR) violations; Disinfectant & Disinfection By Product Rule (Stage1 DBPR) violations; Surface Water Treatment Rule (SWTR) and Enhanced Surface Water Treatment Rule (ESWTR) violations, Filter Backwash Recycle Rule (FBRR) violations, Lead and Copper Rule (LCR) violations; Public Notification violations, and Consumer Confidence Report Notification violations. Individual violations and categories are listed in Table A in Appendix A to this report. Table A indicates the number of violations and PWSs responsible for the reported MCL/MRDL/TT or monitoring and reporting violations for each individual contaminant or Rule within each category. The table indicates relative compliance with a contaminant or Rule throughout the State. Table B

in Appendix B to this report indicates the number of PWSs, and their respective populations, responsible for the reported MCL/MRDL/TT or monitoring and reporting violations for each category. The table eliminates the counting of multiple violations within each category by individual PWSs. The table indicates relative compliance of specific PWSs to the regulations and annual compliance trends. The table also indicates the population effected by violation categories. Table C of Appendix C to this report lists the individual violations sorted by the PWS number and grouped by county. This table is used for the same purposes as Table B, and provides the population effected by all violation categories. The table further eliminates the counting of multiple violations from different categories for individual PWSs.

A discussion of violations for each category follows:

- **INORGANIC CONTAMINANTS**

PWSs were required to meet primary drinking water standards and monitoring and reporting requirements for 17 inorganic contaminants. Table A indicated 101 MCL violations incurred for 6 of the 17 inorganic contaminants, and 106 monitoring or reporting violations incurred for 3 of the inorganic contaminants. The number of inorganic contaminant MCL violations for the year 2005 increased by 12, or 13%, from the previous year. This increase was mainly due to Nitrate contamination.

Table B indicates the 101 inorganic contaminant MCL violations were issued to 64 PWSs, a 99.2% compliance by all PWSs. An estimated population of 14,088 people was exposed to inorganic MCL contamination during the year, or 0.039% of the state population served by PWSs.

Of the 101 inorganic MCL violations, 87 were for Nitrate and one was for combined Nitrite and Nitrate. Nitrate and Nitrite are used in fertilizer and are found in sewage and wastes from human and/or farm animals and generally gets into drinking water from those activities. Excessive levels of nitrate and Nitrite in drinking water have caused serious illness and sometimes death in infants less than six months of age. The serious illness in infants is caused because nitrate is converted to nitrite in the body. Nitrite interferes with the oxygen carrying capacity of the child's blood. This is an acute disease in that symptoms can develop rapidly in infants. In most cases, health deteriorates over a period of days. Symptoms include shortness of breath and blueness of the skin. Expert medical advice and an alternate source of drinking water are recommended under these conditions. Local and State health authorities are the best sources for information concerning alternate sources of drinking water for infants. The Department has set the drinking water standard at 10 ppm nitrate as nitrogen (equivalent to 45 ppm nitrate as nitrate) and 10 ppm for the sum of nitrate and nitrite as nitrogen to protect against the risk of these adverse effects. Drinking water that meets the Department standards is associated with little to none of this risk and is considered safe with respect to nitrate and nitrite.

Nine of the 101 MCL violations for inorganic contaminants were for Arsenic. The major sources of Arsenic in drinking water are from erosion of natural deposits. Other sources of arsenic may include runoff from orchards, and wastes from glass and electronics production. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer. The Department set the drinking water standard for Arsenic at 0.050 ppm to reduce these risks. (Note: although not reflected in the data for this 2005 report, the USEPA lowered the Arsenic MCL to 0.010 ppm on January 26, 2006. The Department has proposed and submitted a regulatory revision to lower the California MCL to 0.010 ppm. However, the standard has not yet been adopted.)

Two of the 101 inorganic contaminant MCL violations were for Fluoride. Major sources of Fluoride in drinking water are from erosion of natural deposits, water additive that promotes strong teeth, and discharges from fertilizer and aluminum factories. Some people who drink water containing fluoride in excess of the federal MCL of 4 ppm over many years may get bone disease, including pain and tenderness of the bones. Children who drink water containing fluoride in excess of the state MCL of 2 ppm may get mottled teeth.

One of the 101 inorganic contaminant MCL violations was for barium. This inorganic chemical occurs naturally in some aquifers that serve as sources of ground water. It is also used in oil and gas drilling muds, automotive paints, bricks, tiles and jet fuels. It generally gets into drinking water after dissolving from naturally occurring minerals in the ground. This chemical may damage the heart and cardiovascular system, and is associated with high blood pressure in laboratory animals such as rats exposed to high levels during their lifetimes. In humans, the Department believes that effects from barium on blood pressure should not occur below 2 ppm in drinking water. The Department has set the drinking water standard for barium at 1 ppm to protect against the risk of these adverse health effects. Drinking water that meets the Department standard is associated with little to none of this risk.

The last one of the 101 inorganic contaminant MCL violations was for cadmium. This inorganic metal is a contaminant in the metals used to galvanize pipe. It generally gets into water by corrosion of galvanized pipes or by improper waste disposal. Food and the smoking of tobacco are other common sources of general exposure to this contaminant. This chemical has been shown to damage the kidney in animals such as rats and mice when the animals are exposed at high levels over their lifetimes. Some industrial workers who were exposed to a relatively large amount of this chemical during working careers also suffered damage to the kidney. The Department has set the drinking water standard for cadmium at 0.005 ppm to protect against the risk of these adverse health effects. Drinking water that meets the DHS standard is associated with little to none of this risk.

- **SYNTHETIC ORGANIC CONTAMINANTS**

Public water systems are required to meet primary drinking water standards and monitoring and reporting requirements for 33 synthetic organic contaminants (SOCs). Table A indicates four MCL violations occurred for one of the 33 SOCs, and three monitoring or reporting violations occurred for one SOC contaminant. There were no MCL violations reported for the previous year.

Table B indicates the four MCL violations were issued to four PWSs, a near 100% compliance by all PWSs. An estimated population of 273 people was exposed to SOC MCL contamination during the year by PWSs.

All four MCL violations were for Dibromochloropropane (DBCP). DBCP may get into drinking water by runoff or leaching from soil fumigant used on soybeans, cotton, and orchards. Some people who drink water containing DBCP in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer. The Department has set the drinking water standard for DBCP at 0.0002 part per million (ppm) to reduce these risks.

- **VOLATILE ORGANIC CONTAMINANTS**

Public water systems are required to meet primary drinking water standards and monitoring and reporting requirements for 27 volatile organic contaminants (VOCs). Table A indicates no MCL violations occurred for the 27 VOCs. However, 28 monitoring or reporting violations occurred with all 27 VOCs by three PWSs. In comparison, no VOC MCL violations and 53 monitoring and reporting violations occurred for the 27 VOCs by two PWSs during the previous year.

- **RADIONUCLIDE CONTAMINANTS**

PWSs are required to meet primary drinking water standards and monitoring and reporting requirements for six radionuclide contaminants. From Table A, three MCL violations occurred for one of the six radionuclide contaminants, and five monitoring or reporting violations occurred for two of the radionuclide contaminants. The number of radionuclide contaminant MCL violations for the year 2005 decreased by three from the previous year.

Table B indicates the three radionuclide contaminant MCL violations were issued to three PWSs, a near 100% compliance by all PWSs. An estimated population of 820 people was exposed to radionuclide MCL contamination during the year.

Of the three radionuclide MCL violations, all were for Uranium. The major source of Uranium in drinking water is from erosion of natural deposits. Some people who drink water containing uranium in excess of the MCL over many years may have kidney problems or an increased risk of getting cancer. The Department has set the drinking

water standard for Uranium at 20 pCi/L to protect against the risk of these adverse health effects. The USEPA has also set a water standard for Uranium at 0.030 ppm. Drinking water that meets the Department and the USEPA standards is associated with little to none of these risks.

▪ **TOTAL COLIFORM RULE**

The Total Coliform Rule violations identify the presence of coliform microbiological contamination in drinking water supplies or failure of a PWS to conduct the required water quality monitoring for coliform bacteria in the water distribution systems. An acute violation indicates a public water system detected fecal coliform or *E. coli* bacteria in the drinking water supply. A non-acute violation indicates a public water system detected total coliform bacteria in greater than five percent of the water samples analyzed in a month from the drinking water supply.

From Table A and B a total of 37 acute violations were incurred by 33 PWSs. This compares to a total of 58 acute violations during the previous year by 53 PWSs, or a decrease of 36% and 38%, respectively. Non-acute violations increased during 2005 from the previous year. During 2005 a total of 606 non-acute violations incurred by 442 PWSs compared to 505 violations by 399 PWSs in 2004, or an increase of 20% and 11%, respectively.

There were also 725 significant monitoring and/or reporting violations incurred by 583 PWSs. These violations were issued for failure to conduct the required bacteriological monitoring for coliform bacteria, the required follow-up monitoring of their water systems, or failure to contact the Department. These violations were slightly down from the 799 violations reported during 2004 by 582 PWSs.

Total coliforms are common in the environment and are generally not harmful themselves. The presence of these bacteria in drinking water, however, generally is a result of a problem with water treatment or the pipes which distribute the water, and indicates that the water may be contaminated with organisms that can cause disease. Disease symptoms may include diarrhea, cramps, nausea, and possibly jaundice, and any associated headaches and fatigue. These symptoms, however, are not just associated with disease-causing organisms in drinking water, but also may be caused by a number of factors other than the drinking water. The Department has set a drinking water standard for total coliforms to reduce the risk of these adverse health effects. Under this standard, no more than 5.0 percent of the samples collected during a month can contain these bacteria, except that systems collecting fewer than 40 samples/month that have one total coliform-positive sample per month are not violating the standard. Drinking water which meets this standard is usually not associated with a health risk from disease-causing bacteria and should be considered safe.

Fecal coliforms and *E. coli* are generally not harmful themselves, but their presence in drinking water is serious because they usually are associated with sewage or animal

wastes. The presence of these bacteria in drinking water is generally a result of a problem with water treatment or the pipes which distribute the water, and indicates that the water may be contaminated with organisms that can cause disease. Disease symptoms may include diarrhea, cramps, nausea, and possibly jaundice, and associated headaches and fatigue. These symptoms, however, are not just associated with disease-causing organisms in drinking water, but also may be caused by a number of factors other than the drinking water. The Department has set an enforceable drinking water standard for fecal coliforms and *E. coli* to reduce the risk of these adverse health effects. Under this standard all drinking water samples must be free of these bacteria. Drinking water which meets this standard is associated with little or none of this risk and should be considered safe.

▪ **DISINFECTANTS AND DISINFECTION BYPRODUCTS RULE**

PWSs are required to meet primary drinking water standards and monitoring requirements for three disinfectants, and five disinfection byproduct contaminants which can form when chemical disinfectants are added to drinking water sources. Table A indicated 100 treatment technique and MCL violations incurred for three of the five disinfection byproduct contaminants, and 170 monitoring or reporting violations incurred for one disinfectant, three disinfection byproduct contaminants and general reporting requirements. The number of treatment technique and contaminant MCL violations for the year 2005 increased significantly from the 18 treatment technique and contaminant MCL violations reported during 2004. This increase is attributed mainly to the fact that PWSs serving surface water with less than 10,000 people were required to begin complying with the DBPR as of January 2004 and were not meeting the lower running annual average MCL levels for trihalomethanes (THMs) and haloacetic acids (HAAs), which largely occurred during 2005.

Table B indicates the 100 treatment technique and MCL violations were issued to 43 PWSs, a marked increase from the nine PWSs the year before. However, the 43 PWSs represent a 99.4% compliance by all PWSs. An estimated population of 108,559 was exposed to the treatment technique and MCL violations during the year, or 0.30% of the state population served by PWSs.

The Department sets drinking water standards and requires the disinfection of drinking water. However, when used in the treatment of drinking water, disinfectants react with naturally-occurring organic and inorganic matter present in water to form chemicals called disinfection byproducts (DBPs). The Department has determined that a number of DBPs are a health concern at certain levels of exposure. Certain DBPs, including some THMs and some HAAs, have been shown to cause cancer in laboratory animals. Other DBPs have been shown to affect the liver and the nervous system, and cause reproductive or developmental effects in laboratory animals. Exposure to certain DBPs may produce similar effects in people. DHS has set standards to limit exposure to THMs, HAAs, and other DBPs. Drinking water which meets these standards is associated with little to none of these risks.

- **SURFACE WATER TREATMENT RULE, ENHANCED SURFACE WATER TREATMENT RULE (ESWTR)**

The Surface Water Treatment Rule (SWTR) and Enhanced Surface Water Treatment Rule (ESWTR) establish monitoring and reporting requirements, treatment techniques, performance standards, and turbidity standards to be met by PWSs using surface water as a drinking water source. For purposes of this report, the ESWTR includes the Interim Enhanced SWTR for PWSs serving 10,000 or more people, and the Long Term One ESWTR (LT1-ESWTR), which is essentially the same regulation for PWSs serving less than 10,000 people.

Treatment techniques and performance standards are used to establish water quality objectives instead of MCL's for microbiological contaminants that may be found in surface waters including *Giardia lamblia*, *Cryptosporidium parvum*, Legionella, heterotrophic plate count bacteria, and viruses. PWSs that use surface water are required to provide multi-barrier treatment to protect against adverse health effects from microbiological contaminants. All multi-barrier treatment systems must include the use of a filtration technology approved by the Department. PWSs may be approved by the Department to use surface water without providing filtration under certain conditions and requirements.

Table A indicated 70 violations occurred during 2005 by 41 PWSs for turbidity exceedances and other treatment techniques required by the SWTR and the ESWTR. This increased from the 39 violation by 28 PWSs reported during 2004 for similar requirements. The increase is attributed to the effective compliance date of January 14, 2005 for the LT1-ESWTR and its impact on PWSs serving surface water with less than 10,000 people. Of the 41 PWSs contributing to the 70 violations, 39 PWSs served less than 10,000 people. The 70 violations affected a total estimated population of 219,242 people, significantly lower than the 3.8 million people impacted by 39 violations during 2004. During 2005, 17 monitoring and reporting violations were issued to PWSs. This number was slightly up from the 15 violations reported during 2004.

Treatment technique violations under the Surface Water Treatment Rule and the Enhanced Surface Water Treatment Rule are typically incurred due to elevated turbidity levels in the water or a failure to maintain the required level of disinfection. Turbidity has no health effects. However, high levels of turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

- **FILTER BACKWASH RECYCLING RULE (FBR)**

There were no FBR violations issued by the Department during the 2005 calendar year.

- **LEAD AND COPPER RULE**

PWSs are required to meet primary drinking water standards and monitoring and reporting requirements for lead and copper, when monitored from customers' water taps. Table A and B indicate that no MCL violations occurred for lead or copper; however, 17 monitoring or reporting violations occurred by 15 PWSs during 2005. No violations were reported during the previous year.

- **PUBLIC NOTIFICATION**

A single violation occurred during 2005 for a PWS failing to notify its customers of a monthly total coliform MCL exceedance. No public notification violations were issued during 2004.

- **CONSUMER CONFIDENCE REPORT VIOLATIONS**

PWSs are required to provide to their customers a report each year of the quality of the water being served by their water system. This report, the Consumer Confidence Report, also includes information on the source of drinking water, the levels of any detected contaminants, and compliance with drinking water regulations by including a clear and understandable explanation of the nature of the violation, its potential adverse health effects, steps that the PWS is undertaking to correct the violation and the possibility of alternative water supplies available during the violation. During 2005 a total of 213 consumer notification violations were issued to 210 PWSs compared to 168 violations by 168 PWSs during 2004. This number of violations represents a 27% increase. Of the 210 PWSs in violation of the reporting requirement, 205 of the PWSs each served less than 1,000 people.

SECTION IV: Enforcement Activities

In response to the violations identified in this report, the Department issued a total of 955 enforcement letters, 270 citations, and 22 compliance orders to the affected PWSs. This aggressive enforcement action, along with routine field inspections, is a key element of the Department's overall regulatory strategy to bring all public water systems into full compliance with all of the drinking water standards and regulations to ensure all Californians receive safe drinking water.

The Department's enforcement actions against a public water system that violates a primary drinking water standard vary according to the type of contaminant and the

specific health risk from exposure to the contaminant in the drinking water. Typically, the Department will require a public water system to immediately perform one or more of the following items depending upon the severity of the public health risk:

- Cease operation of the water system and provide an alternate source of safe drinking water.
- Shutdown or abandon the contaminated drinking water source.
- Conduct additional water quality monitoring to identify the cause and extent of the contamination and take appropriate corrective action.
- Modify the water treatment processes to eliminate the contamination.
- Provide notification of the drinking water contamination to water consumers and identify the potential health risks.
- Issue a “Boil Water Notice” (for bacteriological contamination) or “Do Not Drink Notice” (for contamination by other regulated contaminants).

For treatment technique and monitoring violations, the Department will require the public water system to conduct the required contaminant monitoring program and/or provide the appropriate water treatment.

Additional enforcement actions available to the Department include revoking or suspending a public water system’s operating permit, assessing civil penalties up to \$25,000 per day for each day a drinking water standard violation occurs, or placing a public water system into receivership.

SECTION V: CONCLUSION

Overall, public water systems in California delivered drinking water that generally met all of the established state and federal drinking water standards. The following table lists the estimated populations impacted by the categories of MCL or treatment technique violations discussed in the previous section to this report and as a relative percentage of the total population served by PWSs.

Violation Category	Impacted Population	Percent of Total Population
Inorganic Contaminants	14,088	0.04%
Synthetic Organic contaminants	273	0.00%
Volatile Organic Contaminants	0	0.00%
Radionuclide Contaminants	820	0.00%
Total Coliform Rule (acute)	6,318	0.02%

Violation Category	Impacted Population	Percent of Total Population
Total Coliform Rule (non-acute)	490,496	1.36%
Disinfectants/Disinfection Byproducts Rule	108,559	0.30%
Surface Water Treatment Rules	219,242	0.61%
Lead and Copper Rule	0	0.00%
Public Notification Rule	0	0.00%
Consumer Confidence Notification	0	0.00%
Violations Subtotal	839,796	2.33%
Total PWSs population	36,100,000	100.00%

It is not uncommon to have multiple violations issued to the same PWS from different violation categories. Table C in Appendix C provides the actual total number of PWSs issued MCL or treatment technique violations during 2005 and the total population of the PWSs. This population, 819,314 people, is less than the impacted population listed in the table above.

The success of the Department, as the primacy agency responsible for the administration and enforcement of the SDWA requirements in California, will continue by adopting statutes and regulations to implement the requirements of the SDWA and regulate responsibility over PWSs through issuing operating permits, conducting inspections, monitoring for compliance with regulations, and taking enforcement action to compel compliance when violations are identified.

A copy of the 2005 Annual Compliance Report is available to the public by contacting the Department at (916) 449-5600 or through the Department's website at: www.dhs.ca.gov/ps/ddwem/publications/pubindex.htm

APPENDIX A

Summary of Public Water System Violations (By Contaminant)

Appendix A
State Of California
2005 Annual Compliance Report

Table A

Contaminant		MCL ^(a) (mg/L)	MCLs		Monitoring, Reporting, and Recording	
Code	Name		Number or Violations	Number of PWSs	Number or Violations	Number of PWSs
Inorganic Contaminant Violations						
1005	Arsenic	0.05	9	3	2	2
1010	Barium	1	1	1	0	0
1015	Cadmium	0.005	1	1	0	0
1025	Fluoride	2.0	2	1	1	1
1038	Nitrate + Nitrite (Sum as N)	10	1	1	0	0
1040	Nitrate as (NO ₃)	45	87	58	103	90
Counts / Totals			101		106	
Synthetic Organic Contaminant Violations						
2931	Dibromochloropropane (DBCP)	0.0002	4	4	3	1
Counts / Totals			4		3	
Volatile Organic Contaminant Violations						
2981	1,1,1-Trichloroethane		0	0	1	1
2988	1,1,2,2-Tetrachloroethane		0	0	1	1
2904	1,1,2-Trichloro-1,2,2-Trifluoroethane		0	0	1	1
2985	1,1,2-Trichloroethane		0	0	1	1
2978	1,1-Dichloroethane		0	0	1	1
2977	1,1-Dichloroethylene		0	0	1	1
2378	1,2,4-Trichlorobenzene		0	0	1	1
2967	1,2-Dichlorobenzene		0	0	1	1
2980	1,2-Dichloroethane		0	0	1	1
2983	1,2-Dichloropropane		0	0	1	1
2413	1,3-Dichloropropene (Total)		0	0	1	1
2969	1,4-Dichlorobenzene		0	0	1	1
2990	Benzene		0	0	1	1
2982	Carbon Tetrachloride		0	0	1	1
2380	Cis-1,2-Dichloroethylene		0	0	1	1
2964	Dichloromethane		0	0	1	1
2992	Ethylbenzene		0	0	1	1
2989	Monochlorobenzene		0	0	1	1
2996	Styrene		0	0	1	1
2987	Tetrachloroethylene		0	0	1	1
2991	Toluene		0	0	2	2
2979	Trans-1,2-Dichloroethylene		0	0	1	1
2984	Trichloroethylene		0	0	2	2
2218	Trichlorofluoromethane		0	0	1	1
2976	Vinyl Chloride		0	0	1	1
2955	Xylenes (Total)		0	0	1	1
Counts / Totals			0		28	
Radionuclide Contaminant Violations						
4000	Gross Alpha		0	0	2	2
4006	Uranium	0.030	3	3	3	1
Counts / Totals			3		5	

Appendix A
State Of California
2005 Annual Compliance Report

Table A

Contaminant		MCL ^(a) (mg/L)	MCLs		Monitoring, Reporting, and Recording	
Code	Name		Number or Violations	Number of PWSs	Number or Violations	Number of PWSs
Total Coliform Rule (TCR) Violations						
3100	Coliforms - Acute MCL	Absence	37	33	0	0
3100	Total Coliform - Non acute MCL	Absence	606	442	0	0
3100	Total Coliform-routine monitoring		0	0	650	515
3100	Total Coliform-followup monitoring		0	0	75	68
Counts / Totals			643		725	
Disinfectant and Disinfection Byproducts Rule (DBPR) Violations						
2456	Haloacetic Acids (HAA-5)	0.060	41	21	68	67
2950	Total Trihalomethanes (TTHMs)	0.080	57	31	66	65
2920	Total Organic Carbon (TOC)	TT	2	1	1	1
0400	Stage 1 - DBP (Monitoring Plan)		0	0	6	3
0999	Stage 1 - DBP (Chlorine)		0	0	29	27
Counts / Totals			100		170	
Surface Water Treatment Rule (SWTR) and Enhanced Surface Water Treatment Rules (ESWTR)^(b) Violations						
0200	SWTR - treatment technique (41)	TT	56	34	0	0
0300	ESWTR - turbidity >1 NTU (43)	TT	2	2	0	0
0300	ESWTR - turbidity >0.3 NTU (44)	TT	12	8	0	0
0200	SWTR-unfiltered sys-monitoring (31)		0	0	4	4
0200	SWTR-filtered sys-monitoring (36)		0	0	12	9
0300	ESWTR-filtered sys-monitoring (38)		0	0	1	1
Counts / Totals			70		17	
Lead and Copper Rule (LCR) Violations						
5000	LCR - Initial monitoring		0	0	9	9
5000	LCR - Routine&followup monitoring		0	0	8	6
Counts / Totals			0		17	
Public Notification (PN) Violations						
75	Public Notification-Total Coliform		0	0	1	1
Counts / Totals			0		1	
Consumer Confidence Report (CCR) Violations						
7000	Consumer Confidence Report		0	0	213	210
Counts / Totals			0		213	

Footnotes:

a.....State MCL levels provided when MCL violations occurred. Treatment technique listed as "TT".

b.....Enhanced Surface Water Treatment Rules include Interim Enhanced SWTR (IESWTR) and the Long Term 1 Enhanced SWTR (LT1ESWTR)

APPENDIX B

Summary of Public Water System Violations (By Contaminant Category)

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
Inorganic Contaminant Violations							
1010	Barium	1	1210023	Loleta C.S.D.	750	1	
1040	Nitrate as (NO ₃)	45	1510025	Stallion Springs C.S.D.	4300	1	
1040	Nitrate as (NO ₃)	45	1910244	Green Valley C.W.D.	1000	1	
1038	Nitrate + Nitrite (Sum as N)	10	2700665	Oak Heights W & R Co Inc	105	1	
1040	Nitrate as (NO ₃)	45	2700665			2	
1040	Nitrate as (NO ₃)	45	2700856	Altman Plants WS #01	45	1	
1040	Nitrate as (NO ₃)	45	2701036	Apple Ave WS #03	60	1	
1005	Arsenic	0.05	2701670	Langley/Valle Pacifico WS	81	1	
1040	Nitrate as (NO ₃)	45	2701904	San Jerardo Coop WS	249	1	
1025	Fluoride	2.0	2702148	Asoleado MWC	52	2	
1040	Nitrate as (NO ₃)	45	2702482	Color Spot Nursery WS #02	25	1	
1005	Arsenic	0.05	2702550	Grange Hall WS	25	3	
1040	Nitrate as (NO ₃)	45	2702566	Premium Fresh Farms Ws	25	1	
1015	Cadmium	0.005	2702588	Canada Woods WC	216	1	
1040	Nitrate as (NO ₃)	45	3500526	Arnold Park (O'Bannon's MHP)	28	4	
1005	Arsenic	0.05	3500810	Whispering Pines Retire Home (LSWS)	100	5	
1040	Nitrate as (NO ₃)	45	3600456	Prado Regional Park	25	1	
1040	Nitrate as (NO ₃)	45	3700912	YMCA Camp Marston/Raintree	300	5	
1040	Nitrate as (NO ₃)	45	3700963	Potrero Elementary School	250	1	
1040	Nitrate as (NO ₃)	45	3701241	Al Bahr Shrine Camp	150	1	
1040	Nitrate as (NO ₃)	45	3900983	Cherry Lane Trailer Park	100	1	
1040	Nitrate as (NO ₃)	45	3901377	French Camp Golf Course	25	1	
1040	Nitrate as (NO ₃)	45	3901382	O-G Packing Co	25	1	
1040	Nitrate as (NO ₃)	45	5000208	Neighborhood Church - Modesto Christian	220	1	
1040	Nitrate as (NO ₃)	45	5100176	Calvary Temple Assembly Of God	250	1	
1040	Nitrate as (NO ₃)	45	5100176	Calvary Temple Assembly Of God	250	3	
1040	Nitrate as (NO ₃)	45	5400507	Visalia - Fresno South KOA	150	1	
1040	Nitrate as (NO ₃)	45	5400541	Paramount Citrus	100	1	
1040	Nitrate as (NO ₃)	45	5400545	Norseman M.H.P.	70	1	
1040	Nitrate as (NO ₃)	45	5400548	Kings Inn Motel	130	2	
1040	Nitrate as (NO ₃)	45	5400555	Citrus South Tule School	34	1	
1040	Nitrate as (NO ₃)	45	5400567	Tooleville Water Co.	300	1	
1040	Nitrate as (NO ₃)	45	5400616	Lemon Cove Water Co.	200	1	
1040	Nitrate as (NO ₃)	45	5400636	Orosi High School	900	1	
1040	Nitrate as (NO ₃)	45	5400651	Beverly-Grand Mutual Water	108	3	
1040	Nitrate as (NO ₃)	45	5400660	Lake Success Mobile Lodge	20	2	
1040	Nitrate as (NO ₃)	45	5400663	Fairways Tract Mutual	250	1	
1040	Nitrate as (NO ₃)	45	5400670	Triple R Mutual Water Co.	400	2	
1040	Nitrate as (NO ₃)	45	5400735	Rodriquez Labor Camp	110	1	
1040	Nitrate as (NO ₃)	45	5400795	Waukena Elementary School	230	3	
1040	Nitrate as (NO ₃)	45	5400805	Souls Mutual Water Co.	100	3	
1040	Nitrate as (NO ₃)	45	5400918	Open Country Flea Mart	300	1	
1040	Nitrate as (NO ₃)	45	5400919	Buena Vista School	130	3	
1040	Nitrate as (NO ₃)	45	5401004	Styrotek	36	2	
1040	Nitrate as (NO ₃)	45	5401053	Charlie's	150	3	
1040	Nitrate as (NO ₃)	45	5401096	Sun Pacific-Woodlake	95	1	
1040	Nitrate as (NO ₃)	45	5402013	Sun Pacific-Exeter	200	1	
1040	Nitrate as (NO ₃)	45	5402022	Traver Valley Farms - Texaco	25	1	
1040	Nitrate as (NO ₃)	45	5402024	Kings River Market	25	1	
1040	Nitrate as (NO ₃)	45	5402025	Lakeside Minnit Mart	25	1	
1040	Nitrate as (NO ₃)	45	5402041	Penny Wise Motel	25	1	
1040	Nitrate as (NO ₃)	45	5402043	Monson Market	25	1	
1040	Nitrate as (NO ₃)	45	5402046	Wii Liquidation Inc	225	1	
1040	Nitrate as (NO ₃)	45	5402047	Gleanings For The Hungry	31	1	
1040	Nitrate as (NO ₃)	45	5402056	Peoples Grocery	25	2	
1040	Nitrate as (NO ₃)	45	5403010	Golden State Citrus Packers	75	1	
1040	Nitrate as (NO ₃)	45	5403013	Prince Mart	25	1	
1040	Nitrate as (NO ₃)	45	5403043	Yetterm Water System	350	1	

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
1040	Nitrate as (NO ₃)	45	5403046	Tri County Citrus	80	1	
1040	Nitrate as (NO ₃)	45	5403076	Central Cal Tristeza Erad	25	4	
1040	Nitrate as (NO ₃)	45	5403106	Lo Bue Bros.	99	1	
1040	Nitrate as (NO ₃)	45	5403110	Sierra Mutual Water Co.	39	2	
1040	Nitrate as (NO ₃)	45	5700757	Yolo Bowmens Club	50	1	
1040	Nitrate as (NO ₃)	45	5700817	Jehovah'S Witnesses - Kingdom Hall	245	1	
1040	Nitrate as (NO ₃)	45	5700827	Pioneer Hi-Bred International	25	1	
Counts / Totals				64	14088	101	
1040	Nitrate as (NO ₃)		1010028	Riverdale Public Utility District	3000		1
1005	Arsenic		2700552	Echo Valley School WS	400		1
1040	Nitrate as (NO ₃)		2700634	Chetmoore Acres Wa	50		1
1040	Nitrate as (NO ₃)		2700713	Rolling Hills Rancho Wa	177		1
1040	Nitrate as (NO ₃)		2700856	Altman Plants Ws #01	45		2
1040	Nitrate as (NO ₃)		2701153	Growers Transplanting WS	50		1
1025	Fluoride		2701232	Old Natividad Rd WS #01	25		1
1040	Nitrate as (NO ₃)		2701701	Bradley-Lockwood Rd WS	39		1
1040	Nitrate as (NO ₃)		2701876	Mushroom Farms WS	75		1
1040	Nitrate as (NO ₃)		2702007	Vierra Estates WS	164		1
1040	Nitrate as (NO ₃)		2702293	Rod Mclellan Botanicals WS	45		1
1040	Nitrate as (NO ₃)		2702409	El Camino WC Inc	90		1
1005	Arsenic		2702550	Grange Hall WS	25		1
1040	Nitrate as (NO ₃)		2710010	CWSC Salinas	127750		1
1040	Nitrate as (NO ₃)		2710021	Toro Water Service	1340		1
1040	Nitrate as (NO ₃)		3310036	Western MWD - Murrieta Division	7200		3
1040	Nitrate as (NO ₃)		3400284	Foothill Golf Center	200		3
1040	Nitrate as (NO ₃)		3500563	Mccormick Selph, Inc.	350		1
1040	Nitrate as (NO ₃)		3500817	Lico Labor Camp	49		1
1040	Nitrate as (NO ₃)		3700003	Whispering Winds Conference Center	160		1
1040	Nitrate as (NO ₃)		3700011	Stelzer County Park	25		1
1040	Nitrate as (NO ₃)		3700013	Descanso Junction	50		1
1040	Nitrate as (NO ₃)		3700042	Lakeland Resort	25		1
1040	Nitrate as (NO ₃)		3700049	Potrero General Store	800		1
1040	Nitrate as (NO ₃)		3700063	Freedom Ranch	50		1
1040	Nitrate as (NO ₃)		3700072	William Heise County Park	850		1
1040	Nitrate as (NO ₃)		3700074	Cuyamaca Water District	200		1
1040	Nitrate as (NO ₃)		3700174	Diamond Jacks Rv Ranch	120		1
1040	Nitrate as (NO ₃)		3700195	Outdoor World Retreat	300		1
1040	Nitrate as (NO ₃)		3700276	Oak Knoll Campground	500		1
1040	Nitrate as (NO ₃)		3700277	Sunrise Estates Mutual Water Company	200		1
1040	Nitrate as (NO ₃)		3700846	Agua Caliente County Park	400		1
1040	Nitrate as (NO ₃)		3700847	Lake Hodges Boat Facility	100		1
1040	Nitrate as (NO ₃)		3700848	Alpine Springs RV Park	200		1
1040	Nitrate as (NO ₃)		3700865	Lake Cuyamaca Park & Rec.	600		1
1040	Nitrate as (NO ₃)		3700895	El Monte County Park	25		1
1040	Nitrate as (NO ₃)		3700911	Whispering Oaks Program Center	120		1
1040	Nitrate as (NO ₃)		3700912	Ymca Camp Marston/Raintree	300		1
1040	Nitrate as (NO ₃)		3700931	Vallecito County Park	145		1
1040	Nitrate as (NO ₃)		3700933	Palomar Mountain Mutual Water Co.	70		1
1040	Nitrate as (NO ₃)		3700959	Warner Springs Ranch Owners Assoc.	155		1
1040	Nitrate as (NO ₃)		3700964	Swallows Sun Island Club	50		1
1040	Nitrate as (NO ₃)		3700968	San Pasqual Academy	150		1
1040	Nitrate as (NO ₃)		3701010	Warner Unified School District	400		1
1040	Nitrate as (NO ₃)		3701070	Pinecrest Community Center	70		1
1040	Nitrate as (NO ₃)		3701217	Camp Virginia	25		1
1040	Nitrate as (NO ₃)		3701341	Butterfield Oaks Mobile Home Park	80		1
1040	Nitrate as (NO ₃)		3701380	R & B Wholesale Distributors	50		1
1040	Nitrate as (NO ₃)		3701390	Lux Inn	100		1
1040	Nitrate as (NO ₃)		3701407	Angels Landing Country Inn And Resort	30		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
1040	Nitrate as (NO ₃)		3701476	Indian Hills Camp	160		1
1040	Nitrate as (NO ₃)		3701518	Narconon Southern California	40		1
1040	Nitrate as (NO ₃)		3701588	Jacumba Valley Ranch Water Company	25		1
1040	Nitrate as (NO ₃)		3701780	Richardson Beardsley Inc.	38		1
1040	Nitrate as (NO ₃)		3701934	Pine Valley Bible Conference Center	38		1
1040	Nitrate as (NO ₃)		3701982	Palomar Christian Conference Center	325		1
1040	Nitrate as (NO ₃)		3701988	Alpine Oaks Mobile Estates	125		1
1040	Nitrate as (NO ₃)		3701995	Willowside Terrace Water Association	100		1
1040	Nitrate as (NO ₃)		3702181	K.Q. Ranch Camping Resort	650		1
1040	Nitrate as (NO ₃)		3702235	Mobiland Camper Park	320		1
1040	Nitrate as (NO ₃)		3702253	Dulzura Cafe	50		1
1040	Nitrate as (NO ₃)		3702319	Camp Winacka	250		1
1040	Nitrate as (NO ₃)		3702349	Rancho L'Abri	25		1
1040	Nitrate as (NO ₃)		3702459	Camp Oliver	70		1
1040	Nitrate as (NO ₃)		3702479	Camp Feed & Supply	50		1
1040	Nitrate as (NO ₃)		3702754	Rancho Corrido Campground	300		1
1040	Nitrate as (NO ₃)		3705026	Erreca'S Associates	25		1
1040	Nitrate as (NO ₃)		4100532	Cutter Scout Reservation	25		1
1040	Nitrate as (NO ₃)		4100555	Portola Improvement Association	74		1
1040	Nitrate as (NO ₃)		5000109	Ceres Unified/Westport School	100		1
1040	Nitrate as (NO ₃)		5100117	National American Corp. Lp-Lake Minden	1000		1
1040	Nitrate as (NO ₃)		5103325	South Ridge Golf Course	25		1
1040	Nitrate as (NO ₃)		5400542	Ducor C.S.D.	500		1
1040	Nitrate as (NO ₃)		5400628	Lemon Cove-Sequoia Camp	100		1
1040	Nitrate as (NO ₃)		5400660	Lake Success Mobile Lodge	20		1
1040	Nitrate as (NO ₃)		5400666	Watertek - Grandview Gardens	350		1
1040	Nitrate as (NO ₃)		5400709	Sequoia Union School	400		1
1040	Nitrate as (NO ₃)		5400711	Sierra View Jr Academy	160		2
1040	Nitrate as (NO ₃)		5400795	Waukena Elementary School	230		1
1040	Nitrate as (NO ₃)		5400810	Akal Travel Plaza	200		1
1040	Nitrate as (NO ₃)		5400918	Open Country Flea Mart	300		2
1040	Nitrate as (NO ₃)		5400931	Truckers Mini Mart	25		1
1040	Nitrate as (NO ₃)		5400986	Deer Creek Lodge	46		1
1040	Nitrate as (NO ₃)		5400987	Fountain Springs El Tapatio	25		1
1040	Nitrate as (NO ₃)		5401003	East Orosi C.S.D.	106		3
1040	Nitrate as (NO ₃)		5401038	Akin Water Co.	50		2
1040	Nitrate as (NO ₃)		5402024	Kings River Market	25		2
1040	Nitrate as (NO ₃)		5402025	Lakeside Minnit Mart	25		1
1040	Nitrate as (NO ₃)		5402047	Gleanings For The Hungry	31		2
1040	Nitrate as (NO ₃)		5402056	Peoples Grocery	25		1
1040	Nitrate as (NO ₃)		5403013	Prince Mart	25		1
1040	Nitrate as (NO ₃)		5403030	Foothill Fruit Co.	50		2
1040	Nitrate as (NO ₃)		5403106	Lo Bue Bros.	99		1
Counts / Totals			93		154031		106
Synthetic Organic Contaminant Violations							
2931	Dibromochloropropane (DBCP)	0.0002	1000371	Central Unified/District Office	30	1	
2931	Dibromochloropropane (DBCP)	0.0002	5400554	Western Sky M.H.P.	108	1	
2931	Dibromochloropropane (DBCP)	0.0002	5400558	Saucelito Elem School	75	1	
2931	Dibromochloropropane (DBCP)	0.0002	5400634	Lovell School	60	1	
Counts / Totals			4		273	4	
2931	Dibromochloropropane (DBCP)		5400526	Enns Packing Co	50		3
Counts / Totals			1		50		3
Volatile Organic Contaminant Violations							
2991	Toluene		2701232	Old Natividad Rd Ws #01	25		1
2218	Trichlorofluoromethane		4100555	Portola Improvement Association	74		1
2378	1,2,4-Trichlorobenzene		4100555				1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
2380	Cis-1,2-Dichloroethylene		4100555				1
2413	1,3-Dichloropropene (Total)		4100555				1
2904	1,1,2-Trichloro-1,2,2-Trifluoroethane		4100555				1
2955	Xylenes (Total)		4100555				1
2964	Dichloromethane		4100555				1
2967	1,2-Dichlorobenzene		4100555				1
2969	1,4-Dichlorobenzene		4100555				1
2976	Vinyl Chloride		4100555				1
2977	1,1-Dichloroethylene		4100555				1
2978	1,1-Dichloroethane		4100555				1
2979	Trans-1,2-Dichloroethylene		4100555				1
2980	1,2-Dichloroethane		4100555				1
2981	1,1,1-Trichloroethane		4100555				1
2982	Carbon Tetrachloride		4100555				1
2983	1,2-Dichloropropane		4100555				1
2984	Trichloroethylene		4100555				1
2985	1,1,2-Trichloroethane		4100555				1
2987	Tetrachloroethylene		4100555				1
2988	1,1,2,2-Tetrachloroethane		4100555				1
2989	Monochlorobenzene		4100555				1
2990	Benzene		4100555				1
2991	Toluene		4100555				1
2992	Ethylbenzene		4100555				1
2996	Styrene		4100555				1
2984	Trichloroethylene		4410014	San Lorenzo Valley Water Dist	19000		1
Counts / Totals			3		19099		28
Radionuclide Violations							
4006	Uranium	0.030	1500561	Round Mountain Water Company	50	1	
4006	Uranium	0.030	5400545	Norseman M.H.P.	70	1	
4006	Uranium	0.030	5400665	River Island Service Terr #1	700	1	
Counts / Totals			3		820	3	
4000	Gross Alpha		2700511	Normco Wc	868		1
4000	Gross Alpha		4410002	Cal-Am Water Company - Felton	4340		1
4006	Uranium		5403103	Tract 327 Mutual Water Co.	24		3
Counts / Totals			3		5232		5
Total Coliform Rule (TCR) Violations							
3100	Coliforms - Acute MCL	Absence	706105	D Anna Yacht Center	30	1	
3100	Coliforms - Acute MCL	Absence	706107	Carson Swim School	35	1	
3100	Coliforms - Acute MCL	Absence	707597	Sandy Point Mobile Home Park	94	1	
3100	Coliforms - Acute MCL	Absence	707603	Clayton Regency Water	305	1	
3100	Coliforms - Acute MCL	Absence	900212	Lotus Park Water System	300	1	
3100	Coliforms - Acute MCL	Absence	1000447	E&J Gallo Winery	50	1	
3100	Coliforms - Acute MCL	Absence	1600240	Rubalcava Water System	25	1	
3100	Coliforms - Acute MCL	Absence	2202036	KOA Campground	250	1	
3100	Coliforms - Acute MCL	Absence	3000759	Canyon Rv Park	300	1	
3100	Coliforms - Acute MCL	Absence	3103294	8200 Water System	1000	1	
3100	Coliforms - Acute MCL	Absence	3200188	Greenhorn Creek Services District	130	2	
3100	Coliforms - Acute MCL	Absence	3900748	Escalon Usd- Collegeville Sch	100	1	
3100	Coliforms - Acute MCL	Absence	3901312	Turner Rd Vintners East	100	1	
3100	Coliforms - Acute MCL	Absence	4300985	Ludewig's Christmas Tree Farm	25	1	
3100	Coliforms - Acute MCL	Absence	4400717	Kennolyn Camp	200	1	
3100	Coliforms - Acute MCL	Absence	4400750	Aptos High School	1925	1	
3100	Coliforms - Acute MCL	Absence	4500012	Cascade Racquet Club Mutual Water	100	1	
3100	Coliforms - Acute MCL	Absence	4500143	Rooster'S Landing	65	1	
3100	Coliforms - Acute MCL	Absence	4500277	USFS Yolla Bolla Corp Yard	120	1	
3100	Coliforms - Acute MCL	Absence	4900708	Gravenstein School District-Gravenstein	400	1	

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Coliforms - Acute MCL	Absence	4900844	Francis Coppola Winery	80	1	
3100	Coliforms - Acute MCL	Absence	4901176	Sonoma Coast Villa	25	1	
3100	Coliforms - Acute MCL	Absence	4901197	Silver Oak Wine Cellars L.P.	25	3	
3100	Coliforms - Acute MCL	Absence	4901232	La Crema Winery	75	1	
3100	Coliforms - Acute MCL	Absence	4901254	Buena Vista Carneros Production Area	100	1	
3100	Coliforms - Acute MCL	Absence	4901298	Lynmar Winery	8	1	
3100	Coliforms - Acute MCL	Absence	5200550	Orchard Mobile Home Park	56	1	
3100	Coliforms - Acute MCL	Absence	5200579	Wilcox Oaks Golf Club	25	1	
3100	Coliforms - Acute MCL	Absence	5200581	Forest Inn, The	25	1	
3100	Coliforms - Acute MCL	Absence	5402022	Traver Valley Farms - Texaco	25	1	
3100	Coliforms - Acute MCL	Absence	5500102	Red Barn	25	1	
3100	Coliforms - Acute MCL	Absence	5500132	Marble Quarry Resort	250	1	
3100	Coliforms - Acute MCL	Absence	5500363	Mdwc:Wards Ferry Ranches	45	2	
Counts / Totals			33		6318	37	
3100	Total Coliform - Non acute MCL	Absence	210003	Caltrans-Caples Lake Maintenance Station	30	1	
3100	Total Coliform - Non acute MCL	Absence	300022	Camp Winton	999	2	
3100	Total Coliform - Non acute MCL	Absence	300074	So. Silver Lake Homeowners	100	1	
3100	Total Coliform - Non acute MCL	Absence	410008	Thermalito I.D.	8750	1	
3100	Total Coliform - Non acute MCL	Absence	500009	United Parcel Service	75	1	
3100	Total Coliform - Non acute MCL	Absence	500027	Lili Valley Water Co.	99	1	
3100	Total Coliform - Non acute MCL	Absence	500068	Dunrovin Mobile Home Village	99	1	
3100	Total Coliform - Non acute MCL	Absence	706007	Villa De Guadalupe	55	1	
3100	Total Coliform - Non acute MCL	Absence	706027	Orin Allen Youth Rehab Facility	600	1	
3100	Total Coliform - Non acute MCL	Absence	706101	Roddy Ranch Golf Course	75	1	
3100	Total Coliform - Non acute MCL	Absence	707625	Golden Eagle Refinery	600	2	
3100	Total Coliform - Non acute MCL	Absence	800605	West Park Properties	60	1	
3100	Total Coliform - Non acute MCL	Absence	800861	Reservation Ranch	50	1	
3100	Total Coliform - Non acute MCL	Absence	900112	Candlelight Village Water Syst	35	1	
3100	Total Coliform - Non acute MCL	Absence	900502	Pyramid Creek Trailhead	500	1	
3100	Total Coliform - Non acute MCL	Absence	900578	Pistante'S Coyote Den	32	1	
3100	Total Coliform - Non acute MCL	Absence	900655	Rockwater Apts.	50	1	
3100	Total Coliform - Non acute MCL	Absence	900660	Heavenly Ski Resort	1000	1	
3100	Total Coliform - Non acute MCL	Absence	901219	Capps Crossing Campground	25	1	
3100	Total Coliform - Non acute MCL	Absence	901249	Wench Creek Campground	250	1	
3100	Total Coliform - Non acute MCL	Absence	1000041	Fcwwd #38/Sky Harbour	75	1	
3100	Total Coliform - Non acute MCL	Absence	1000105	Madison Elementary School	900	1	
3100	Total Coliform - Non acute MCL	Absence	1000108	Herndon-Barstow School	350	1	
3100	Total Coliform - Non acute MCL	Absence	1000136	Usts/Trimmer Ranger Station	60	1	
3100	Total Coliform - Non acute MCL	Absence	1000204	American Union School	250	1	
3100	Total Coliform - Non acute MCL	Absence	1000206	Houghton-Kearney School	310	2	
3100	Total Coliform - Non acute MCL	Absence	1000207	Pershing High School	56	1	
3100	Total Coliform - Non acute MCL	Absence	1000220	Mckinley Elementary School	500	1	
3100	Total Coliform - Non acute MCL	Absence	1000276	Orange Center School	410	1	
3100	Total Coliform - Non acute MCL	Absence	1000304	Sierra Inn	25	2	
3100	Total Coliform - Non acute MCL	Absence	1000445	Linda Vista Farms	40	1	
3100	Total Coliform - Non acute MCL	Absence	1000485	Ag Formulators	50	1	
3100	Total Coliform - Non acute MCL	Absence	1000537	Johnny Quik Food Store #161*	25	1	
3100	Total Coliform - Non acute MCL	Absence	1000553	Trinity Presbyterian Church	450	1	
3100	Total Coliform - Non acute MCL	Absence	1009020	Five Points Ranch	130	1	
3100	Total Coliform - Non acute MCL	Absence	1010026	Pinedale County Water District	8495	1	
3100	Total Coliform - Non acute MCL	Absence	1010028	Riverdale Public Utility District	3000	1	
3100	Total Coliform - Non acute MCL	Absence	1010034	San Joaquin, City Of	3510	1	
3100	Total Coliform - Non acute MCL	Absence	1010042	Malaga County Water District	900	1	
3100	Total Coliform - Non acute MCL	Absence	1010049	Biola Community Services Dist	1200	2	
3100	Total Coliform - Non acute MCL	Absence	1010800	Miramonte Conservation Camp	105	1	
3100	Total Coliform - Non acute MCL	Absence	1200541	Phillipsville C.S.D.	300	1	
3100	Total Coliform - Non acute MCL	Absence	1200583	Forson Water Company	100	2	
3100	Total Coliform - Non acute MCL	Absence	1200765	Redwood Trails Water System	300	1	

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	1206001	Redwood Empire G&Cc	300	1	
3100	Total Coliform - Non acute MCL	Absence	1210011	Redway C.S.D.	1500	1	
3100	Total Coliform - Non acute MCL	Absence	1400013	Bishop Creek Lodge	58	2	
3100	Total Coliform - Non acute MCL	Absence	1400069	Death Valley Junction	200	1	
3100	Total Coliform - Non acute MCL	Absence	1400072	North Lone Pine Water District	70	1	
3100	Total Coliform - Non acute MCL	Absence	1400098	Darwin Community Services District	60	1	
3100	Total Coliform - Non acute MCL	Absence	1500211	Stockdale Annex Mutual Water	260	3	
3100	Total Coliform - Non acute MCL	Absence	1500252	Kern Valley Mutual Water	100	2	
3100	Total Coliform - Non acute MCL	Absence	1500324	Wonder Acres Water System	83	5	
3100	Total Coliform - Non acute MCL	Absence	1500373	Seventh Standard Mutual	25	1	
3100	Total Coliform - Non acute MCL	Absence	1500436	Hungry Gulch Water System	30	1	
3100	Total Coliform - Non acute MCL	Absence	1500452	Riverdale Village	760	2	
3100	Total Coliform - Non acute MCL	Absence	1500461	Fountain Trailer Park Water	45	1	
3100	Total Coliform - Non acute MCL	Absence	1500478	Valley Estates Poa, Inc.	300	1	
3100	Total Coliform - Non acute MCL	Absence	1500493	EI Adobe Poa, Inc.	200	2	
3100	Total Coliform - Non acute MCL	Absence	1500508	Twin Pines Mobilehome Park	92	2	
3100	Total Coliform - Non acute MCL	Absence	1500516	Tut Brothers Farm #96	100	1	
3100	Total Coliform - Non acute MCL	Absence	1500518	Agbayani Village Water System	100	1	
3100	Total Coliform - Non acute MCL	Absence	1500561	Round Mountain Water Company	50	1	
3100	Total Coliform - Non acute MCL	Absence	1500564	Hometown Water Association	29	1	
3100	Total Coliform - Non acute MCL	Absence	1500585	Oasis Property Owners Association	60	1	
3100	Total Coliform - Non acute MCL	Absence	1502017	Wheeler Farms Headquarters	25	1	
3100	Total Coliform - Non acute MCL	Absence	1502084	Frazier Woods Conference Center	250	1	
3100	Total Coliform - Non acute MCL	Absence	1502093	Harvest Steakhouse	70	1	
3100	Total Coliform - Non acute MCL	Absence	1502153	Lake Isabella Motel & Trailer Park	60	2	
3100	Total Coliform - Non acute MCL	Absence	1502162	Linns Court Mutual Water	60	1	
3100	Total Coliform - Non acute MCL	Absence	1502244	Semi Tropic School Water System	263	2	
3100	Total Coliform - Non acute MCL	Absence	1502249	Camp St Nicholas Water System	125	1	
3100	Total Coliform - Non acute MCL	Absence	1502307	Camp Condor	75	1	
3100	Total Coliform - Non acute MCL	Absence	1502325	Kern Co P&R-Tehachapi Mt Park Water	350	3	
3100	Total Coliform - Non acute MCL	Absence	1502418	Indian Wells Lodge	40	1	
3100	Total Coliform - Non acute MCL	Absence	1502422	Boron Rest Stop Water System	1000	2	
3100	Total Coliform - Non acute MCL	Absence	1502524	Camp Arev	300	1	
3100	Total Coliform - Non acute MCL	Absence	1502622	Gosford Road Water Company	42	1	
3100	Total Coliform - Non acute MCL	Absence	1502685	USFS+H356 - Lk Isabella Office Water System	40	1	
3100	Total Coliform - Non acute MCL	Absence	1502690	Dune Iii Mutual Water Company	70	1	
3100	Total Coliform - Non acute MCL	Absence	1502699	East Wilson Road Water Company	35	2	
3100	Total Coliform - Non acute MCL	Absence	1502826	B&J Land Company	225	1	
3100	Total Coliform - Non acute MCL	Absence	1503209	Superior Mutual Water Company	44	1	
3100	Total Coliform - Non acute MCL	Absence	1503211	DWR-Chrisman Pumping Plant/Wind Gap	130	2	
3100	Total Coliform - Non acute MCL	Absence	1503292	Weatherford U.S., L.P.	50	1	
3100	Total Coliform - Non acute MCL	Absence	1503368	South Fork Middle School	204	1	
3100	Total Coliform - Non acute MCL	Absence	1503475	Western Acres Mutual Water Company	290	3	
3100	Total Coliform - Non acute MCL	Absence	1510004	Casa Loma Water Co, Inc.	600	1	
3100	Total Coliform - Non acute MCL	Absence	1510016	Rand Communities CWD - Randsburg	921	2	
3100	Total Coliform - Non acute MCL	Absence	1510023	Lake Of The Woods MWC	968	1	
3100	Total Coliform - Non acute MCL	Absence	1510032	California City, City Of	11500	1	
3100	Total Coliform - Non acute MCL	Absence	1510302	CSP - Tule Elk	100	2	
3100	Total Coliform - Non acute MCL	Absence	1510703	China Lake Naval Air Weapons Station	4500	2	
3100	Total Coliform - Non acute MCL	Absence	1600013	Lakeside Union School	294	1	
3100	Total Coliform - Non acute MCL	Absence	1610002	Avenal, City Of	16205	2	
3100	Total Coliform - Non acute MCL	Absence	1610005	Lemoore, City Of	21076	1	
3100	Total Coliform - Non acute MCL	Absence	1610700	Lemoore Naval Air Station	10661	1	
3100	Total Coliform - Non acute MCL	Absence	1700715	Jack In The Box - Lakeport, Ca	21	1	
3100	Total Coliform - Non acute MCL	Absence	1700717	Legacy School	40	1	
3100	Total Coliform - Non acute MCL	Absence	1800524	Lassen Mobile Home Park	62	1	
3100	Total Coliform - Non acute MCL	Absence	1800599	PNF-Laufman Admin. Site	25	1	
3100	Total Coliform - Non acute MCL	Absence	1900009	Adams Ranch Mutual	300	1	
3100	Total Coliform - Non acute MCL	Absence	1900075	Bleich Flats Mutual	75	1	

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	1900100	Mettler Valley Mutual	200	1	
3100	Total Coliform - Non acute MCL	Absence	1900301	Shadow Acres Mutual Water Co	300	1	
3100	Total Coliform - Non acute MCL	Absence	1900868	Rivers End Trailer Park	25	1	
3100	Total Coliform - Non acute MCL	Absence	2100545	Walker Creek Ranch Educational Center	100	1	
3100	Total Coliform - Non acute MCL	Absence	2100567	Bothin Youth Center	100	1	
3100	Total Coliform - Non acute MCL	Absence	2210933	BLM-Briceburg Water System	25	1	
3100	Total Coliform - Non acute MCL	Absence	2300503	Sutherland Waterworks	27	1	
3100	Total Coliform - Non acute MCL	Absence	2300610	Caspar South Service Company	125	1	
3100	Total Coliform - Non acute MCL	Absence	2300845	Point Arena Lighthouse Keepers	50	1	
3100	Total Coliform - Non acute MCL	Absence	2300847	Whale Gulch Elementary School	45	1	
3100	Total Coliform - Non acute MCL	Absence	2300892	Covelo Mobile Home Park	30	1	
3100	Total Coliform - Non acute MCL	Absence	2500538	MNF-Blue Lake CG	200	2	
3100	Total Coliform - Non acute MCL	Absence	2500811	Sulley'S Trailer Lodge	30	1	
3100	Total Coliform - Non acute MCL	Absence	2500911	I'Sot Well #3 & #15	215	1	
3100	Total Coliform - Non acute MCL	Absence	2510001	City Of Alturas	2982	1	
3100	Total Coliform - Non acute MCL	Absence	2700509	Oak Manor WS	71	2	
3100	Total Coliform - Non acute MCL	Absence	2700523	Calera Canyon Heights HOA	39	3	
3100	Total Coliform - Non acute MCL	Absence	2700534	Colonial Oaks WC	198	2	
3100	Total Coliform - Non acute MCL	Absence	2700535	Jost Post Wa	60	1	
3100	Total Coliform - Non acute MCL	Absence	2700541	Del Monte Farms Rd WS #03	55	1	
3100	Total Coliform - Non acute MCL	Absence	2700547	Desmond Rd WS #03	55	2	
3100	Total Coliform - Non acute MCL	Absence	2700548	Dolan Rd MWC	120	1	
3100	Total Coliform - Non acute MCL	Absence	2700586	Gabilan WC	454	1	
3100	Total Coliform - Non acute MCL	Absence	2700589	Glenn Ave WS #01	78	1	
3100	Total Coliform - Non acute MCL	Absence	2700592	Harrison Rd WS #01	40	1	
3100	Total Coliform - Non acute MCL	Absence	2700598	Moss Landing School WS	575	1	
3100	Total Coliform - Non acute MCL	Absence	2700622	Outlook Wa	45	3	
3100	Total Coliform - Non acute MCL	Absence	2700663	Murphy Hill WS #02	60	1	
3100	Total Coliform - Non acute MCL	Absence	2700669	Orchard Ln WS #02	32	1	
3100	Total Coliform - Non acute MCL	Absence	2700682	Paradise Rd WS #09	250	1	
3100	Total Coliform - Non acute MCL	Absence	2700703	Calvary Church Inc WS	150	3	
3100	Total Coliform - Non acute MCL	Absence	2700713	Rolling Hills Rancho Wa	177	3	
3100	Total Coliform - Non acute MCL	Absence	2700731	Z Ranch MWC	62	3	
3100	Total Coliform - Non acute MCL	Absence	2700733	San Juan Rd WS #01	45	3	
3100	Total Coliform - Non acute MCL	Absence	2700740	San Miguel WS #03	48	1	
3100	Total Coliform - Non acute MCL	Absence	2700771	Springfield MWC	200	1	
3100	Total Coliform - Non acute MCL	Absence	2700775	Tierra Verde MWC	48	1	
3100	Total Coliform - Non acute MCL	Absence	2700792	Summerhill MHP WS	102	1	
3100	Total Coliform - Non acute MCL	Absence	2700799	Vista Del Toro WS	87	1	
3100	Total Coliform - Non acute MCL	Absence	2700838	Spring Canyon Wa	99	2	
3100	Total Coliform - Non acute MCL	Absence	2701570	Los Carneros MWA	105	1	
3100	Total Coliform - Non acute MCL	Absence	2701647	Green Acres Wa	50	1	
3100	Total Coliform - Non acute MCL	Absence	2701800	Tularcitos MWC	85	1	
3100	Total Coliform - Non acute MCL	Absence	2701814	Prunedale Plaza WS	90	2	
3100	Total Coliform - Non acute MCL	Absence	2701837	Meridian Rd WS #09	35	1	
3100	Total Coliform - Non acute MCL	Absence	2701870	Buena Vista WC	550	3	
3100	Total Coliform - Non acute MCL	Absence	2701918	Lomas Del Sol MWS	93	1	
3100	Total Coliform - Non acute MCL	Absence	2701926	Moro Rd WS #09	210	1	
3100	Total Coliform - Non acute MCL	Absence	2701959	Tierra Vista MWC	57	1	
3100	Total Coliform - Non acute MCL	Absence	2702007	Vierra Estates WS	164	1	
3100	Total Coliform - Non acute MCL	Absence	2702094	Blackie Rd WS #18	60	1	
3100	Total Coliform - Non acute MCL	Absence	2702121	Rosehart Industrial Park WS	75	2	
3100	Total Coliform - Non acute MCL	Absence	2702135	Foothill Wa	28	1	
3100	Total Coliform - Non acute MCL	Absence	2702140	Woodside Wa	78	2	
3100	Total Coliform - Non acute MCL	Absence	2702163	Hilltop Mwa	100	1	
3100	Total Coliform - Non acute MCL	Absence	2702165	Orchard Ln WS #09	25	1	
3100	Total Coliform - Non acute MCL	Absence	2702202	Growers Company Inc WS	200	3	
3100	Total Coliform - Non acute MCL	Absence	2702209	Big Sur Bazaar WS	100	2	
3100	Total Coliform - Non acute MCL	Absence	2702226	Elkhorn Slough Reserve Water System	375	1	

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	2702254	Pacific Valley School WS	55	1	
3100	Total Coliform - Non acute MCL	Absence	2702315	Corral De Tierra Country Club WS	60	1	
3100	Total Coliform - Non acute MCL	Absence	2702336	Monterey Bay Nursery WS	25	2	
3100	Total Coliform - Non acute MCL	Absence	2702368	Prunetree Shopping Center WS	200	1	
3100	Total Coliform - Non acute MCL	Absence	2702370	SPCA WS	50	1	
3100	Total Coliform - Non acute MCL	Absence	2702374	Countryside Estates MWC	73	1	
3100	Total Coliform - Non acute MCL	Absence	2702388	Royal Oak Place WS	60	1	
3100	Total Coliform - Non acute MCL	Absence	2702405	Jensen MHP WS	56	2	
3100	Total Coliform - Non acute MCL	Absence	2702431	Foothill Rd WS #01	25	5	
3100	Total Coliform - Non acute MCL	Absence	2702456	Mrwpc Treatment Plant WS	25	2	
3100	Total Coliform - Non acute MCL	Absence	2702482	Color Spot Nursery WS #02	25	2	
3100	Total Coliform - Non acute MCL	Absence	2702486	Bernardo Rd WS #02	25	2	
3100	Total Coliform - Non acute MCL	Absence	2702551	Loma Vista Inn WS	25	1	
3100	Total Coliform - Non acute MCL	Absence	2702572	Alba WS	70	2	
3100	Total Coliform - Non acute MCL	Absence	2710850	Correctional Training Facility - Soledad	7300	1	
3100	Total Coliform - Non acute MCL	Absence	2900529	Sunset Mobile Home Park Water System	60	2	
3100	Total Coliform - Non acute MCL	Absence	2900530	Rough & Ready MHP Water System	200	2	
3100	Total Coliform - Non acute MCL	Absence	2900531	Creekside Village Mobile Home Park	300	1	
3100	Total Coliform - Non acute MCL	Absence	2900567	Diamond Arrow Christian Conference Cpgd	250	1	
3100	Total Coliform - Non acute MCL	Absence	2900601	Bitney Springs Charter High School	125	1	
3100	Total Coliform - Non acute MCL	Absence	2900626	Streeter Plaza Industrial Park Water Sys	35	1	
3100	Total Coliform - Non acute MCL	Absence	2901994	Shady Creek Family Camp And Conf Center	250	1	
3100	Total Coliform - Non acute MCL	Absence	2902392	Penn Valley Shell Water System	100	1	
3100	Total Coliform - Non acute MCL	Absence	3100011	Auburn Valley Community Service Dis	120	1	
3100	Total Coliform - Non acute MCL	Absence	3103259	Penryn Oaks Preschool	50	1	
3100	Total Coliform - Non acute MCL	Absence	3103279	Applegate Inn	34	1	
3100	Total Coliform - Non acute MCL	Absence	3103664	Kaspian Point Picnic Area	25	1	
3100	Total Coliform - Non acute MCL	Absence	3107126	Weco Aerospace Systems Inc	45	1	
3100	Total Coliform - Non acute MCL	Absence	3110047	Talmont Resort Improvement District	300	2	
3100	Total Coliform - Non acute MCL	Absence	3301148	Coachella Valley Public Cemetary	25	2	
3100	Total Coliform - Non acute MCL	Absence	3301241	El Dorado Polo Club	50	1	
3100	Total Coliform - Non acute MCL	Absence	3301359	Kennedy Grocery	450	1	
3100	Total Coliform - Non acute MCL	Absence	3301529	Ramona Water Company	250	1	
3100	Total Coliform - Non acute MCL	Absence	3301990	Amezcu Garcia Water	250	1	
3100	Total Coliform - Non acute MCL	Absence	3303026	Granite Construction Company	25	1	
3100	Total Coliform - Non acute MCL	Absence	3310800	California Rehabilitation Center - Norco	4800	1	
3100	Total Coliform - Non acute MCL	Absence	3400250	Pleasant Grove Elementary School	60	1	
3100	Total Coliform - Non acute MCL	Absence	3400280	Dry Creek Ranch Golf Club	100	1	
3100	Total Coliform - Non acute MCL	Absence	3410003	Golden State Water Co - Arden	6796	1	
3100	Total Coliform - Non acute MCL	Absence	3410015	Golden State Water Co. - Cordova	44657	1	
3100	Total Coliform - Non acute MCL	Absence	3500503	Harmony Hills Water System	60	1	
3100	Total Coliform - Non acute MCL	Absence	3500550	San Justo Mutual Water Company	160	2	
3100	Total Coliform - Non acute MCL	Absence	3500575	Springwood Estates MWC	45	3	
3100	Total Coliform - Non acute MCL	Absence	3500810	Whispering Pines Retire Home (LSWS)	100	1	
3100	Total Coliform - Non acute MCL	Absence	3500836	Betabel RV Resort	200	1	
3100	Total Coliform - Non acute MCL	Absence	3500921	Pietra Santa Winery	30	1	
3100	Total Coliform - Non acute MCL	Absence	3500923	Fairview Road Water System	40	1	
3100	Total Coliform - Non acute MCL	Absence	3600172	Moly Corp Inc	172	1	
3100	Total Coliform - Non acute MCL	Absence	3600345	West End Mutual (Willow Wells)	63	1	
3100	Total Coliform - Non acute MCL	Absence	3600377	Echo Lodge	25	1	
3100	Total Coliform - Non acute MCL	Absence	3600452	Lucerne Valley Parks & Rec (CSA 29)	26	1	
3100	Total Coliform - Non acute MCL	Absence	3601113	SS Hert Trucking , Inc	25	1	
3100	Total Coliform - Non acute MCL	Absence	3601139	Heart Bar Equestrian Group Camp Ground	100	1	
3100	Total Coliform - Non acute MCL	Absence	3610024	Hesperia WD	62099	1	
3100	Total Coliform - Non acute MCL	Absence	3610030	Mariana Ranchos CWD	1048	1	
3100	Total Coliform - Non acute MCL	Absence	3700011	Stelzer County Park	25	1	
3100	Total Coliform - Non acute MCL	Absence	3700029	Descanso Fire Station	34	1	
3100	Total Coliform - Non acute MCL	Absence	3700073	H & J Water Company	50	1	
3100	Total Coliform - Non acute MCL	Absence	3700848	Alpine Springs Rv Park	200	1	

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	3700918	Rancho Santa Teresa MWC	74	1	
3100	Total Coliform - Non acute MCL	Absence	3700922	Live Oak Springs Water & Power	200	1	
3100	Total Coliform - Non acute MCL	Absence	3700923	Lake Morena Oak Shore MWC	600	1	
3100	Total Coliform - Non acute MCL	Absence	3700934	Pauma Valley Mutual Water Company	120	2	
3100	Total Coliform - Non acute MCL	Absence	3700962	Oakvale Park	100	1	
3100	Total Coliform - Non acute MCL	Absence	3701184	Butterfield Ranch	25	1	
3100	Total Coliform - Non acute MCL	Absence	3701213	Borrego Springs Park Community Services	35	1	
3100	Total Coliform - Non acute MCL	Absence	3701934	Pine Valley Bible Conference Center	38	1	
3100	Total Coliform - Non acute MCL	Absence	3702237	Banner Small Water Company	175	1	
3100	Total Coliform - Non acute MCL	Absence	3702754	Rancho Corrido Campground	300	1	
3100	Total Coliform - Non acute MCL	Absence	3705005	Boulevard Springs	25	1	
3100	Total Coliform - Non acute MCL	Absence	3710036	Borrego WD	3500	1	
3100	Total Coliform - Non acute MCL	Absence	3710311	Cuyamaca Sp - Paso Picacho	8	1	
3100	Total Coliform - Non acute MCL	Absence	3710706	USN Sere Camp Warner Springs	12	1	
3100	Total Coliform - Non acute MCL	Absence	3900505	Farmington Water Company	100	3	
3100	Total Coliform - Non acute MCL	Absence	3900512	Morada Acres Water System	105	1	
3100	Total Coliform - Non acute MCL	Absence	3900523	Morada Manor Water System	109	1	
3100	Total Coliform - Non acute MCL	Absence	3900555	Banta Mutual Water Co #1	81	1	
3100	Total Coliform - Non acute MCL	Absence	3900557	Banta Mutual Water Co #3	75	3	
3100	Total Coliform - Non acute MCL	Absence	3900581	Sj County Housing Authority	500	2	
3100	Total Coliform - Non acute MCL	Absence	3900606	A-1 Winston'S Mobile Home Park	75	1	
3100	Total Coliform - Non acute MCL	Absence	3900666	King Island Marina PWS	1000	3	
3100	Total Coliform - Non acute MCL	Absence	3900682	Lockeford Mobile Home Park	100	2	
3100	Total Coliform - Non acute MCL	Absence	3900701	Currier Estates Water Corp	148	1	
3100	Total Coliform - Non acute MCL	Absence	3900705	Finnlee's Trailer Park	55	1	
3100	Total Coliform - Non acute MCL	Absence	3900713	Delta Island Elementary School	145	1	
3100	Total Coliform - Non acute MCL	Absence	3900755	Shady Rest Trailer Court	120	2	
3100	Total Coliform - Non acute MCL	Absence	3900797	Escalon Premier Brands	300	2	
3100	Total Coliform - Non acute MCL	Absence	3900798	Franzia Winery	250	3	
3100	Total Coliform - Non acute MCL	Absence	3900807	Whiskey Slough Harbor	200	1	
3100	Total Coliform - Non acute MCL	Absence	3900810	Jr Simplot Co	300	1	
3100	Total Coliform - Non acute MCL	Absence	3900831	Arbor Mobile Home Park	340	1	
3100	Total Coliform - Non acute MCL	Absence	3900839	Mokelumne River School	204	1	
3100	Total Coliform - Non acute MCL	Absence	3900888	South San Joaquin Irr Dist	55	1	
3100	Total Coliform - Non acute MCL	Absence	3901032	Lodi USD-Turner School	200	1	
3100	Total Coliform - Non acute MCL	Absence	3901085	Lodi USD-Davis School	630	1	
3100	Total Coliform - Non acute MCL	Absence	3901116	Navarra Water System	725	1	
3100	Total Coliform - Non acute MCL	Absence	3901121	Morada Shopping Center	100	1	
3100	Total Coliform - Non acute MCL	Absence	3901131	Bay Valley Estates PWS	50	1	
3100	Total Coliform - Non acute MCL	Absence	3901179	Lodi Wine & Business Center	61	1	
3100	Total Coliform - Non acute MCL	Absence	3901196	Mainland Nursery Inc	50	1	
3100	Total Coliform - Non acute MCL	Absence	3901197	Oak Ridge Winery, Llc	50	1	
3100	Total Coliform - Non acute MCL	Absence	3901198	Yosemite Inn - PWS	50	1	
3100	Total Coliform - Non acute MCL	Absence	3901209	St Marys High School	950	1	
3100	Total Coliform - Non acute MCL	Absence	3901249	3 B'S Truck & Auto Plaza	1000	2	
3100	Total Coliform - Non acute MCL	Absence	3901282	Woodbridge Winery	100	2	
3100	Total Coliform - Non acute MCL	Absence	3901296	Italian Athletic Club	50	1	
3100	Total Coliform - Non acute MCL	Absence	3901315	Gaf Materials Co	30	4	
3100	Total Coliform - Non acute MCL	Absence	3901321	J B Golf	75	1	
3100	Total Coliform - Non acute MCL	Absence	3901324	Subway Sandwiches Water Sys	500	1	
3100	Total Coliform - Non acute MCL	Absence	3901330	Cecchini & Giovannoni Water System	50	2	
3100	Total Coliform - Non acute MCL	Absence	3901342	Zuckerman, Roscoe 39-316	30	1	
3100	Total Coliform - Non acute MCL	Absence	3901350	Boething Treeland Farms Inc	30	1	
3100	Total Coliform - Non acute MCL	Absence	3901360	Holiday Harbor Marina	100	2	
3100	Total Coliform - Non acute MCL	Absence	3901361	Backspin Golf Center	1000	2	
3100	Total Coliform - Non acute MCL	Absence	3901369	Basalite Concrete Products Llc	25	1	
3100	Total Coliform - Non acute MCL	Absence	3901371	Lockeford Springs Golf Course	25	2	
3100	Total Coliform - Non acute MCL	Absence	3901388	P G & E-Turner Cut	25	2	
3100	Total Coliform - Non acute MCL	Absence	3901407	Burlington Northern Santa Fe	25	2	

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	3901411	Oakmoore Congre Of Jehovah Wit	100	1	
3100	Total Coliform - Non acute MCL	Absence	3901412	Korean Presbyterian Church	25	1	
3100	Total Coliform - Non acute MCL	Absence	3901414	Wastequip Mclaughlin	25	1	
3100	Total Coliform - Non acute MCL	Absence	3901423	Greif Bros Inc	25	1	
3100	Total Coliform - Non acute MCL	Absence	3901437	Lodi Elks Building Association	25	4	
3100	Total Coliform - Non acute MCL	Absence	3901442	Tarditi Rentals Water	25	2	
3100	Total Coliform - Non acute MCL	Absence	3901444	Gianneccchini Farms Water System	25	1	
3100	Total Coliform - Non acute MCL	Absence	4000221	Laetitia Vineyard & Winery Inc	25	2	
3100	Total Coliform - Non acute MCL	Absence	4000554	Green River Mutual Water Co.	350	3	
3100	Total Coliform - Non acute MCL	Absence	4000656	Santa Margarita Koa	50	2	
3100	Total Coliform - Non acute MCL	Absence	4010026	Nipomo Comm Services Dist	12626	1	
3100	Total Coliform - Non acute MCL	Absence	4200514	Cuyama Mutual Water Co.	65	1	
3100	Total Coliform - Non acute MCL	Absence	4200556	Foster Road Mutual Water Co.	150	1	
3100	Total Coliform - Non acute MCL	Absence	4200612	Meadowlark Ranches Os	150	2	
3100	Total Coliform - Non acute MCL	Absence	4200618	Midland School Corporation Os	150	3	
3100	Total Coliform - Non acute MCL	Absence	4200644	San Marcos Baptist Camp	75	1	
3100	Total Coliform - Non acute MCL	Absence	4200647	Community Christian School	80	1	
3100	Total Coliform - Non acute MCL	Absence	4200666	Kinecta Federal Credit Union	40	2	
3100	Total Coliform - Non acute MCL	Absence	4200842	Saint Marie Mobile Home Park	250	2	
3100	Total Coliform - Non acute MCL	Absence	4200903	Sanford Winery	135	1	
3100	Total Coliform - Non acute MCL	Absence	4200925	Santa Barbara Pistachio Co	25	1	
3100	Total Coliform - Non acute MCL	Absence	4200939	Cotton Wood Winery	25	2	
3100	Total Coliform - Non acute MCL	Absence	4300603	Oak Dell Park	100	1	
3100	Total Coliform - Non acute MCL	Absence	4410016	Forest Lakes MWC	1141	1	
3100	Total Coliform - Non acute MCL	Absence	4410306	Csp - Rancho Del Oso	200	2	
3100	Total Coliform - Non acute MCL	Absence	4500012	Cascade Racquet Club Mutual Water	100	1	
3100	Total Coliform - Non acute MCL	Absence	4500017	Moose Camp	50	1	
3100	Total Coliform - Non acute MCL	Absence	4500053	Antlers Resort & Marina	109	1	
3100	Total Coliform - Non acute MCL	Absence	4500061	PG&E - Cassel Campground	80	2	
3100	Total Coliform - Non acute MCL	Absence	4500066	Clear Creek Mobile Park	110	1	
3100	Total Coliform - Non acute MCL	Absence	4500080	Doney Creek Lakeshore Villa RV Park	55	1	
3100	Total Coliform - Non acute MCL	Absence	4500224	Basshole	30	1	
3100	Total Coliform - Non acute MCL	Absence	4500277	USFS Yolla Bolla Corp Yard	120	1	
3100	Total Coliform - Non acute MCL	Absence	4500325	Lassen Pines Christian Conference Center	300	1	
3100	Total Coliform - Non acute MCL	Absence	4500327	Jgw RV Park	215	1	
3100	Total Coliform - Non acute MCL	Absence	4510003	Burney Water District	3000	1	
3100	Total Coliform - Non acute MCL	Absence	4600055	Central Town WS	25	1	
3100	Total Coliform - Non acute MCL	Absence	4600068	TNF-Logger & Stampede Rc	1200	2	
3100	Total Coliform - Non acute MCL	Absence	4700528	Siskiyou Co. Rolling Hills MWC	384	1	
3100	Total Coliform - Non acute MCL	Absence	4700541	Chateau Shasta Mobile Home & RV Park	55	1	
3100	Total Coliform - Non acute MCL	Absence	4700546	Cal Ore Trail Mobile Estates	74	1	
3100	Total Coliform - Non acute MCL	Absence	4700571	Mcbride Springs Campground	80	1	
3100	Total Coliform - Non acute MCL	Absence	4700575	Butte Valley Middle School	55	1	
3100	Total Coliform - Non acute MCL	Absence	4700577	Big Springs Union Elem. School	300	1	
3100	Total Coliform - Non acute MCL	Absence	4700621	Mid River RV Park	40	1	
3100	Total Coliform - Non acute MCL	Absence	4700626	Cove Mobile Villa	210	1	
3100	Total Coliform - Non acute MCL	Absence	4700686	Sun Mountain M.W.C.	55	1	
3100	Total Coliform - Non acute MCL	Absence	4700886	Blue Heron RV Park	25	1	
3100	Total Coliform - Non acute MCL	Absence	4710013	Lake Shastina C.S.D	2400	1	
3100	Total Coliform - Non acute MCL	Absence	4900686	KOA - Cloverdale	25	1	
3100	Total Coliform - Non acute MCL	Absence	4900720	Mobile Home Estates	320	1	
3100	Total Coliform - Non acute MCL	Absence	4900937	Joe's Place	25	1	
3100	Total Coliform - Non acute MCL	Absence	4901025	Johnson's Beach Resort	100	1	
3100	Total Coliform - Non acute MCL	Absence	4901093	Martinelli Ranch	30	2	
3100	Total Coliform - Non acute MCL	Absence	4901251	Safari West	60	1	
3100	Total Coliform - Non acute MCL	Absence	4901284	Mauritson Family Winery	26	1	
3100	Total Coliform - Non acute MCL	Absence	5000132	Valley Home School Texas	26	1	
3100	Total Coliform - Non acute MCL	Absence	5000167	Stan Cnty Honor Farm Water System/Laird	300	1	
3100	Total Coliform - Non acute MCL	Absence	5000271	Buehner Water System - Weber Complex	100	1	

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	5000277	Valley Home School Pioneer	26	1	
3100	Total Coliform - Non acute MCL	Absence	5000433	Oid-Oakdale Rural Water System #1	1162	1	
3100	Total Coliform - Non acute MCL	Absence	5000465	Duarte Nursery Inc Water System	75	1	
3100	Total Coliform - Non acute MCL	Absence	5010007	Hillsview Homes	840	1	
3100	Total Coliform - Non acute MCL	Absence	5010014	Oakdale, City Of	17600	1	
3100	Total Coliform - Non acute MCL	Absence	5100109	Wildwood Mutual Water Company	255	2	
3100	Total Coliform - Non acute MCL	Absence	5100159	Verona Marina Launch & R.V.	50	1	
3100	Total Coliform - Non acute MCL	Absence	5103007	Happy Time	40	2	
3100	Total Coliform - Non acute MCL	Absence	5103303	Tierra Buena Tavern	60	1	
3100	Total Coliform - Non acute MCL	Absence	5103335	Live Oak Child Care Center	50	1	
3100	Total Coliform - Non acute MCL	Absence	5105002	Rio La Paz Golf Course	1	1	
3100	Total Coliform - Non acute MCL	Absence	5110002	City Of Yuba City	50782	1	
3100	Total Coliform - Non acute MCL	Absence	5200014	Wilson Acres Mutual Water	80	1	
3100	Total Coliform - Non acute MCL	Absence	5200529	Siemens Water Technologies Corp	330	1	
3100	Total Coliform - Non acute MCL	Absence	5200550	Orchard Mobile Home Park	56	1	
3100	Total Coliform - Non acute MCL	Absence	5200560	Mira Monte Water Co.	100	1	
3100	Total Coliform - Non acute MCL	Absence	5200570	Surrey Village Water Co., Inc.	130	2	
3100	Total Coliform - Non acute MCL	Absence	5200575	Rancho Colorado WS	36	1	
3100	Total Coliform - Non acute MCL	Absence	5200581	Forest Inn, The	25	1	
3100	Total Coliform - Non acute MCL	Absence	5200611	USDA-Lake Red Bluff Rec Area	25	1	
3100	Total Coliform - Non acute MCL	Absence	5301012	Trinity River Lodge	74	1	
3100	Total Coliform - Non acute MCL	Absence	5301104	Trinity Lake Forest	50	2	
3100	Total Coliform - Non acute MCL	Absence	5304006	Big Bar Ranger Station	200	5	
3100	Total Coliform - Non acute MCL	Absence	5400541	Paramount Citrus	100	2	
3100	Total Coliform - Non acute MCL	Absence	5400548	Kings Inn Motel	130	1	
3100	Total Coliform - Non acute MCL	Absence	5400550	Seville Water Co.	400	1	
3100	Total Coliform - Non acute MCL	Absence	5400558	Saucelito Elem School	75	1	
3100	Total Coliform - Non acute MCL	Absence	5400631	Linnell Farm Labor Center	896	1	
3100	Total Coliform - Non acute MCL	Absence	5400638	Sierra School	40	2	
3100	Total Coliform - Non acute MCL	Absence	5400651	Beverly-Grand Mutual Water	108	1	
3100	Total Coliform - Non acute MCL	Absence	5400665	River Island Service Terr #1	700	1	
3100	Total Coliform - Non acute MCL	Absence	5400699	Kaweah High School	110	3	
3100	Total Coliform - Non acute MCL	Absence	5400704	Three Rivers School	300	1	
3100	Total Coliform - Non acute MCL	Absence	5400709	Sequoia Union School	400	3	
3100	Total Coliform - Non acute MCL	Absence	5400735	Rodriguez Labor Camp	110	2	
3100	Total Coliform - Non acute MCL	Absence	5400762	Giumarra Vineyards 3 & 4	125	1	
3100	Total Coliform - Non acute MCL	Absence	5400797	Tulare Co Correctional Center	300	3	
3100	Total Coliform - Non acute MCL	Absence	5400850	Packwood School	30	1	
3100	Total Coliform - Non acute MCL	Absence	5400951	Mooney Grove Park	200	2	
3100	Total Coliform - Non acute MCL	Absence	5401003	East Orosi C.S.D.	106	1	
3100	Total Coliform - Non acute MCL	Absence	5401026	Deer Meadow Mutual	75	1	
3100	Total Coliform - Non acute MCL	Absence	5401033	A & P Growers	100	2	
3100	Total Coliform - Non acute MCL	Absence	5401040	Moore Wallace Incorporated	208	1	
3100	Total Coliform - Non acute MCL	Absence	5401093	Doyle Springs Assn.	300	1	
3100	Total Coliform - Non acute MCL	Absence	5402022	Traver Valley Farms - Texaco	25	2	
3100	Total Coliform - Non acute MCL	Absence	5402039	Seville Market	100	1	
3100	Total Coliform - Non acute MCL	Absence	5402048	River Island Service Terr #2	87	2	
3100	Total Coliform - Non acute MCL	Absence	5403011	Rj'S Super Stop & Liquor	25	1	
3100	Total Coliform - Non acute MCL	Absence	5403031	Sun Pacific-Tulare	250	1	
3100	Total Coliform - Non acute MCL	Absence	5403032	Monrovia Nursery - Nursery	400	1	
3100	Total Coliform - Non acute MCL	Absence	5403051	Friends Rv Park	24	1	
3100	Total Coliform - Non acute MCL	Absence	5403086	Martella Livestock Auction	50	1	
3100	Total Coliform - Non acute MCL	Absence	5403113	South Fork Estates Mutual Water Co	76	2	
3100	Total Coliform - Non acute MCL	Absence	5403114	Foster Farms - Traver Feedmill	40	1	
3100	Total Coliform - Non acute MCL	Absence	5410002	Dinuba, City Of	18369	2	
3100	Total Coliform - Non acute MCL	Absence	5410019	Ivanhoe Public Utility Dist	4474	2	
3100	Total Coliform - Non acute MCL	Absence	5410021	Earlimart PUD	7100	4	
3100	Total Coliform - Non acute MCL	Absence	5500152	Curtis Creek Elementary School	595	1	
3100	Total Coliform - Non acute MCL	Absence	5500258	Christian Heights	50	1	

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	5500259	Hatler Industrial Park	26	1	
3100	Total Coliform - Non acute MCL	Absence	5510016	Odd Fellows Sierra Rec Assoc	200	1	
3100	Total Coliform - Non acute MCL	Absence	5601716	USFS - Wheeler Gorge Campground	500	1	
3100	Total Coliform - Non acute MCL	Absence	5610005	Meiners Oaks Cwd	4000	1	
3100	Total Coliform - Non acute MCL	Absence	5610014	Golden State Water Company - Ojai	8200	1	
3100	Total Coliform - Non acute MCL	Absence	5700509	Clarksburg Elem School	400	2	
3100	Total Coliform - Non acute MCL	Absence	5700532	Yolo Bypass Wildlife Area	25	2	
3100	Total Coliform - Non acute MCL	Absence	5700537	Campbell Soup Supply Co Llc - Water	40	2	
3100	Total Coliform - Non acute MCL	Absence	5700543	Yolo Fruit Stand	30	2	
3100	Total Coliform - Non acute MCL	Absence	5700551	Bill & Kathy'S	550	1	
3100	Total Coliform - Non acute MCL	Absence	5700552	Pilot Travel Center #168 - Water	700	1	
3100	Total Coliform - Non acute MCL	Absence	5700554	Campers Inn - Rv & Golf Course	120	1	
3100	Total Coliform - Non acute MCL	Absence	5700560	Dunnigan 76 Gas & Mini - Water	50	2	
3100	Total Coliform - Non acute MCL	Absence	5700565	Rose Valley Group Inc	25	2	
3100	Total Coliform - Non acute MCL	Absence	5700568	River Garden Farms #1	26	1	
3100	Total Coliform - Non acute MCL	Absence	5700584	Reynolds Resorts - Sacramento Llc	300	1	
3100	Total Coliform - Non acute MCL	Absence	5700588	Sacramento Yacht Club	25	1	
3100	Total Coliform - Non acute MCL	Absence	5700600	Fast & Easy Mart #54 - Water	100	1	
3100	Total Coliform - Non acute MCL	Absence	5700608	Canyon Creek Resort	200	1	
3100	Total Coliform - Non acute MCL	Absence	5700636	Pacific Coast Producers	1100	1	
3100	Total Coliform - Non acute MCL	Absence	5700707	Rolling Acres Wat Mutual	33	2	
3100	Total Coliform - Non acute MCL	Absence	5700713	Cache Creek Canyon-Middle Site	100	3	
3100	Total Coliform - Non acute MCL	Absence	5700729	Reyes, Javier Ceja	75	1	
3100	Total Coliform - Non acute MCL	Absence	5700741	United Petroleum Truck Stop	200	2	
3100	Total Coliform - Non acute MCL	Absence	5700752	Chevron #92597 - Woodland	71	4	
3100	Total Coliform - Non acute MCL	Absence	5700767	Woodland Aviation - Wold Airport	32	1	
3100	Total Coliform - Non acute MCL	Absence	5700828	R H Phillips Winery - Water	30	2	
3100	Total Coliform - Non acute MCL	Absence	5710001	City Of Davis	67740	1	
3100	Total Coliform - Non acute MCL	Absence	5710007	Esparto C.S.D.	1858	4	
3100	Total Coliform - Non acute MCL	Absence	5710008	Valhalla Mobile Home Park	400	3	
3100	Total Coliform - Non acute MCL	Absence	5800001	Browns Valley One Stop	50	1	
3100	Total Coliform - Non acute MCL	Absence	5800002	North Yuba Little League	30	2	
3100	Total Coliform - Non acute MCL	Absence	5800004	Mariani Packing Company Inc.	65	1	
3100	Total Coliform - Non acute MCL	Absence	5800201	Prune Tree	25	1	
3100	Total Coliform - Non acute MCL	Absence	5800805	Lake Francis Mutual Water	60	1	
3100	Total Coliform - Non acute MCL	Absence	5800820	River Highlands Com.Serv.Dist	100	1	
3100	Total Coliform - Non acute MCL	Absence	5800823	Country Air Mobile Home Park	70	1	
3100	Total Coliform - Non acute MCL	Absence	5800824	Country Village Mobile Hm Prk	30	1	
3100	Total Coliform - Non acute MCL	Absence	5800826	Quail Ridge	60	3	
3100	Total Coliform - Non acute MCL	Absence	5800844	Browns Valley School	135	2	
3100	Total Coliform - Non acute MCL	Absence	5800845	Dobbins School	149	1	
3100	Total Coliform - Non acute MCL	Absence	5800851	Feather River Manor	35	1	
3100	Total Coliform - Non acute MCL	Absence	5800853	Sycamore Ranch RV Park	40	1	
3100	Total Coliform - Non acute MCL	Absence	5800856	Christopher Sims Rentals	30	1	
Counts / Totals			442	490496	606		
3100	Total Coliform-routine monitoring		300007	Stockton Municipal Family Camp	999		1
3100	Total Coliform-routine monitoring		300028	Amador Harvest Inn	40		1
3100	Total Coliform-routine monitoring		300036	Bear River Lake Resort	250		1
3100	Total Coliform-routine monitoring		300043	O. K. Corral	200		2
3100	Total Coliform-routine monitoring		300055	Sunset West Water Company	150		4
3100	Total Coliform-routine monitoring		300062	Hope Foundation/Moriah Heights	300		2
3100	Total Coliform-routine monitoring		300077	Spinetta Vineyards - Inactive	25		1
3100	Total Coliform-routine monitoring		300518	Oro Madre Moose Lodge 1761	300		1
3100	Total Coliform-routine monitoring		300627	Amador Station	20		1
3100	Total Coliform-routine monitoring		300649	Rancho Cicada	50		1
3100	Total Coliform-routine monitoring		310013	Sunset Heights C.S.D.	103		1
3100	Total Coliform-routine monitoring		500009	United Parcel Service	75		1
3100	Total Coliform-routine monitoring		500021	Sky High Ranch HOA	94		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		500026	Camp Lodestar	150		1
3100	Total Coliform-routine monitoring		500037	Tamarack Lodge	50		1
3100	Total Coliform-routine monitoring		500097	Cusd District Office	100		1
3100	Total Coliform-routine monitoring		706015	Docs Marina	35		1
3100	Total Coliform-routine monitoring		706018	Cruiser Haven Marina	75		2
3100	Total Coliform-routine monitoring		706101	Roddy Ranch Golf Course	75		1
3100	Total Coliform-routine monitoring		707542	Concord Mt Diablo Trailride Assoc.	14		2
3100	Total Coliform-routine monitoring		707585	Moraga Heights Mutual Water	60		1
3100	Total Coliform-routine monitoring		707623	Mc Cosker Ranch	90		1
3100	Total Coliform-routine monitoring		707630	Willowest Marina WS	30		1
3100	Total Coliform-routine monitoring		708006	Cecchini Water	35		2
3100	Total Coliform-routine monitoring		800548	Klamath C.S.D.	100		1
3100	Total Coliform-routine monitoring		900104	Pioneer Bible Church Water System	250		2
3100	Total Coliform-routine monitoring		900106	Indian Diggings School	45		2
3100	Total Coliform-routine monitoring		900107	Gray's Mart & Gas (Health)	100		1
3100	Total Coliform-routine monitoring		900118	Pearl's Little Place - Restaur	50		1
3100	Total Coliform-routine monitoring		900206	Camp Chiquita Campground (Health)	50		1
3100	Total Coliform-routine monitoring		900304	Silverfork School (Health)	25		4
3100	Total Coliform-routine monitoring		900311	Mountain Camp li	140		1
3100	Total Coliform-routine monitoring		900423	Whitewater Voyages	100		2
3100	Total Coliform-routine monitoring		900502	Pyramid Creek Trailhead	500		2
3100	Total Coliform-routine monitoring		900508	Sierra Nevada Building	150		1
3100	Total Coliform-routine monitoring		900517	Lone Pine Lodge	40		1
3100	Total Coliform-routine monitoring		900519	Crystal Range Motel	30		1
3100	Total Coliform-routine monitoring		900536	Tahoe Chalet Inn .	100		1
3100	Total Coliform-routine monitoring		900542	Bayview Campground	100		1
3100	Total Coliform-routine monitoring		900555	Matterhorn Motel	50		1
3100	Total Coliform-routine monitoring		900557	Emerald Pines Resort Cabins	25		1
3100	Total Coliform-routine monitoring		900576	Alpine Inn & Spa	25		1
3100	Total Coliform-routine monitoring		900578	Pistante'S Coyote Den	32		1
3100	Total Coliform-routine monitoring		900582	Alpenrose Inn	40		1
3100	Total Coliform-routine monitoring		900585	Sky Lake Lodge	25		1
3100	Total Coliform-routine monitoring		900646	Al Tahoe Elem/Stms (Water Sys)	1300		1
3100	Total Coliform-routine monitoring		900648	Tahoe Valley Elementary School	700		1
3100	Total Coliform-routine monitoring		900649	South Shore Recreation Area	3300		1
3100	Total Coliform-routine monitoring		900650	Echo Lake Camp	150		1
3100	Total Coliform-routine monitoring		900651	Sierra Pines Camp	25		1
3100	Total Coliform-routine monitoring		900654	Baldwin Beach	200		2
3100	Total Coliform-routine monitoring		900665	Heavenly Valley Gondola	500		1
3100	Total Coliform-routine monitoring		901219	Capps Crossing Campground	25		1
3100	Total Coliform-routine monitoring		901222	China Flat Campground	75		1
3100	Total Coliform-routine monitoring		901239	Sand Flat Campground	75		2
3100	Total Coliform-routine monitoring		901243	Silverfork Campground	75		1
3100	Total Coliform-routine monitoring		901244	Stumpy MeadoWS Campground	100		2
3100	Total Coliform-routine monitoring		1000247	Sherwood Forest MHP	100		3
3100	Total Coliform-routine monitoring		1000482	Wolf Lakes Park	500		2
3100	Total Coliform-routine monitoring		1000524	Auberry Seventh Day Adventist Chrch	25		3
3100	Total Coliform-routine monitoring		1200517	Kimtu MeadoWS MWC	30		1
3100	Total Coliform-routine monitoring		1200588	Seawood Estates Mutual Water	30		2
3100	Total Coliform-routine monitoring		1200675	Stafford R V Park	100		1
3100	Total Coliform-routine monitoring		1200704	Azalea Glen	42		1
3100	Total Coliform-routine monitoring		1200718	Waddington W.W.	75		1
3100	Total Coliform-routine monitoring		1200728	Sounds Of The Seas W. S.	30		1
3100	Total Coliform-routine monitoring		1200772	Ocean Grove Lodge	50		1
3100	Total Coliform-routine monitoring		1200778	Bridgeville Elem. School	300		1
3100	Total Coliform-routine monitoring		1200792	Patrick'S Point Inn	25		1
3100	Total Coliform-routine monitoring		1210800	Eel River Conservation Camp	2000		1
3100	Total Coliform-routine monitoring		1400004	Charles Brown Water Company	330		1
3100	Total Coliform-routine monitoring		1400063	Tecopa Francis Elementary School	50		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		1400069	Death Valley Junction	200		1
3100	Total Coliform-routine monitoring		1400088	Delight'S Hot Springs Resort	55		1
3100	Total Coliform-routine monitoring		1400096	Tecopa Hot Springs Park	100		1
3100	Total Coliform-routine monitoring		1400133	Tecopa Palms Rv Park	50		2
3100	Total Coliform-routine monitoring		1400526	Eastern Sierra College Center - Bishop	100		1
3100	Total Coliform-routine monitoring		1500313	Mitchell'S Water System	30		1
3100	Total Coliform-routine monitoring		1500364	KrvWC - Kernvale Mutual Water Co	52		3
3100	Total Coliform-routine monitoring		1500398	Frontier Trail Homeowners Assoc, Inc.	40		1
3100	Total Coliform-routine monitoring		1500448	Hillview Acres Mutual Water Company	35		1
3100	Total Coliform-routine monitoring		1500455	William Fisher Memorial Water Company	80		2
3100	Total Coliform-routine monitoring		1500461	Fountain Trailer Park Water	45		2
3100	Total Coliform-routine monitoring		1500462	James Water System	40		2
3100	Total Coliform-routine monitoring		1500517	Stoco Mutual Water Company	2500		1
3100	Total Coliform-routine monitoring		1500553	Ranchos Del Rio	63		1
3100	Total Coliform-routine monitoring		1500571	Rosamond Mutual Water Company	60		1
3100	Total Coliform-routine monitoring		1500578	Long Canyon Water Company Corp.	197		1
3100	Total Coliform-routine monitoring		1502004	AndreWS Ag., Inc	50		1
3100	Total Coliform-routine monitoring		1502008	Jones Auction	120		1
3100	Total Coliform-routine monitoring		1502012	Heck Cellars Water System	60		1
3100	Total Coliform-routine monitoring		1502034	California Portland Cement	200		1
3100	Total Coliform-routine monitoring		1502044	Camp Tecuya Water System	180		1
3100	Total Coliform-routine monitoring		1502084	Frazier Woods Conference Center	250		1
3100	Total Coliform-routine monitoring		1502093	Harvest Steakhouse	70		1
3100	Total Coliform-routine monitoring		1502142	Kern Valley Golf Course	500		1
3100	Total Coliform-routine monitoring		1502163	Linns Valley School	100		2
3100	Total Coliform-routine monitoring		1502194	Sierra Vista Restaurant	250		2
3100	Total Coliform-routine monitoring		1502260	South Fork School Water System	154		1
3100	Total Coliform-routine monitoring		1502383	Nord Road Water Association	47		1
3100	Total Coliform-routine monitoring		1502622	Gosford Road Water Company	42		1
3100	Total Coliform-routine monitoring		1502666	Wilcox Water System	27		2
3100	Total Coliform-routine monitoring		1502699	East Wilson Road Water Company	35		1
3100	Total Coliform-routine monitoring		1502750	Riverview Homeowners Association	60		1
3100	Total Coliform-routine monitoring		1502756	Kern Valley Courts Complex	290		1
3100	Total Coliform-routine monitoring		1503093	Grimmway Enterprises-Malaga Water System	1500		1
3100	Total Coliform-routine monitoring		1503214	No. 1 Golf Driving Range	100		1
3100	Total Coliform-routine monitoring		1503231	Four Winds Water System	30		2
3100	Total Coliform-routine monitoring		1503256	Kids Kountry Preschool	70		2
3100	Total Coliform-routine monitoring		1503292	Weatherford U.S., L.P.	50		1
3100	Total Coliform-routine monitoring		1503368	South Fork Middle School	204		1
3100	Total Coliform-routine monitoring		1503378	Wind Wolves Preserve	30		2
3100	Total Coliform-routine monitoring		1503392	Four Twenty 420 Club	150		1
3100	Total Coliform-routine monitoring		1503537	Cemex Construction Materials Lp	45		1
3100	Total Coliform-routine monitoring		1510301	CSP - Fort Tejon	150		1
3100	Total Coliform-routine monitoring		1610007	Home Garden CSD	1850		1
3100	Total Coliform-routine monitoring		1700511	Harbin Hot Springs	170		1
3100	Total Coliform-routine monitoring		1700589	Blue Lakes Mobile Home Park	50		1
3100	Total Coliform-routine monitoring		1700686	Harbor Restaurant And Lounge	25		1
3100	Total Coliform-routine monitoring		1700712	Lakeport Theatre	500		1
3100	Total Coliform-routine monitoring		1800531	Caltrans-Honey Lake Rest Stop	350		1
3100	Total Coliform-routine monitoring		1900514	Llano Farms Water Company- Community	40		1
3100	Total Coliform-routine monitoring		1900677	Oasis Park Mobile Home Park	100		1
3100	Total Coliform-routine monitoring		1900946	Palmdale Trailer Park	104		1
3100	Total Coliform-routine monitoring		2300503	Sutherland Waterworks	27		2
3100	Total Coliform-routine monitoring		2300506	Meadow Estates Mutual	85		1
3100	Total Coliform-routine monitoring		2300609	Seafair Road And Water Company	50		1
3100	Total Coliform-routine monitoring		2300663	Harwood Water System	100		1
3100	Total Coliform-routine monitoring		2300736	Caspar Beach RV Park	25		1
3100	Total Coliform-routine monitoring		2310010	Hopland Public Utility District	1020		1
3100	Total Coliform-routine monitoring		2600557	Tioga Pass Market/Rest.	100		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		2600568	Edna Beaman Elementary School	90		1
3100	Total Coliform-routine monitoring		2600572	Mcgee Creek Mobile Home Park	20		1
3100	Total Coliform-routine monitoring		2600614	June Mtn. Ski Area, Stew Pot Slim'S	50		1
3100	Total Coliform-routine monitoring		2600615	June Mtn. Ski Area, Stew Pot Slim'S	500		2
3100	Total Coliform-routine monitoring		2600621	White Mountain Estates	50		2
3100	Total Coliform-routine monitoring		2700509	Oak Manor WS	71		1
3100	Total Coliform-routine monitoring		2700511	Normco WC	868		1
3100	Total Coliform-routine monitoring		2700518	Watsonville Produce WS	100		1
3100	Total Coliform-routine monitoring		2700534	Colonial Oaks WC	198		1
3100	Total Coliform-routine monitoring		2700594	Hidden Valley Wa	51		1
3100	Total Coliform-routine monitoring		2700606	Hidden VieWS MHP WS	75		1
3100	Total Coliform-routine monitoring		2700636	Royal Oaks Park WS	25		1
3100	Total Coliform-routine monitoring		2700702	Prunedale MWC	252		3
3100	Total Coliform-routine monitoring		2700771	Springfield MWC	200		2
3100	Total Coliform-routine monitoring		2700792	Summerhill MHP WS	102		1
3100	Total Coliform-routine monitoring		2700856	Altman Plants WS #01	45		2
3100	Total Coliform-routine monitoring		2700875	Pajaro Valley Greenhouse WS	110		1
3100	Total Coliform-routine monitoring		2700998	Bud Antle Marina WS	150		1
3100	Total Coliform-routine monitoring		2701040	Mccoy Rd WS #05	72		2
3100	Total Coliform-routine monitoring		2701153	Growers Transplanting WS	50		1
3100	Total Coliform-routine monitoring		2701254	Carmel Riviera MWC	555		1
3100	Total Coliform-routine monitoring		2701498	Harbor View Wa	75		1
3100	Total Coliform-routine monitoring		2701553	Pond-Derosa Oaks WC	216		1
3100	Total Coliform-routine monitoring		2701589	Sunny Acres MWS	45		1
3100	Total Coliform-routine monitoring		2701630	Prunedale Chevron WS	25		1
3100	Total Coliform-routine monitoring		2701658	Arroyo Center WC	130		1
3100	Total Coliform-routine monitoring		2701726	Spence Rd WS #05	25		1
3100	Total Coliform-routine monitoring		2701731	Brandon Creek MWS	41		3
3100	Total Coliform-routine monitoring		2701800	Tularcitos MWC	85		1
3100	Total Coliform-routine monitoring		2701876	Mushroom Farms WS	75		1
3100	Total Coliform-routine monitoring		2701946	Hoson Produce WS	60		2
3100	Total Coliform-routine monitoring		2702009	Laguna Seca Recreation WS	500		1
3100	Total Coliform-routine monitoring		2702030	Cypress Community Church WS	200		1
3100	Total Coliform-routine monitoring		2702073	San Miguel WS #22	93		1
3100	Total Coliform-routine monitoring		2702110	Delany WC	60		1
3100	Total Coliform-routine monitoring		2702163	Hilltop MWA	100		1
3100	Total Coliform-routine monitoring		2702165	Orchard Ln WS #09	25		1
3100	Total Coliform-routine monitoring		2702172	Stonepine Resort WS	100		1
3100	Total Coliform-routine monitoring		2702180	Graves School WS	56		1
3100	Total Coliform-routine monitoring		2702254	Pacific Valley School WS	55		1
3100	Total Coliform-routine monitoring		2702255	All Saints Campground WS	25		1
3100	Total Coliform-routine monitoring		2702374	Countryside Estates MWC	73		1
3100	Total Coliform-routine monitoring		2702396	River Rd WS #26	25		1
3100	Total Coliform-routine monitoring		2702431	Foothill Rd WS #01	25		1
3100	Total Coliform-routine monitoring		2702475	Free Will Baptist Church WS	80		1
3100	Total Coliform-routine monitoring		2702486	Bernardo Rd WS #02	25		1
3100	Total Coliform-routine monitoring		2702551	Loma Vista Inn WS	25		1
3100	Total Coliform-routine monitoring		2702566	Premium Fresh Farms WS	25		2
3100	Total Coliform-routine monitoring		2702575	Tree Bones Resort WS	25		1
3100	Total Coliform-routine monitoring		2702613	Estancia Winery WS	25		1
3100	Total Coliform-routine monitoring		2702616	Altman Plants WS #02	25		2
3100	Total Coliform-routine monitoring		2702620	Harrington Rd WS #07	25		1
3100	Total Coliform-routine monitoring		2702643	Cypress Center WS	40		2
3100	Total Coliform-routine monitoring		2702784	Spreckels Rd WS #04	25		1
3100	Total Coliform-routine monitoring		2800031	Signorello Winery	25		1
3100	Total Coliform-routine monitoring		2800736	Domaine Chandon	200		1
3100	Total Coliform-routine monitoring		2801020	Clemmer Trust, The	30		1
3100	Total Coliform-routine monitoring		2801026	Opus One Winery	100		1
3100	Total Coliform-routine monitoring		2801046	St. Supery Winery	40		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		2900529	Sunset Mobile Home Park Water System	60		1
3100	Total Coliform-routine monitoring		2900540	Forest Lake Christian School Water System	150		1
3100	Total Coliform-routine monitoring		2900547	Rollins Lakeside Inn Water System	35		1
3100	Total Coliform-routine monitoring		2900572	Five-Mile House Restaurant Water System	150		1
3100	Total Coliform-routine monitoring		2900578	Grizzly Hill School Water System	125		1
3100	Total Coliform-routine monitoring		2900587	Milhouse Children Services Water System	50		1
3100	Total Coliform-routine monitoring		2900593	Oak Tree School Water System	120		2
3100	Total Coliform-routine monitoring		2902326	Dew Drop Inn Water System	50		1
3100	Total Coliform-routine monitoring		2902363	Mission Beth'El Church Water System	60		1
3100	Total Coliform-routine monitoring		2902391	North Gold Senior Mountaineers Water Sys	50		1
3100	Total Coliform-routine monitoring		3100001	Timber Hills Mutual Water Co	100		1
3100	Total Coliform-routine monitoring		3100058	Dutch Flat Mutual	250		1
3100	Total Coliform-routine monitoring		3100072	Live Oak Waldorf School	220		1
3100	Total Coliform-routine monitoring		3103195	Applegate Station	25		1
3100	Total Coliform-routine monitoring		3103234	Everybody's Inn	25		1
3100	Total Coliform-routine monitoring		3104519	Caltrans-Whitmore Maint. Station	25		1
3100	Total Coliform-routine monitoring		3107311	Summit Deck & Grill- Northstar	2000		1
3100	Total Coliform-routine monitoring		3107315	Tahoe Vistana	50		1
3100	Total Coliform-routine monitoring		3200009	Caltrans-Massack Rest Stop	350		1
3100	Total Coliform-routine monitoring		3200020	Caltrans-L.T. Davis Reststop	200		1
3100	Total Coliform-routine monitoring		3200022	Caltrans-Chester Safety Rest Stop	120		1
3100	Total Coliform-routine monitoring		3200072	Buck'S Lakeshore Resort	200		1
3100	Total Coliform-routine monitoring		3200078	FRCCSD-Old Mill Mutual	16		1
3100	Total Coliform-routine monitoring		3200103	FRCCSD-Belden Town	25		1
3100	Total Coliform-routine monitoring		3200105	FRCCSD-Tobin	25		1
3100	Total Coliform-routine monitoring		3301241	El Dorado Polo Club	50		1
3100	Total Coliform-routine monitoring		3301280	Golden Era Productions	500		1
3100	Total Coliform-routine monitoring		3301305	California Redi Date, Llc	27		1
3100	Total Coliform-routine monitoring		3301308	Cottonwood School	300		1
3100	Total Coliform-routine monitoring		3301359	Kennedy Grocery	450		1
3100	Total Coliform-routine monitoring		3301643	Spring Crest Water & Power	30		2
3100	Total Coliform-routine monitoring		3301682	Trails End Mutual Water Company	75		1
3100	Total Coliform-routine monitoring		3301690	Twin Pines Boys Ranch	70		1
3100	Total Coliform-routine monitoring		3301850	Delara Rentals	25		1
3100	Total Coliform-routine monitoring		3301937	Mesquite Mutual Water Company	25		1
3100	Total Coliform-routine monitoring		3301947	Morning Sky School	50		1
3100	Total Coliform-routine monitoring		3302045	Rancho San Miguel Labor Camp	25		1
3100	Total Coliform-routine monitoring		3302069	La Pena Housing Facility	100		1
3100	Total Coliform-routine monitoring		3302079	Aida Aguirre & Dimicio Sampagan	50		1
3100	Total Coliform-routine monitoring		3302088	Rancho La Mesa Rica	40		1
3100	Total Coliform-routine monitoring		3303002	Oasis Palms Rv Park	25		1
3100	Total Coliform-routine monitoring		3303026	Granite Construction Company	25		1
3100	Total Coliform-routine monitoring		3303085	Hits Desert Horse Park	900		1
3100	Total Coliform-routine monitoring		3400161	Tahoe Lodge	40		1
3100	Total Coliform-routine monitoring		3400204	Red Phoenix/Beau's	50		1
3100	Total Coliform-routine monitoring		3400284	Foothill Golf Center	200		2
3100	Total Coliform-routine monitoring		3500505	Thousand Trails San Benito Preserve	1750		1
3100	Total Coliform-routine monitoring		3500507	Bitterwater-Tully School WS	45		1
3100	Total Coliform-routine monitoring		3500509	Tres Pinos Cwd	500		1
3100	Total Coliform-routine monitoring		3500510	Mcmahon Road Mutual Water Company	100		1
3100	Total Coliform-routine monitoring		3500511	Casa De Fruta Orchards	81		1
3100	Total Coliform-routine monitoring		3500521	Southside Elementary School	250		1
3100	Total Coliform-routine monitoring		3500526	Arnold Park (O'Bannon's MHP)	28		1
3100	Total Coliform-routine monitoring		3500527	Valenzuela Water System	55		1
3100	Total Coliform-routine monitoring		3500547	Cedar House Restaurant	25		1
3100	Total Coliform-routine monitoring		3500549	Rosa Morada Mutual Water Company	50		1
3100	Total Coliform-routine monitoring		3500552	Venture Estates MWC	55		1
3100	Total Coliform-routine monitoring		3500565	Fairview Child Develop Center	70		1
3100	Total Coliform-routine monitoring		3500570	B&R Farms	25		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		3500571	San Benito High School	2700		1
3100	Total Coliform-routine monitoring		3500575	Springwood Estates MWC	45		1
3100	Total Coliform-routine monitoring		3500576	Aromas Hills Mutual Water Association	60		1
3100	Total Coliform-routine monitoring		3500577	Cole Rd MWC	29		2
3100	Total Coliform-routine monitoring		3500578	Los Madrones MWC	40		1
3100	Total Coliform-routine monitoring		3500801	Willow Grove Union Elem School	60		1
3100	Total Coliform-routine monitoring		3500804	Seminis Vegetables Seeds, Inc.	30		1
3100	Total Coliform-routine monitoring		3500806	Blossom Hill Winery	60		1
3100	Total Coliform-routine monitoring		3500807	Denice & Filice Llc	200		1
3100	Total Coliform-routine monitoring		3500810	Whispering Pines Retire Home (LSWS)	100		1
3100	Total Coliform-routine monitoring		3500816	Quintero Labor Camp #2	35		1
3100	Total Coliform-routine monitoring		3500817	Lico Labor Camp	49		1
3100	Total Coliform-routine monitoring		3500903	San Juan Oaks Golf Club	450		1
3100	Total Coliform-routine monitoring		3500906	Haydon Family Farm & Park	150		1
3100	Total Coliform-routine monitoring		3500912	Comstock Mutual Water Company	100		1
3100	Total Coliform-routine monitoring		3500913	Earthbound Farms	900		1
3100	Total Coliform-routine monitoring		3500920	Paicines Water System	50		1
3100	Total Coliform-routine monitoring		3500924	El Modeno Nursery Inc.	150		1
3100	Total Coliform-routine monitoring		3500925	Paicines Ranch	45		1
3100	Total Coliform-routine monitoring		3510006	Mission Oaks Mobile Home Park	500		1
3100	Total Coliform-routine monitoring		3510300	CSP-Fremont Peak	50		1
3100	Total Coliform-routine monitoring		3600394	New Beginnings	150		1
3100	Total Coliform-routine monitoring		3600504	Knoll Enterprises Inc	500		1
3100	Total Coliform-routine monitoring		3700003	Whispering Winds Conference Center	160		1
3100	Total Coliform-routine monitoring		3700008	Volcan Mountain Hunting Club	70		1
3100	Total Coliform-routine monitoring		3700015	Heller Ford Mitsubishi Suzuki	160		1
3100	Total Coliform-routine monitoring		3700018	Campo Elementary School	300		1
3100	Total Coliform-routine monitoring		3700023	Coleman Creek Village	50		1
3100	Total Coliform-routine monitoring		3700030	Fry Creek Observatory	300		1
3100	Total Coliform-routine monitoring		3700041	Barrett Lake Mobilehome Park	150		4
3100	Total Coliform-routine monitoring		3700042	Lakeland Resort	25		1
3100	Total Coliform-routine monitoring		3700047	T.C. Worthy Cash & Carry, Inc.	25		1
3100	Total Coliform-routine monitoring		3700049	Potrero General Store	800		2
3100	Total Coliform-routine monitoring		3700065	South Bay Rod & Gun Club	8000		1
3100	Total Coliform-routine monitoring		3700071	Heavenly Oaks	300		3
3100	Total Coliform-routine monitoring		3700073	H & J Water Company	50		1
3100	Total Coliform-routine monitoring		3700074	Cuyamaca Water District	200		1
3100	Total Coliform-routine monitoring		3700118	Campo Alternative School	25		1
3100	Total Coliform-routine monitoring		3700149	Wynola Bible Conference	100		1
3100	Total Coliform-routine monitoring		3700195	Outdoor World Retreat	300		1
3100	Total Coliform-routine monitoring		3700277	Sunrise Estates Mutual Water Company	200		3
3100	Total Coliform-routine monitoring		3700848	Alpine Springs Rv Park	200		2
3100	Total Coliform-routine monitoring		3700858	Shady Oaks Trailer Ranch	25		1
3100	Total Coliform-routine monitoring		3700859	Rancho Del Campo Water System	290		3
3100	Total Coliform-routine monitoring		3700906	Camp Stevens	50		1
3100	Total Coliform-routine monitoring		3700909	Julian Community Services District	578		1
3100	Total Coliform-routine monitoring		3700913	Apple Tree Inn	300		1
3100	Total Coliform-routine monitoring		3700924	Lake Morena VieWS Mw Co.	350		5
3100	Total Coliform-routine monitoring		3700933	Palomar Mountain Mutual Water Co.	70		1
3100	Total Coliform-routine monitoring		3700934	Pauma Valley Mutual Water Company	120		1
3100	Total Coliform-routine monitoring		3700936	Rancho Estates Mutual Water Co.	220		2
3100	Total Coliform-routine monitoring		3700962	Oakvale Park	100		2
3100	Total Coliform-routine monitoring		3700964	Swallows Sun Island Club	50		1
3100	Total Coliform-routine monitoring		3700968	San Pasqual Academy	150		1
3100	Total Coliform-routine monitoring		3700970	Yoga Center Retreat	50		1
3100	Total Coliform-routine monitoring		3701005	Spencer Valley School District	51		2
3100	Total Coliform-routine monitoring		3701070	Pincrest Community Center	70		1
3100	Total Coliform-routine monitoring		3701184	Butterfield Ranch	25		3
3100	Total Coliform-routine monitoring		3701213	Borrego Springs Park Community Services	35		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		3701217	Camp Virginia	25		1
3100	Total Coliform-routine monitoring		3701240	Yoga Center Mother's Kitchen	98		1
3100	Total Coliform-routine monitoring		3701241	Al Bahr Shrine Camp	150		1
3100	Total Coliform-routine monitoring		3701341	Butterfield Oaks Mobile Home Park	80		3
3100	Total Coliform-routine monitoring		3701407	Angels Landing Country Inn And Resort	30		1
3100	Total Coliform-routine monitoring		3701478	Phoenix Academy	65		1
3100	Total Coliform-routine monitoring		3701594	Featherstone Canyon Christian Camp	50		1
3100	Total Coliform-routine monitoring		3701780	Richardson Beardsley Inc.	38		3
3100	Total Coliform-routine monitoring		3701837	Wynola Water District	120		3
3100	Total Coliform-routine monitoring		3701983	Dudley'S Bakery	100		1
3100	Total Coliform-routine monitoring		3702059	Skyline Ranch Campgrounds & RV Park	38		1
3100	Total Coliform-routine monitoring		3702235	Mobiland Camper Park	320		1
3100	Total Coliform-routine monitoring		3702236	Palomar Observatory	25		1
3100	Total Coliform-routine monitoring		3702283	Mt. Laguna Improv. Assn.	100		2
3100	Total Coliform-routine monitoring		3702302	Desert Ironwoods Resort Inc.	25		1
3100	Total Coliform-routine monitoring		3702349	Rancho L'Abri	25		1
3100	Total Coliform-routine monitoring		3702420	Stagecoach Trails Resort	695		1
3100	Total Coliform-routine monitoring		3702479	Ranch Feed & Supply	50		1
3100	Total Coliform-routine monitoring		3702494	Chef's Hat Restaurant	250		1
3100	Total Coliform-routine monitoring		3702530	Camp Cedar Glen	100		1
3100	Total Coliform-routine monitoring		3702703	De Anza Springs Resort	300		1
3100	Total Coliform-routine monitoring		3702706	Highland East Trailer Park	25		1
3100	Total Coliform-routine monitoring		3702757	Barrett Junction Cafe, Inc.	25		1
3100	Total Coliform-routine monitoring		3705046	Amerimex Market	50		1
3100	Total Coliform-routine monitoring		3710302	Anza Borrego Sp - Palm Canyon	18		1
3100	Total Coliform-routine monitoring		3710306	Anza Borrego Sp - Tamarisk Grove	146		1
3100	Total Coliform-routine monitoring		3900557	Banta Mutual Water Co #3	75		1
3100	Total Coliform-routine monitoring		3900575	Donald'S	36		2
3100	Total Coliform-routine monitoring		3900592	Town & Country Inn	55		1
3100	Total Coliform-routine monitoring		3900607	Country Squire Mobile Estates	64		1
3100	Total Coliform-routine monitoring		3900616	Windmill Cove Marina & RV Park	50		2
3100	Total Coliform-routine monitoring		3900651	Lost Isle Resort	25		1
3100	Total Coliform-routine monitoring		3900666	King Island Marina PWS	1000		2
3100	Total Coliform-routine monitoring		3901198	Yosemite Inn - PWS	50		2
3100	Total Coliform-routine monitoring		3901238	Mokelumne Beach Rv Park	30		1
3100	Total Coliform-routine monitoring		3901249	3 B'S Truck & Auto Plaza	1000		3
3100	Total Coliform-routine monitoring		3901252	Waterloo California Restaurant	25		1
3100	Total Coliform-routine monitoring		3901296	Italian Athletic Club	50		1
3100	Total Coliform-routine monitoring		3901341	Raudel Delgado Water System	50		1
3100	Total Coliform-routine monitoring		3901361	Backspin Golf Center	1000		1
3100	Total Coliform-routine monitoring		3901396	Beneto Water System	30		1
3100	Total Coliform-routine monitoring		3901418	Austin Industrial Park	25		1
3100	Total Coliform-routine monitoring		3901422	St Michael'S Water System	25		1
3100	Total Coliform-routine monitoring		3901427	Buon Giardino	25		1
3100	Total Coliform-routine monitoring		3901446	Amorosa Inn & Gardens Llc	25		1
3100	Total Coliform-routine monitoring		3901447	Old River Golf Course	25		2
3100	Total Coliform-routine monitoring		4000203	Irish Hills Mutual Water Co	10		1
3100	Total Coliform-routine monitoring		4000211	Greenheart Farms	50		1
3100	Total Coliform-routine monitoring		4000213	Toyota San Luis Obispo	35		1
3100	Total Coliform-routine monitoring		4000215	Williams Water Co	30		1
3100	Total Coliform-routine monitoring		4000219	Links At Vista Del Hombre, The	25		1
3100	Total Coliform-routine monitoring		4000221	Laetitia Vineyard & Winery Inc	25		1
3100	Total Coliform-routine monitoring		4000226	Pacific Dunes Ranch	40		1
3100	Total Coliform-routine monitoring		4000300	Arciero Winery	28		2
3100	Total Coliform-routine monitoring		4000568	San Simeon Csd	499		1
3100	Total Coliform-routine monitoring		4000590	Water World Resorts-Lake Nacimiento	1000		2
3100	Total Coliform-routine monitoring		4000637	Country Hills Estates	60		1
3100	Total Coliform-routine monitoring		4000643	Black Mountain R.V. Resort	35		1
3100	Total Coliform-routine monitoring		4000673	Jack Ranch Cafe	30		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		4000705	Laguna Negra Mutual Water Co.	80		2
3100	Total Coliform-routine monitoring		4000730	Holdgrafer & Associates	30		2
3100	Total Coliform-routine monitoring		4000741	H2O, Inc	60		1
3100	Total Coliform-routine monitoring		4000744	Afuera De Chorro Water Company	75		1
3100	Total Coliform-routine monitoring		4000749	Terra De Oro Water Company	35		2
3100	Total Coliform-routine monitoring		4000750	Rim Rock Water Company	55		1
3100	Total Coliform-routine monitoring		4000751	Ernie Ball, Inc	300		1
3100	Total Coliform-routine monitoring		4000757	Cerro Alto Campground	30		1
3100	Total Coliform-routine monitoring		4000765	Varian Ranch	120		1
3100	Total Coliform-routine monitoring		4000771	Rancho Nipomo Water Company	65		1
3100	Total Coliform-routine monitoring		4000781	Meridian Vineyards	30		1
3100	Total Coliform-routine monitoring		4000804	Whispering MeadoWS - Butterfly Lane	45		1
3100	Total Coliform-routine monitoring		4100504	Webb Ranch	25		1
3100	Total Coliform-routine monitoring		4100512	Loma Mar Mutual	108		1
3100	Total Coliform-routine monitoring		4100603	Costanoa Campground	25		2
3100	Total Coliform-routine monitoring		4300808	O'Connor Hospital	2500		1
3100	Total Coliform-routine monitoring		4400502	Mar Vista Water Company Inc	584		1
3100	Total Coliform-routine monitoring		4400526	Big Redwood Park Water	215		1
3100	Total Coliform-routine monitoring		4400528	Laurel Community League	69		1
3100	Total Coliform-routine monitoring		4400530	Land Of Medicine Buddha	75		1
3100	Total Coliform-routine monitoring		4400570	Mountain Summit Mutual Water System	30		1
3100	Total Coliform-routine monitoring		4400582	Pine Tree Lane Mutual Water Co	40		1
3100	Total Coliform-routine monitoring		4400597	La Madrona Swim & Racquet Club	100		1
3100	Total Coliform-routine monitoring		4400605	Crestwood Heights Water Assn	142		1
3100	Total Coliform-routine monitoring		4400613	Las Colinas Road & Water Assn	69		1
3100	Total Coliform-routine monitoring		4400624	Rancho Corralitos	50		1
3100	Total Coliform-routine monitoring		4400631	Las Cumbres Mutual Water Co	250		1
3100	Total Coliform-routine monitoring		4400645	Hidden Meadow Mutual Water Co	37		1
3100	Total Coliform-routine monitoring		4400659	Potbelly Beach Club	60		1
3100	Total Coliform-routine monitoring		4400707	Camp Lindblad	125		1
3100	Total Coliform-routine monitoring		4400711	Camp Chesebrough	150		1
3100	Total Coliform-routine monitoring		4400721	Skylark Ranch Girl Scout Camp	99		1
3100	Total Coliform-routine monitoring		4400723	Mission Springs Conference Center	564		1
3100	Total Coliform-routine monitoring		4400807	Mount Madonna Inn Restaurant	100		1
3100	Total Coliform-routine monitoring		4410800	Ben Lomond Camp	110		1
3100	Total Coliform-routine monitoring		4500011	Andreini Business Park Water System	130		1
3100	Total Coliform-routine monitoring		4500035	Siskiyou Forest Products	75		1
3100	Total Coliform-routine monitoring		4500076	E & G Resort	35		2
3100	Total Coliform-routine monitoring		4500083	Pg&E - Mccumber Campground	60		3
3100	Total Coliform-routine monitoring		4500086	Pg&E - Northshore Campground	75		3
3100	Total Coliform-routine monitoring		4500098	Shady Hill Mobile Home Park	35		1
3100	Total Coliform-routine monitoring		4500100	Shasta Marina Resort	235		1
3100	Total Coliform-routine monitoring		4500110	Silverthorn Resort	175		1
3100	Total Coliform-routine monitoring		4500136	Klub Klondike	35		1
3100	Total Coliform-routine monitoring		4500153	Shasta District Fair	10200		1
3100	Total Coliform-routine monitoring		4500213	Jolly Giant Flea Market	75		1
3100	Total Coliform-routine monitoring		4500214	West Valley High School	1100		1
3100	Total Coliform-routine monitoring		4500224	Basshole	30		1
3100	Total Coliform-routine monitoring		4500227	Crystal Creek Regional Boy's Camp	75		1
3100	Total Coliform-routine monitoring		4500283	Caltrans-Hillcrest SRRA	2500		1
3100	Total Coliform-routine monitoring		4500289	Caltrans-Shingletown SRRA	270		1
3100	Total Coliform-routine monitoring		4500325	Lassen Pines Christian Conference Center	300		1
3100	Total Coliform-routine monitoring		4500333	Airport Planet Water	35		1
3100	Total Coliform-routine monitoring		4500334	Rainbow'S End Mobile Home Park	38		1
3100	Total Coliform-routine monitoring		4600058	Coyoteville	65		1
3100	Total Coliform-routine monitoring		4700521	Siskiyou Co.Service Area #5/Carrick	142		1
3100	Total Coliform-routine monitoring		4700539	Macdoel Waterworks	35		1
3100	Total Coliform-routine monitoring		4700569	Willow Creek School	100		1
3100	Total Coliform-routine monitoring		4700585	Junction Elementary School	40		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		4700591	Delphic Elementary School	50		1
3100	Total Coliform-routine monitoring		4700663	Weed Golf Club, Inc.	110		1
3100	Total Coliform-routine monitoring		4700847	Quartz Valley School	60		1
3100	Total Coliform-routine monitoring		4710009	City Of Weed	2963		1
3100	Total Coliform-routine monitoring		4900552	Michele Mutual Water Company	170		1
3100	Total Coliform-routine monitoring		4900568	Valley Ford Water Association	40		1
3100	Total Coliform-routine monitoring		4900640	Sonoma County Mutual Water Company	40		1
3100	Total Coliform-routine monitoring		4900702	Pacific Christian Academy	84		1
3100	Total Coliform-routine monitoring		4900720	Mobile Home Estates	320		1
3100	Total Coliform-routine monitoring		4900791	Western Mobile Home Park	225		1
3100	Total Coliform-routine monitoring		4900799	EI Portal Mobile Estates	200		2
3100	Total Coliform-routine monitoring		4900905	Mark West Meadows Mutual Water	70		1
3100	Total Coliform-routine monitoring		4900911	Blackstone Winery	50		1
3100	Total Coliform-routine monitoring		4900940	Petaluma Mushroom Farm, Inc.	40		1
3100	Total Coliform-routine monitoring		4901101	Mount Gilead Bible Conference	85		1
3100	Total Coliform-routine monitoring		4901120	Roche Winery	25		2
3100	Total Coliform-routine monitoring		4901129	Viansa Winery	200		1
3100	Total Coliform-routine monitoring		4901151	Schug Cellars	25		1
3100	Total Coliform-routine monitoring		4901179	Redwood Empire Sawmill	80		1
3100	Total Coliform-routine monitoring		4901193	Schellville Grill	50		1
3100	Total Coliform-routine monitoring		4901262	Ravenswood (Quarry) Winery	25		1
3100	Total Coliform-routine monitoring		4910701	U.S. Coast Guard Training Center	1350		1
3100	Total Coliform-routine monitoring		5000106	City Of Oakdale Airport Water System	25		1
3100	Total Coliform-routine monitoring		5000139	Durango'S/Owner: Leonardo Lopez	26		1
3100	Total Coliform-routine monitoring		5000272	City Of Oakdale - Kerr Park	26		1
3100	Total Coliform-routine monitoring		5000430	City Of Oakdale Treatment Plant-Water Qu	25		1
3100	Total Coliform-routine monitoring		5100120	Roll-A-Home Mobile H.P.	150		1
3100	Total Coliform-routine monitoring		5101007	Country Village North MHP	26		2
3100	Total Coliform-routine monitoring		5200534	Paskenta Comm. Services Dist.	120		1
3100	Total Coliform-routine monitoring		5200606	Tehama Co.-Cone Grove Park	25		1
3100	Total Coliform-routine monitoring		5200608	Tehama Co.-River Park	25		1
3100	Total Coliform-routine monitoring		5200642	Tehama Co.-Ridgeway Park	25		1
3100	Total Coliform-routine monitoring		5200653	Tehama Co.-Mill Creek Park	25		1
3100	Total Coliform-routine monitoring		5301018	Trinity Alps Marina	75		3
3100	Total Coliform-routine monitoring		5304502	Salyer Heights W.S., Inc	82		3
3100	Total Coliform-routine monitoring		5400509	Panorama Heights Prop Owners	100		1
3100	Total Coliform-routine monitoring		5400529	Shady Grove M.H.P.	137		4
3100	Total Coliform-routine monitoring		5400536	Kings River Estates	100		1
3100	Total Coliform-routine monitoring		5400552	Stoney Creek	42		1
3100	Total Coliform-routine monitoring		5400553	Traver Water Llc	500		2
3100	Total Coliform-routine monitoring		5400555	Citrus South Tule School	34		1
3100	Total Coliform-routine monitoring		5400563	Country Manor M.H.P.	250		1
3100	Total Coliform-routine monitoring		5400567	Tooleville Water Co.	300		1
3100	Total Coliform-routine monitoring		5400581	Spear Creek Cabin Owners Assoc	52		1
3100	Total Coliform-routine monitoring		5400611	Porterville Trailer Park	80		3
3100	Total Coliform-routine monitoring		5400634	Lovell School	60		3
3100	Total Coliform-routine monitoring		5400636	Orosi High School	900		3
3100	Total Coliform-routine monitoring		5400638	Sierra School	40		2
3100	Total Coliform-routine monitoring		5400687	Orange Blossom Junction	100		1
3100	Total Coliform-routine monitoring		5400695	Army Corps Engs-South Camp	100		1
3100	Total Coliform-routine monitoring		5400696	Army Corps Engs-North Camp	25		1
3100	Total Coliform-routine monitoring		5400699	Kaweah High School	110		2
3100	Total Coliform-routine monitoring		5400722	Sugarloaf Mutual Water Co.	38		1
3100	Total Coliform-routine monitoring		5400724	Panorama Park Fire Pro. Co.	90		1
3100	Total Coliform-routine monitoring		5400761	Lake Elowin Resort	40		1
3100	Total Coliform-routine monitoring		5400778	Scicon	21		2
3100	Total Coliform-routine monitoring		5400797	Tulare Co Correctional Center	300		1
3100	Total Coliform-routine monitoring		5400816	Bedel Mutual Water Co.	155		1
3100	Total Coliform-routine monitoring		5400819	Mountain View M.H.P.	44		2

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		5400824	Sultana C.S.D.	650		3
3100	Total Coliform-routine monitoring		5400850	Packwood School	30		1
3100	Total Coliform-routine monitoring		5400931	Truckers Mini Mart	25		1
3100	Total Coliform-routine monitoring		5400975	The Seafood Cafe	50		1
3100	Total Coliform-routine monitoring		5400985	Bob's Tiny Mart	25		1
3100	Total Coliform-routine monitoring		5400986	Deer Creek Lodge	46		2
3100	Total Coliform-routine monitoring		5401001	Sequoia Cider Mill	30		2
3100	Total Coliform-routine monitoring		5401003	East Orosi C.S.D.	106		1
3100	Total Coliform-routine monitoring		5401039	Tulare County Civic Center	300		1
3100	Total Coliform-routine monitoring		5401074	Bob Wiley Detention Facility	575		1
3100	Total Coliform-routine monitoring		5401096	Sun Pacific-Woodlake	95		3
3100	Total Coliform-routine monitoring		5402008	Hot Springs School	42		2
3100	Total Coliform-routine monitoring		5402013	Sun Pacific-Exeter	200		3
3100	Total Coliform-routine monitoring		5402037	Three Rivers Library	80		1
3100	Total Coliform-routine monitoring		5402055	Camp Keep Sierra	110		1
3100	Total Coliform-routine monitoring		5403013	Prince Mart	25		1
3100	Total Coliform-routine monitoring		5403023	Delft Colony Water	400		1
3100	Total Coliform-routine monitoring		5403043	Yettem Water System	350		1
3100	Total Coliform-routine monitoring		5403053	NS Mini Mart	140		2
3100	Total Coliform-routine monitoring		5403072	Rogers Camp Homeowners Assn.	25		1
3100	Total Coliform-routine monitoring		5403084	Fairway Mutual Water Co	53		1
3100	Total Coliform-routine monitoring		5410033	Pratt Mutual Water Co	1600		3
3100	Total Coliform-routine monitoring		5510021	Tud-Peaceful Pines Water System	71		1
3100	Total Coliform-routine monitoring		5601104	Casitas Mutual Water Company	229		1
3100	Total Coliform-routine monitoring		5602406	Rio School Dist/Rio Del Valle School	820		1
3100	Total Coliform-routine monitoring		5602516	Well-Pict Berries WS	50		4
3100	Total Coliform-routine monitoring		5603117	Santa Clara Resources	200		1
3100	Total Coliform-routine monitoring		5800854	Spring Valley School	100		1
3100	Total Coliform-routine monitoring		5805001	Plumas Lake	3300		1
3100	Total Coliform-routine monitoring		5810003	Olivehurst Public U.D.	12200		1
Counts / Totals			515		129207	650	
3100	Total Coliform-followup monitoring		300062	Hope Foundation/Moriah Heights	300		1
3100	Total Coliform-followup monitoring		500096	Valley Springs Driving Range	100		1
3100	Total Coliform-followup monitoring		706059	Blue Star Gas Mart	120		2
3100	Total Coliform-followup monitoring		706107	Carson Swim School	35		1
3100	Total Coliform-followup monitoring		707515	Church Of Jesus Christ	200		1
3100	Total Coliform-followup monitoring		707521	Byron Corners	90		1
3100	Total Coliform-followup monitoring		707580	Baldocchi Water System	90		1
3100	Total Coliform-followup monitoring		707581	Riverview Marina SWS	40		1
3100	Total Coliform-followup monitoring		707591	Blue Tip Trailer Park Water	35		1
3100	Total Coliform-followup monitoring		708004	Pacific Ranch	45		1
3100	Total Coliform-followup monitoring		800552	Northcrest Trailer City	250		1
3100	Total Coliform-followup monitoring		800700	Las Palmas Mobile Home Park	120		1
3100	Total Coliform-followup monitoring		800800	Pine Grove Trailer Park	100		1
3100	Total Coliform-followup monitoring		1000365	Ponderosa Trailer Park	156		1
3100	Total Coliform-followup monitoring		1500517	Stoco Mutual Water Company	2500		1
3100	Total Coliform-followup monitoring		1503274	Ed Oakley Hall	45		1
3100	Total Coliform-followup monitoring		1503341	Tejon Ranch-Intst. 5 & Laval Rd.	500		1
3100	Total Coliform-followup monitoring		1510701	Edwards Afb - Main Base	17066		1
3100	Total Coliform-followup monitoring		1900563	Sundale Mutual Water Company 'A', 'B'	350		1
3100	Total Coliform-followup monitoring		2300519	Coast Motel	25		1
3100	Total Coliform-followup monitoring		2700518	Watsonville Produce WS	100		1
3100	Total Coliform-followup monitoring		2700534	Colonial Oaks WC	198		1
3100	Total Coliform-followup monitoring		2700575	El Camino Real WS #16	29		1
3100	Total Coliform-followup monitoring		2700592	Harrison Rd WS #01	40		1
3100	Total Coliform-followup monitoring		2700594	Hidden Valley Wa	51		1
3100	Total Coliform-followup monitoring		2700613	Lagunita School WS	60		1
3100	Total Coliform-followup monitoring		2700638	Maher Rd WS #05	51		2

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-followup monitoring		2700662	Murphy Hill WS #01	65		1
3100	Total Coliform-followup monitoring		2700674	Paradise Lake MWC	180		1
3100	Total Coliform-followup monitoring		2700703	Calvary Church Inc WS	150		1
3100	Total Coliform-followup monitoring		2700772	Struve Rd WS #02	166		1
3100	Total Coliform-followup monitoring		2700856	Altman Plants WS #01	45		2
3100	Total Coliform-followup monitoring		2701040	Mccoy Rd WS #05	72		1
3100	Total Coliform-followup monitoring		2701063	River Rd WS #25	65		1
3100	Total Coliform-followup monitoring		2701355	Princes Camp Resort WS	126		1
3100	Total Coliform-followup monitoring		2701647	Green Acres Wa	50		1
3100	Total Coliform-followup monitoring		2701731	Brandon Creek MWS	41		1
3100	Total Coliform-followup monitoring		2701918	Lomas Del Sol MWS	93		1
3100	Total Coliform-followup monitoring		2701942	Vierra Canyon WS #29	25		1
3100	Total Coliform-followup monitoring		2702140	Woodside Wa	78		1
3100	Total Coliform-followup monitoring		2702165	Orchard Ln WS #09	25		1
3100	Total Coliform-followup monitoring		2702409	Ei Camino WC Inc	90		1
3100	Total Coliform-followup monitoring		2702551	Loma Vista Inn WS	25		1
3100	Total Coliform-followup monitoring		2702615	Esperanza Rd WS	160		1
3100	Total Coliform-followup monitoring		2702616	Altman Plants WS #02	25		3
3100	Total Coliform-followup monitoring		3200103	FRCCSD-Belden Town	25		1
3100	Total Coliform-followup monitoring		3200105	FRCCSD-Tobin	25		1
3100	Total Coliform-followup monitoring		3701478	Phoenix Academy	65		1
3100	Total Coliform-followup monitoring		3901252	Waterloo California Restaurant	25		1
3100	Total Coliform-followup monitoring		3901361	Backspin Golf Center	1000		1
3100	Total Coliform-followup monitoring		3901394	Calva Products Co Inc	30		1
3100	Total Coliform-followup monitoring		4210018	Buellton Water Department	4000		1
3100	Total Coliform-followup monitoring		4400652	Cathedral Hills MWC, Inc	50		1
3100	Total Coliform-followup monitoring		4400665	Meadowridge Mutual Water Co	25		2
3100	Total Coliform-followup monitoring		4400701	Quaker Center	65		1
3100	Total Coliform-followup monitoring		4400823	Spring Hills Golf Course	55		1
3100	Total Coliform-followup monitoring		4500061	Pg&E - Cassel Campground	80		1
3100	Total Coliform-followup monitoring		4900107	Alexander Valley Store/Bar	25		1
3100	Total Coliform-followup monitoring		4901162	Quivira Vineyards	60		1
3100	Total Coliform-followup monitoring		4901218	Groskopf Warehouse, Inc.	30		1
3100	Total Coliform-followup monitoring		4901253	Belvedere Vineyards & Winery	28		1
3100	Total Coliform-followup monitoring		5301103	Covington Mill - A	55		1
3100	Total Coliform-followup monitoring		5301104	Trinity Lake Forest	50		2
3100	Total Coliform-followup monitoring		5301201	Seymour's Mutual Water System	25		1
3100	Total Coliform-followup monitoring		5301205	Coffee Creek Ranch	50		1
3100	Total Coliform-followup monitoring		5403103	Tract 327 Mutual Water Co.	24		1
3100	Total Coliform-followup monitoring		5500145	San Jose Family Camp	200		1
3100	Total Coliform-followup monitoring		5500363	MDWC:Wards Ferry Ranches	45		1
Counts / Totals					68	30214	75
Disinfectant and Disinfection Byproducts Rule (DBPR) Violations							
2456	Haloacetic Acids (HAA-5)	0.060	310005	Pine Grove Comm Serv Dist	900	1	
2456	Haloacetic Acids (HAA-5)	0.060	310011	First Mace Meadow # 1	913	1	
2456	Haloacetic Acids (HAA-5)	0.060	310015	Rabb Park Community Ser. Dist.	353	1	
2456	Haloacetic Acids (HAA-5)	0.060	310018	First Mace Meadows Unit No. 2	221	1	
2456	Haloacetic Acids (HAA-5)	0.060	510006	C.C.W.D., Jenny Lind	9702	1	
2950	Total Trihalomethanes (TTHMs)	0.080	1010044	Huron, City Of	6306	3	
2950	Total Trihalomethanes (TTHMs)	0.080	1010051	Fresno Co Water Works Dist 18	891	1	
2950	Total Trihalomethanes (TTHMs)	0.080	1503341	Tejon Ranch-Intst. 5 & Laval Rd.	500	2	
2950	Total Trihalomethanes (TTHMs)	0.080	1510053	Antelope Valley E Kern Wtr Agy	0	1	
2950	Total Trihalomethanes (TTHMs)	0.080	1610001	Armona Community Services Dist	3239	3	
2950	Total Trihalomethanes (TTHMs)	0.080	1610700	Lemoore Naval Air Station	10661	1	
2950	Total Trihalomethanes (TTHMs)	0.080	1700568	Riviera West Mutual Water Co.	500	1	
2456	Haloacetic Acids (HAA-5)	0.060	1700581	Cache Creek Mobile Home Park	250	2	
2456	Haloacetic Acids (HAA-5)	0.060	1700609	Lazy S Mobile Ranch	73	1	
2456	Haloacetic Acids (HAA-5)	0.060	1710011	Buckingham Park Water District	575	1	

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
2950	Total Trihalomethanes (TTHMs)	0.080	2110001	Inverness Public Utility Dist	1200	1	
2456	Haloacetic Acids (HAA-5)	0.060	2110005	Bolinas Community PUD	1500	4	
2950	Total Trihalomethanes (TTHMs)	0.080	2110005			3	
2456	Haloacetic Acids (HAA-5)	0.060	2210001	Mariposa Public Utility Dist	2000	2	
2950	Total Trihalomethanes (TTHMs)	0.080	2210001			2	
2950	Total Trihalomethanes (TTHMs)	0.080	2300541	Heritage House Water System	50	1	
2950	Total Trihalomethanes (TTHMs)	0.080	2300832	Hills Ranch Mutual Water Company	60	2	
2456	Haloacetic Acids (HAA-5)	0.060	2310008	Redwood Valley County Water District	3969	2	
2950	Total Trihalomethanes (TTHMs)	0.080	2310008			2	
2456	Haloacetic Acids (HAA-5)	0.060	2310009	Brooktrails Township CSD	3700	1	
2950	Total Trihalomethanes (TTHMs)	0.080	2410950	DWR - San Luis Division O&M	150	2	
2950	Total Trihalomethanes (TTHMs)	0.080	2701221	Washington School WS	250	1	
2950	Total Trihalomethanes (TTHMs)	0.080	2701670	Langley/Valle Pacifico WS	81	1	
2456	Haloacetic Acids (HAA-5)	0.060	2810001	Howell Mountain Mutual Water Company	1500	1	
2950	Total Trihalomethanes (TTHMs)	0.080	2810001			1	
2950	Total Trihalomethanes (TTHMs)	0.080	2810005	American Canyon, City Of	15300	1	
2456	Haloacetic Acids (HAA-5)	0.060	2810011	Pleasure Cove Resort	650	2	
2950	Total Trihalomethanes (TTHMs)	0.080	2810011			2	
2950	Total Trihalomethanes (TTHMs)	0.080	3310046	Farm Mutual W.C. (The)	2710	3	
2950	Total Trihalomethanes (TTHMs)	0.080	3710707	Usn San Clemente Island	700	1	
2950	Total Trihalomethanes (TTHMs)	0.080	3710750	Nas North Island & Nab Coronado	4500	2	
2950	Total Trihalomethanes (TTHMs)	0.080	3910027	Mountain House Community Services Dist	4290	1	
2950	Total Trihalomethanes (TTHMs)	0.080	4210001	Carpinteria Valley Water District	18700	1	
2456	Haloacetic Acids (HAA-5)	0.060	5010039	Western Hills Water District/Diablo Grn	3000	4	
2950	Total Trihalomethanes (TTHMs)	0.080	5010039			4	
2456	Haloacetic Acids (HAA-5)	0.060	5410007	LSID - Tonyville	400	3	
2950	Total Trihalomethanes (TTHMs)	0.080	5410007			3	
2456	Haloacetic Acids (HAA-5)	0.060	5410037	LSID-Page Moore System	550	4	
2950	Total Trihalomethanes (TTHMs)	0.080	5410037			4	
2456	Haloacetic Acids (HAA-5)	0.060	5410038	Terra Bella Irrigation District - Tbt	2340	2	
2456	Haloacetic Acids (HAA-5)	0.060	5410503	SNP-Wolverton	2900	4	
2950	Total Trihalomethanes (TTHMs)	0.080	5410503			4	
2456	Haloacetic Acids (HAA-5)	0.060	5510007	Conlin Strawberry Water Company	165	2	
2950	Total Trihalomethanes (TTHMs)	0.080	5510008	Lake Don Pedro C S D	3200	1	
2456	Haloacetic Acids (HAA-5)	0.060	5510009	Groveland Community Serv Dist	3400	1	
2950	Total Trihalomethanes (TTHMs)	0.080	5510009			1	
2920	Total Organic Carbon (TOC)	TT	5510852	Baseline Conservation Camp	150	2	
2950	Total Trihalomethanes (TTHMs)	0.080	5610702	U.S.N., San Nicolas Island	350	1	
Counts / Totals			43		108559	100	
2456	Haloacetic Acids (HAA-5)		310004	Plymouth, City Of	941		1
2950	Total Trihalomethanes (TTHMs)		310004				1
2456	Haloacetic Acids (HAA-5)		310006	River Pines Pud	498		1
2950	Total Trihalomethanes (TTHMs)		310006				1
2950	Total Trihalomethanes (TTHMs)		500091	Rite Of Passage/Sierra Ridge	150		1
2456	Haloacetic Acids (HAA-5)		710004	City Of Brentwood	21000		1
2950	Total Trihalomethanes (TTHMs)		710004				1
0999	Stage 1 - DBP (Chlorine)		1010018	Kerman, City Of	11455		1
2456	Haloacetic Acids (HAA-5)		1010027	Reedley, City Of	22460		1
2950	Total Trihalomethanes (TTHMs)		1010027				1
2456	Haloacetic Acids (HAA-5)		1010028	Riverdale Public Utility District	3000		1
2950	Total Trihalomethanes (TTHMs)		1010028				1
2456	Haloacetic Acids (HAA-5)		1502759	Paramount Farms - Hwy 33 Facility	695		1
2950	Total Trihalomethanes (TTHMs)		1502759				1
2456	Haloacetic Acids (HAA-5)		1510013	Mcfarland MWC	9837		1
2950	Total Trihalomethanes (TTHMs)		1510013				1
2456	Haloacetic Acids (HAA-5)		1510014	Mojave Pud	3900		1
2950	Total Trihalomethanes (TTHMs)		1510014				1
2456	Haloacetic Acids (HAA-5)		1510022	West Kern Cwd	16800		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
2456	Haloacetic Acids (HAA-5)		1510027	Desert Lake Comm Serv Dist	860		1
2950	Total Trihalomethanes (TTHMs)		1510027				1
2456	Haloacetic Acids (HAA-5)		1510046	Lost Hills Utility District	1900		1
2950	Total Trihalomethanes (TTHMs)		1510046				1
2920	Total Organic Carbon (TOC)		1610002	Avenal, City Of	16205		1
2950	Total Trihalomethanes (TTHMs)		1610005	Lemoore, City Of	21076		1
2456	Haloacetic Acids (HAA-5)		1700508	Glenhaven Mutual Water Company	300		1
2950	Total Trihalomethanes (TTHMs)		1700508				1
2456	Haloacetic Acids (HAA-5)		1700519	Crescent Bay Improvement Company	18		1
2950	Total Trihalomethanes (TTHMs)		1700519				1
2456	Haloacetic Acids (HAA-5)		1700526	Pine Grove Water System	304		1
2950	Total Trihalomethanes (TTHMs)		1700526				1
2456	Haloacetic Acids (HAA-5)		1700536	Sunrise Shore Mutual Water Company	45		1
2950	Total Trihalomethanes (TTHMs)		1700536				1
2456	Haloacetic Acids (HAA-5)		1700574	Lake County Csa 18 - Starview	338		1
2950	Total Trihalomethanes (TTHMs)		1700574				1
2456	Haloacetic Acids (HAA-5)		1700589	Blue Lakes Mobile Home Park	50		1
2950	Total Trihalomethanes (TTHMs)		1700589				1
2456	Haloacetic Acids (HAA-5)		1700674	Walnut Cove Mobile Estates	10		1
2950	Total Trihalomethanes (TTHMs)		1700674				1
2456	Haloacetic Acids (HAA-5)		1900803	El Dorado Mutual Water Co.	648		1
2950	Total Trihalomethanes (TTHMs)		1900803				1
2456	Haloacetic Acids (HAA-5)		1910048	Castaic Lake Water Agency	0		1
2950	Total Trihalomethanes (TTHMs)		2010001	Chowchilla City Water Dept	9000		1
2456	Haloacetic Acids (HAA-5)		2110001	Inverness Public Utility Dist	1200		1
2950	Total Trihalomethanes (TTHMs)		2110001				1
2456	Haloacetic Acids (HAA-5)		2110008	Lawson's Landing	3100		1
2950	Total Trihalomethanes (TTHMs)		2110008				1
2456	Haloacetic Acids (HAA-5)		2300503	Sutherland Waterworks	27		1
2950	Total Trihalomethanes (TTHMs)		2300503				1
2456	Haloacetic Acids (HAA-5)		2300610	Caspar South Service Company	125		1
2950	Total Trihalomethanes (TTHMs)		2300610				1
2456	Haloacetic Acids (HAA-5)		2300663	Harwood Water System	100		2
2950	Total Trihalomethanes (TTHMs)		2300663				2
2456	Haloacetic Acids (HAA-5)		2300705	Little Lake Mobile Home Park	52		1
2950	Total Trihalomethanes (TTHMs)		2300705				1
2456	Haloacetic Acids (HAA-5)		2300708	Ridgewood Water System	200		1
2456	Haloacetic Acids (HAA-5)		2300829	Round Valley Schools	400		1
2950	Total Trihalomethanes (TTHMs)		2300829				1
2456	Haloacetic Acids (HAA-5)		2310010	Hopland Public Utility District	1020		1
2950	Total Trihalomethanes (TTHMs)		2310010				1
2456	Haloacetic Acids (HAA-5)		2310011	Laytonville County Water District	1301		1
2950	Total Trihalomethanes (TTHMs)		2310011				1
0999	Stage 1 - DBP (Chlorine)		2702412	Dole Fresh Vegetables WS	80		1
0999	Stage 1 - DBP (Chlorine)		2710004	Cal Am Water Company - Monterey	92115		1
0999	Stage 1 - DBP (Chlorine)		2710007	Gonzales, City Of	8374		1
0999	Stage 1 - DBP (Chlorine)		2710011	Soledad, City Of	14543		1
2456	Haloacetic Acids (HAA-5)		2810009	Berrysessa Pines Water System	200		1
2950	Total Trihalomethanes (TTHMs)		2810009				1
2456	Haloacetic Acids (HAA-5)		2810012	Pacific Union College	3000		1
2456	Haloacetic Acids (HAA-5)		2810014	Spanish Flat Water District	460		1
2950	Total Trihalomethanes (TTHMs)		2810014				1
0999	Stage 1 - DBP (Chlorine)		3000515	Harding Water Users	100		1
0999	Stage 1 - DBP (Chlorine)		3000803	Northrop Grumman Capistrano Test Site	120		1
0999	Stage 1 - DBP (Chlorine)		3000811	Crescent Water Association	300		2
2456	Haloacetic Acids (HAA-5)		3310033	Santa Ana River Water Company	8020		1
2950	Total Trihalomethanes (TTHMs)		3310033				1
0999	Stage 1 - DBP (Chlorine)		3500503	Harmony Hills Water System	60		1
0999	Stage 1 - DBP (Chlorine)		3500507	Bitterwater-Tully School WS	45		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
0400	Stage 1 - DBP (Monitoring Plan)		3500509	Tres Pinos CWD	500		2
0999	Stage 1 - DBP (Chlorine)		3500510	Mcmahon Road Mutual Water Company	100		1
0999	Stage 1 - DBP (Chlorine)		3500511	Casa De Fruta Orchards	81		1
0999	Stage 1 - DBP (Chlorine)		3500526	Arnold Park (O'Bannon'S MHP)	28		1
0999	Stage 1 - DBP (Chlorine)		3500527	Valenzuela Water System	55		1
0999	Stage 1 - DBP (Chlorine)		3500552	Venture Estates MWC	55		1
2456	Haloacetic Acids (HAA-5)		3500552				1
2950	Total Trihalomethanes (TTHMs)		3500552				1
0400	Stage 1 - DBP (Monitoring Plan)		3500556	Mission Farm R.V. Park	110		2
0999	Stage 1 - DBP (Chlorine)		3500556				2
0999	Stage 1 - DBP (Chlorine)		3500565	Fairview Child Develop Center	70		1
0999	Stage 1 - DBP (Chlorine)		3500578	Los Madrones MWC	40		1
0999	Stage 1 - DBP (Chlorine)		3500581	Rancho San Joaquin MWC	100		1
0999	Stage 1 - DBP (Chlorine)		3500801	Willow Grove Union Elem School	60		1
0999	Stage 1 - DBP (Chlorine)		3500817	Lico Labor Camp	49		1
0999	Stage 1 - DBP (Chlorine)		3500830	Hernandez Labor Camp	70		1
0999	Stage 1 - DBP (Chlorine)		3500903	San Juan Oaks Golf Club	450		1
0400	Stage 1 - DBP (Monitoring Plan)		3500913	Earthbound Farms	900		2
0999	Stage 1 - DBP (Chlorine)		3510006	Mission Oaks Mobile Home Park	500		1
2456	Haloacetic Acids (HAA-5)		4100546	Woodside Mutual	195		1
2950	Total Trihalomethanes (TTHMs)		4100546				1
2456	Haloacetic Acids (HAA-5)		4310800	AgneWS Dev. Center - East Campus	1830		1
2950	Total Trihalomethanes (TTHMs)		4310800				1
0999	Stage 1 - DBP (Chlorine)		4410001	Big Basin Water Company	1600		1
0999	Stage 1 - DBP (Chlorine)		4410016	Forest Lakes MWC	1141		1
0999	Stage 1 - DBP (Chlorine)		4410800	Ben Lomond Camp	110		1
2456	Haloacetic Acids (HAA-5)		4900536	Occidental Community Services District	150		1
2950	Total Trihalomethanes (TTHMs)		4900536				1
2456	Haloacetic Acids (HAA-5)		4900548	Holland Heights Mutual Water Company	300		1
2950	Total Trihalomethanes (TTHMs)		4900548				1
2456	Haloacetic Acids (HAA-5)		4900551	Melita Heights Mutual Water Company	60		1
2950	Total Trihalomethanes (TTHMs)		4900551				1
2456	Haloacetic Acids (HAA-5)		4900553	Park Royal Mutual Water	75		1
2950	Total Trihalomethanes (TTHMs)		4900553				1
2456	Haloacetic Acids (HAA-5)		4900568	Valley Ford Water Association	40		1
2950	Total Trihalomethanes (TTHMs)		4900568				1
2456	Haloacetic Acids (HAA-5)		4900570	Palomino Lakes Mutual Water Co.	340		1
2950	Total Trihalomethanes (TTHMs)		4900570				1
2456	Haloacetic Acids (HAA-5)		4900587	Brand Water Company	100		1
2950	Total Trihalomethanes (TTHMs)		4900587				1
2456	Haloacetic Acids (HAA-5)		4900620	Austin Acres Mutual Water Company	78		1
2950	Total Trihalomethanes (TTHMs)		4900620				1
2456	Haloacetic Acids (HAA-5)		4900702	Pacific Christian Academy	84		1
2950	Total Trihalomethanes (TTHMs)		4900702				1
2456	Haloacetic Acids (HAA-5)		4900707	Twin Hills School Dist-Twin Hills School	440		1
2950	Total Trihalomethanes (TTHMs)		4900707				1
2456	Haloacetic Acids (HAA-5)		4900710	Twin Hills School Dist-Apple Blossom Sch	600		1
2950	Total Trihalomethanes (TTHMs)		4900710				1
2456	Haloacetic Acids (HAA-5)		4900786	Rancho Santa Rosa MHP	175		1
2950	Total Trihalomethanes (TTHMs)		4900786				1
2456	Haloacetic Acids (HAA-5)		4900788	EI Crystal Mobile Home Park	130		1
2950	Total Trihalomethanes (TTHMs)		4900788				1
2456	Haloacetic Acids (HAA-5)		4900791	Western Mobile Home Park	225		1
2950	Total Trihalomethanes (TTHMs)		4900791				1
2456	Haloacetic Acids (HAA-5)		4900797	North Star Mobile Home Park	75		1
2950	Total Trihalomethanes (TTHMs)		4900797				1
2456	Haloacetic Acids (HAA-5)		4900799	EI Portal Mobile Estates	200		1
2950	Total Trihalomethanes (TTHMs)		4900799				1
2456	Haloacetic Acids (HAA-5)		4900800	Mark West Estates	60		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
2950	Total Trihalomethanes (TTHMs)		4900800				1
2456	Haloacetic Acids (HAA-5)		4900815	Days Inn	300		1
2950	Total Trihalomethanes (TTHMs)		4900815				1
2456	Haloacetic Acids (HAA-5)		4900907	Summerfield Waldorf School	400		1
2950	Total Trihalomethanes (TTHMs)		4900907				1
2456	Haloacetic Acids (HAA-5)		4900918	Sonoma Mission Apartments	100		1
2950	Total Trihalomethanes (TTHMs)		4900918				1
2456	Haloacetic Acids (HAA-5)		4901005	Todd Road Mutual Water Company	25		1
2950	Total Trihalomethanes (TTHMs)		4901005				1
2456	Haloacetic Acids (HAA-5)		4901257	Capital Lumber Company	50		1
2950	Total Trihalomethanes (TTHMs)		4901257				1
2456	Haloacetic Acids (HAA-5)		4910002	Cloverdale, City Of	8200		1
2950	Total Trihalomethanes (TTHMs)		4910002				1
2456	Haloacetic Acids (HAA-5)		4910006	Petaluma, City Of	55900		1
2456	Haloacetic Acids (HAA-5)		4910026	Odd Fellows Recreation Club	103		1
2950	Total Trihalomethanes (TTHMs)		4910026				1
2456	Haloacetic Acids (HAA-5)		5410007	Lsid - Tonyville	400		1
2950	Total Trihalomethanes (TTHMs)		5410007				1
2456	Haloacetic Acids (HAA-5)		5410033	Pratt Mutual Water Co	1600		1
2950	Total Trihalomethanes (TTHMs)		5410033				1
2456	Haloacetic Acids (HAA-5)		5410039	Plainview Mutual Water Company	1000		1
2950	Total Trihalomethanes (TTHMs)		5410039				1
2456	Haloacetic Acids (HAA-5)		5410502	SNP-Lodgepole	35		1
2950	Total Trihalomethanes (TTHMs)		5410502				1
2456	Haloacetic Acids (HAA-5)		5510023	Sonora Meadows Mutual Wtr Co	1435		1
2950	Total Trihalomethanes (TTHMs)		5510023				1
Counts / Totals			99		357156	0	170
Surface Water Treatment Rule (SWTR) and Enhanced Surface Water Treatment Rules (ESWTR)^(b) Violations							
0200	SWTR - treatment technique (41)	TT	310002	AWA, City Of Ione	4593	1	
0200	SWTR - treatment technique (41)	TT	310801	Preston Youth Correctional Facility	925	1	
0200	SWTR - treatment technique (41)	TT	410018	Del Oro Water Co.-Stirling Bluffs	300	1	
0200	SWTR - treatment technique (41)	TT	500013	Mountain Ranch Elementary	50	2	
0200	SWTR - treatment technique (41)	TT	1010044	Huron, City Of	6306	1	
0300	SWTR - treatment technique (41)	TT	1010051	Fresno Co Water Works Dist 18	891	1	
0200	SWTR - treatment technique (41)	TT	1200501	Alderpoint County Water	217	1	
0200	SWTR - treatment technique (41)	TT	1200544	Redcrest Water Works	95	5	
0200	SWTR - treatment technique (41)	TT	1200553	Weott C.S.D.	305	6	
0200	SWTR - treatment technique (41)	TT	1200566	Orleans Mutual Water Co.	85	1	
0200	SWTR - treatment technique (41)	TT	1200704	Azalea Glen	42	1	
0200	SWTR - treatment technique (41)	TT	1200706	Midway Rv Park	130	1	
0200	SWTR - treatment technique (41)	TT	1200796	Bishop Pine Lodge	25	1	
0200	SWTR - treatment technique (41)	TT	1200831	Larrupin Cafe	340	5	
0200	SWTR - treatment technique (41)	TT	1210308	Grizzly Creek Sp-State Parks	150	1	
0200	SWTR - treatment technique (41)	TT	1210312	Founders Grove-State Parks	200	1	
0200	SWTR - treatment technique (41)	TT	1210801	High Rock Conservation Camp	500	3	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	1310012	SCWC, Niland	1204	1	
0300	ESWTR - turbidity >1 NTU (43)	TT	2010300	Millerton SRA Meadow Tank Hill	2500	1	
0200	SWTR - treatment technique (41)	TT	2210905	Mcclure Boat Club, Inc.	64	1	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	2210905			2	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	2702322	Captain Cooper School WS	95	1	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	3710014	Oceanside, City Of	175085	1	
0300	SWTR - treatment technique (41)	TT	4100503	Butano Canyon Mutual	276	1	
0200	SWTR - treatment technique (41)	TT	4100512	Loma Mar Mutual	108	2	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	4100512			1	
0200	SWTR - treatment technique (41)	TT	4100533	Skylonda Mutual	431	4	
0200	SWTR - treatment technique (41)	TT	4110011	Coastside County Water District	16900	1	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	4410001	Big Basin Water Company	1600	1	
0200	SWTR - treatment technique (41)	TT	4410301	CSP - Big Basin State Park	3000	1	

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
0300	ESWTR - turbidity >1 NTU (43)	TT	4410301			1	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	4500110	Silverthorn Resort	175	2	
0200	SWTR - treatment technique (41)	TT	4900644	Bridgehaven Park	30	1	
0200	SWTR - treatment technique (41)	TT	4901106	Catholic Charities - CYO Camp	25	1	
0200	SWTR - treatment technique (41)	TT	5301012	Trinity River Lodge	74	1	
0200	SWTR - treatment technique (41)	TT	5301017	Rush Creek Mutual Water System	80	1	
0200	SWTR - treatment technique (41)	TT	5303005	Indian Creek Lodge	34	2	
0200	SWTR - treatment technique (41)	TT	5400506	No. Kaweah Mutual Water Co.	75	2	
0200	SWTR - treatment technique (41)	TT	5400637	Buckeye Tree Lodge	30	1	
0200	SWTR - treatment technique (41)	TT	5400747	Sierra Lodge	52	1	
0200	SWTR - treatment technique (41)	TT	5401085	Main Fork Bistro	100	1	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	5410011	Springville Pud	1500	3	
0200	SWTR - treatment technique (41)	TT	5601134	Elkins Ranch	150	1	
0200	SWTR - treatment technique (41)	TT	5601716	Usfs - Wheeler Gorge Campground	500	1	
Counts / Totals				41	219242	70	
0200	SWTR-filtered sys-monitoring (36)		500013	Mountain Ranch Elementary	50		1
0200	SWTR-unfiltered sys-monitoring (31)		1200517	Kimtu Meadows MWC	30		1
0200	SWTR-unfiltered sys-monitoring (31)		2701731	Brandon Creek MWS	41		1
0200	SWTR-unfiltered sys-monitoring (31)		2701945	Big Sur Campground WS	100		1
0200	SWTR-filtered sys-monitoring (36)		2702266	Coast Gallery WS	100		1
0200	SWTR-unfiltered sys-monitoring (31)		2702373	Phenegar Creek WS	48		1
0200	SWTR-filtered sys-monitoring (36)		3210001	Ivcsd-Greenville	3000		1
0200	SWTR-filtered sys-monitoring (36)		4100533	Skylonda Mutual	431		2
0200	SWTR-filtered sys-monitoring (36)		5400644	Sequoia Village Inn	35		1
0200	SWTR-filtered sys-monitoring (36)		5400968	Improvement Dist #1	480		1
0200	SWTR-filtered sys-monitoring (36)		5401071	Silver City Water Co.	128		2
0200	SWTR-filtered sys-monitoring (36)		5401085	Main Fork Bistro	100		1
0200	SWTR-filtered sys-monitoring (36)		5403061	River View Restaurant	50		2
0300	ESWTR-filtered sys-monitoring (38)		5510006	Mi-Wuk Village Mut Wtr Co	2200		1
Counts / Totals				14	6793		17
Lead and Copper Rule (LCR) Violations							
5000	LCR - Routine&followup monitoring		1000484	Fcsa #34/Brighton Crest	140		1
5000	LCR - Routine&followup monitoring		1010006	Fowler, City Of	4729		1
5000	LCR - Routine&followup monitoring		1010052	Sierra Cedars Csd	300		1
5000	LCR - Routine&followup monitoring		1010053	Shaver Lake Heights MWC	350		1
5000	LCR - Initial monitoring		1010055	Fresno Csa No. 47 (Quail Lake Estates)	1265		1
5000	LCR - Initial monitoring		2210515	NPS-Yosemite-El Portal	635		2
5000	LCR - Initial monitoring		2210925	Yosemite Westlake Mobile Estates	30		2
5000	LCR - Routine&followup monitoring		2410001	Atwater, City Of	26515		1
5000	LCR - Initial monitoring		3110031	Ward Well Water Company	375		1
5000	LCR - Routine&followup monitoring		3910015	City Of Lathrop	12427		1
5000	LCR - Routine&followup monitoring		4100517	Menlo College	1500		1
5000	LCR - Initial monitoring		4100537	Silva Wholesale Florist	30		1
5000	LCR - Initial monitoring		4900720	Mobile Home Estates	320		1
5000	LCR - Routine&followup monitoring		5000427	Covanta Stanislaus, Inc (Stan. Waste Ene	25		1
5000	LCR - Routine&followup monitoring		5510852	Baseline Conservation Camp	150		1
Counts / Totals				15	48791		17
Public Notification Violations							
3100	Total Coliform		3701478	Phoenix Academy	65		1
Counts / Totals				1	65		1
Consumer Confidence Report Violations							
7000	Consumer Confidence Report		3301011	Stone Creek Water Co.	50		1
7000	Consumer Confidence Report		3301018	Anza Pines Mobile Home Park	150		1
7000	Consumer Confidence Report		3301031	Banning Hts. Mutual Water Co.	350		1
7000	Consumer Confidence Report		3301040	Bermuda Palms Mobile Estates	300		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
7000	Consumer Confidence Report		3301045	Blythe Mobile Home Estates	30		1
7000	Consumer Confidence Report		3301046	Boe Del Heights Mutual Water	250		1
7000	Consumer Confidence Report		3301055	Village Of Child Help	100		1
7000	Consumer Confidence Report		3301058	Country Hills Rv Park	50		1
7000	Consumer Confidence Report		3301107	Carver Tract Mutual Water Company	300		1
7000	Consumer Confidence Report		3301114	Cherry Valley Water Company	200		1
7000	Consumer Confidence Report		3301115	Chiriaco Summit Water Dist.	400		1
7000	Consumer Confidence Report		3301147	Cvusd Facilities/M&O	50		1
7000	Consumer Confidence Report		3301149	Cvusd, Cv High School	2025		1
7000	Consumer Confidence Report		3301152	Cvusd, Oasis School	750		2
7000	Consumer Confidence Report		3301153	Cvusd, Westside School	975		1
7000	Consumer Confidence Report		3301155	College Of The Desert	4000		1
7000	Consumer Confidence Report		3301169	Murrieta Palms Mobile Home Park	150		1
7000	Consumer Confidence Report		3301180	Anza Mutual Water Company	200		1
7000	Consumer Confidence Report		3301209	Desert View Trailer Park	50		1
7000	Consumer Confidence Report		3301220	Double 'R' Trailer Park	90		1
7000	Consumer Confidence Report		3301247	Elms Mobile Park	80		1
7000	Consumer Confidence Report		3301267	Fisherman's Retreat	100		1
7000	Consumer Confidence Report		3301276	Fuller Mutual Water Company	100		1
7000	Consumer Confidence Report		3301280	Golden Era Productions	500		1
7000	Consumer Confidence Report		3301283	Glen Eden Sun Club	200		1
7000	Consumer Confidence Report		3301294	Glen Ivy Hot Springs	750		1
7000	Consumer Confidence Report		3301305	California Redi Date, Llc	27		1
7000	Consumer Confidence Report		3301308	Cottonwood School	300		1
7000	Consumer Confidence Report		3301309	Hamilton School	950		1
7000	Consumer Confidence Report		3301330	Indian Oaks Trailer Park	50		1
7000	Consumer Confidence Report		3301372	La Quinta Ridge Mobile Estates	350		1
7000	Consumer Confidence Report		3301380	Saint Anthony Trailer Park	250		1
7000	Consumer Confidence Report		3301381	Riverside County Service Area #51	350		1
7000	Consumer Confidence Report		3301385	Jojoba Hills Skp Resort, Inc.	154		1
7000	Consumer Confidence Report		3301388	Desert Dunes Golf Club Llc	90		1
7000	Consumer Confidence Report		3301445	Mountain View Mobile Home Park	200		1
7000	Consumer Confidence Report		3301476	Ibarra/Spates Families Water	45		1
7000	Consumer Confidence Report		3301491	Alpine Village	130		1
7000	Consumer Confidence Report		3301494	Palm Springs Aerial Tramway	1000		1
7000	Consumer Confidence Report		3301502	Paradise Valley MWC	30		1
7000	Consumer Confidence Report		3301511	Pinyon Crest Hoa	200		1
7000	Consumer Confidence Report		3301529	Ramona Water Company	250		1
7000	Consumer Confidence Report		3301535	Rancho Carrillo MWC	168		1
7000	Consumer Confidence Report		3301541	Reche Canyon MWC	150		1
7000	Consumer Confidence Report		3301577	Riverside County Service Area #62	700		1
7000	Consumer Confidence Report		3301588	Royal Carrizo Hoa	25		1
7000	Consumer Confidence Report		3301643	Spring Crest Water & Power	30		1
7000	Consumer Confidence Report		3301676	Thomas Mountain Water Company	75		1
7000	Consumer Confidence Report		3301682	Trails End Mutual Water Company	75		1
7000	Consumer Confidence Report		3301717	Valley View Trailer Park	100		1
7000	Consumer Confidence Report		3301734	Vista Dunes Mobilehome Park	180		1
7000	Consumer Confidence Report		3301735	Waller Tract Water District	200		1
7000	Consumer Confidence Report		3301746	Whispering Sands Mobile Home Park	37		1
7000	Consumer Confidence Report		3301755	Sunbird MHP, C/O Hawkeye Asset.Mgmt	258		1
7000	Consumer Confidence Report		3301756	Kkottongnae Retreat Camp	75		1
7000	Consumer Confidence Report		3301775	High Valleys Water District	300		1
7000	Consumer Confidence Report		3301803	Castro Trailer Park	180		1
7000	Consumer Confidence Report		3301850	Delara Rentals	25		1
7000	Consumer Confidence Report		3301863	Trinity - Anza	75		1
7000	Consumer Confidence Report		3301877	Block 77 Water Company	50		1
7000	Consumer Confidence Report		3301935	Coachella Valley Citrus - Dunlap	250		1
7000	Consumer Confidence Report		3301937	Mesquite Mutual Water Company	25		1
7000	Consumer Confidence Report		3301947	Morning Sky School	50		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
7000	Consumer Confidence Report		3301980	Desert Hills Premium Outlets	7250		1
7000	Consumer Confidence Report		3301990	Amezcu Garcia Water	250		1
7000	Consumer Confidence Report		3302008	Sanchez Water Well	50		1
7000	Consumer Confidence Report		3302009	Sam'S Fence	50		1
7000	Consumer Confidence Report		3302019	Bundy Canyon Christian School	400		1
7000	Consumer Confidence Report		3302045	Rancho San Miguel Labor Camp	25		1
7000	Consumer Confidence Report		3302065	Imperial Irrigation Dist. La Quinta	100		2
7000	Consumer Confidence Report		3302069	La Pena Housing Facility	100		1
7000	Consumer Confidence Report		3302079	Aida Aguirre & Dimicio Sampagan	50		1
7000	Consumer Confidence Report		3302081	Perez Water	30		1
7000	Consumer Confidence Report		3302088	Rancho La Mesa Rica	40		1
7000	Consumer Confidence Report		3302093	County Water Company	180		1
7000	Consumer Confidence Report		3303003	Galindo Housing Facility	50		1
7000	Consumer Confidence Report		3303026	Granite Construction Company	25		1
7000	Consumer Confidence Report		3303028	Shady Acres	45		1
7000	Consumer Confidence Report		3303035	Benjamin Hernandez Housing	50		1
7000	Consumer Confidence Report		3303048	Manuela Garcia Water	50		1
7000	Consumer Confidence Report		3303071	PGA Of So. Ca Golf Club Oak Vly	300		1
7000	Consumer Confidence Report		3303072	Goose Creek Golf Club	300		1
7000	Consumer Confidence Report		3303081	Idyllwild Arts Academy	275		1
7000	Consumer Confidence Report		3500556	Mission Farm R.V. Park	110		1
7000	Consumer Confidence Report		3700041	Barrett Lake Mobilehome Park	150		1
7000	Consumer Confidence Report		3700073	H & J Water Company	50		1
7000	Consumer Confidence Report		3700074	Cuyamaca Water District	200		1
7000	Consumer Confidence Report		3700277	Sunrise Estates Mutual Water Company	200		1
7000	Consumer Confidence Report		3700422	Stuart Water Company	250		1
7000	Consumer Confidence Report		3700922	Live Oak Springs Water & Power	200		2
7000	Consumer Confidence Report		3700923	Lake Morena Oak Shore Mw Co.	600		1
7000	Consumer Confidence Report		3700924	Lake Morena Views MWC	350		1
7000	Consumer Confidence Report		3700934	Pauma Valley Mutual Water Company	120		1
7000	Consumer Confidence Report		3700964	Swallows Sun Island Club	50		1
7000	Consumer Confidence Report		3701184	Butterfield Ranch	25		1
7000	Consumer Confidence Report		3701341	Butterfield Oaks Mobile Home Park	80		1
7000	Consumer Confidence Report		3701793	Twin Lakes Resort	200		1
7000	Consumer Confidence Report		3701988	Alpine Oaks Mobile Estates	125		1
7000	Consumer Confidence Report		3900511	Sjc Micke Grove Park	1000		1
7000	Consumer Confidence Report		3900555	Banta Mutual Water Co #1	81		1
7000	Consumer Confidence Report		3900556	Banta Mutual Water Co #2	42		1
7000	Consumer Confidence Report		3900557	Banta Mutual Water Co #3	75		1
7000	Consumer Confidence Report		3900559	Wine Country Apartments	40		1
7000	Consumer Confidence Report		3900561	Lodi Lake Mobile Home Park	104		1
7000	Consumer Confidence Report		3900568	Caribou Mobile Park PWS	180		1
7000	Consumer Confidence Report		3900579	Century Mobile Home Park	50		1
7000	Consumer Confidence Report		3900586	Sycamore Mobile Home Park	50		1
7000	Consumer Confidence Report		3900602	Tahama Village Mobile Home Prk	200		1
7000	Consumer Confidence Report		3900603	Leisure Manor	100		1
7000	Consumer Confidence Report		3900624	West Lane Mobile Home Park	160		1
7000	Consumer Confidence Report		3900649	Glenwood Mobile Home Park	100		1
7000	Consumer Confidence Report		3900661	Mapache Trailer Park	275		1
7000	Consumer Confidence Report		3900701	Currier Estates Water Corp	148		1
7000	Consumer Confidence Report		3900705	Finnlee'S Trailer Park	55		1
7000	Consumer Confidence Report		3900711	A & J Mobil Park	75		1
7000	Consumer Confidence Report		3900719	Mokelumne MeadoWS Trailer Park	55		1
7000	Consumer Confidence Report		3900721	Woodbridge Mobile Estates	110		1
7000	Consumer Confidence Report		3900726	Bentley Trailer Court	84		1
7000	Consumer Confidence Report		3900732	V & P Trailer Court	35		1
7000	Consumer Confidence Report		3900733	Country Club Vista	75		1
7000	Consumer Confidence Report		3900742	J-M Manufacturing Co Inc	100		1
7000	Consumer Confidence Report		3900755	Shady Rest Trailer Court	120		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
7000	Consumer Confidence Report		3900762	Riverside Mobile Home Park	55		1
7000	Consumer Confidence Report		3900763	Wimpy'S Marina	70		1
7000	Consumer Confidence Report		3900768	Paradise Point Marina	200		1
7000	Consumer Confidence Report		3900779	Sj County Mental Retardation Ctr	65		1
7000	Consumer Confidence Report		3900796	Btqc-Escalon	110		1
7000	Consumer Confidence Report		3900805	Morehead Park	300		1
7000	Consumer Confidence Report		3900825	Owens Brockway	280		1
7000	Consumer Confidence Report		3900835	Wayside Apartments	70		1
7000	Consumer Confidence Report		3900837	Lodi Homes	39		1
7000	Consumer Confidence Report		3900839	Mokelumne River School	204		1
7000	Consumer Confidence Report		3900846	Oak View Union Elementary Sch	350		1
7000	Consumer Confidence Report		3900848	Lodi Usd-Tokay Colony School	166		1
7000	Consumer Confidence Report		3900849	Lodi Usd-Live Oak School	100		1
7000	Consumer Confidence Report		3900850	Lodi Usd-Houston School*	405		1
7000	Consumer Confidence Report		3900907	Bel Air Mobile Estate	150		1
7000	Consumer Confidence Report		3900921	Cardoza Villa Corp	30		1
7000	Consumer Confidence Report		3900964	Sahara Mobile Court	300		1
7000	Consumer Confidence Report		3900972	Lodi Usd-Elkhorn School	200		1
7000	Consumer Confidence Report		3900983	Cherry Lane Trailer Park	100		1
7000	Consumer Confidence Report		3900991	La Torres Park	40		1
7000	Consumer Confidence Report		3900993	New Jerusalem School	210		1
7000	Consumer Confidence Report		3901032	Lodi Usd-Turner School	200		1
7000	Consumer Confidence Report		3901035	Lodi Usd-Henderson School	200		1
7000	Consumer Confidence Report		3901074	Twin Oaks Mobile Park	255		1
7000	Consumer Confidence Report		3901080	Alpine Packing Co	270		1
7000	Consumer Confidence Report		3901081	Mobile Villas Trailer Park	130		1
7000	Consumer Confidence Report		3901085	Lodi Usd-Davis School	630		1
7000	Consumer Confidence Report		3901109	Lodi Usd-Morada Middle School	435		1
7000	Consumer Confidence Report		3901121	Morada Shopping Center	100		1
7000	Consumer Confidence Report		3901167	Escalon Usd-Van Allen School	200		1
7000	Consumer Confidence Report		3901179	Lodi Wine & Business Center	61		1
7000	Consumer Confidence Report		3901181	Ameron International	100		1
7000	Consumer Confidence Report		3901194	Valimet Inc	60		1
7000	Consumer Confidence Report		3901196	Mainland Nursery Inc	50		1
7000	Consumer Confidence Report		3901197	Oak Ridge Winery, Llc	50		1
7000	Consumer Confidence Report		3901204	Diamond Pet Food	35		1
7000	Consumer Confidence Report		3901209	St Marys High School	950		1
7000	Consumer Confidence Report		3901215	San Juan Vista	100		1
7000	Consumer Confidence Report		3901245	California Fruit Processors	150		1
7000	Consumer Confidence Report		3901256	South San Joaquin Education Center	100		1
7000	Consumer Confidence Report		3901278	Color Spot, Lodi	30		1
7000	Consumer Confidence Report		3901281	First Baptist Church Of Stkn	200		1
7000	Consumer Confidence Report		3901286	Victorian Park Water Service	30		1
7000	Consumer Confidence Report		3901290	Fisher Nursery	50		1
7000	Consumer Confidence Report		3901309	Pacific Triple E Ltd	50		1
7000	Consumer Confidence Report		3901319	International Paper	40		1
7000	Consumer Confidence Report		3901347	Ripon Farm Service	26		1
7000	Consumer Confidence Report		3901349	Sierra Hills Packing	40		1
7000	Consumer Confidence Report		3901354	Pearce, Jeff H 39-40	30		1
7000	Consumer Confidence Report		3901368	The Scotts/Hyponex Co	50		1
7000	Consumer Confidence Report		3901374	Holt Union Esd-Holt School	100		1
7000	Consumer Confidence Report		3901375	Pilkington North America, Inc	25		1
7000	Consumer Confidence Report		3901378	San-I-Pak Inc	25		1
7000	Consumer Confidence Report		3901382	O-G Packing Co	25		1
7000	Consumer Confidence Report		3901387	Stockton Baptist Church	25		1
7000	Consumer Confidence Report		3901392	Enviroplex, Inc	25		1
7000	Consumer Confidence Report		3901405	Insulair, Inc	25		1
7000	Consumer Confidence Report		3901407	Burlington Northern Santa Fe	25		1
7000	Consumer Confidence Report		3901414	Wastequip Mclaughlin	25		1

Appendix B

State Of California 2005 Annual Compliance Report

Table B

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
7000	Consumer Confidence Report		3901421	Viejo Ltd	163		1
7000	Consumer Confidence Report		3901422	St Michael'S Water System	25		1
7000	Consumer Confidence Report		3901425	Morada Produce Water System	25		1
7000	Consumer Confidence Report		4000214	Baron Canyon Mutual Water Co.	25		1
7000	Consumer Confidence Report		4000216	Tank Farm Business Park	45		1
7000	Consumer Confidence Report		4000555	Guadalupe Cooling Company	35		1
7000	Consumer Confidence Report		4000563	Higuera Apartments	30		1
7000	Consumer Confidence Report		4000590	Water World Resorts-Lake Nacimiento	1000		1
7000	Consumer Confidence Report		4000598	Cuyama Lane Water Company	25		1
7000	Consumer Confidence Report		4000637	Country Hills Estates	60		1
7000	Consumer Confidence Report		4000665	Morro Bay Mutual Water Co	100		1
7000	Consumer Confidence Report		4000771	Rancho Nipomo Water Company	65		1
7000	Consumer Confidence Report		4210003	Guadalupe Water Department	5659		1
7000	Consumer Confidence Report		4900720	Mobile Home Estates	320		1
7000	Consumer Confidence Report		5010039	Western Hills Water District/Diablo Gran	3000		1
7000	Consumer Confidence Report		5200521	Antelope Creek MHP	90		1
7000	Consumer Confidence Report		5201137	Millstream Mobile Home Park	53		1
7000	Consumer Confidence Report		5400536	Kings River Estates	100		1
7000	Consumer Confidence Report		5400553	Traver Water Llc	500		1
7000	Consumer Confidence Report		5400816	Bedel Mutual Water Co.	155		1
7000	Consumer Confidence Report		5400886	Columbine School	160		1
7000	Consumer Confidence Report		5401006	Uc Davis-Vet School	40		1
7000	Consumer Confidence Report		5401082	Ventura Coastal Corp.	35		1
7000	Consumer Confidence Report		5401096	Sun Pacific-Woodlake	95		1
7000	Consumer Confidence Report		5402013	Sun Pacific-Exeter	200		1
7000	Consumer Confidence Report		5402027	Tulare County Road Yard #2	60		1
7000	Consumer Confidence Report		5402046	Sun Pacific-Tulare	225		1
7000	Consumer Confidence Report		5403031	Kraft - Tulare So.	250		1
7000	Consumer Confidence Report		5403074	Kraft - Tulare So.	130		1
Counts / Totals				210	56284		213

Footnotes:

a.....State MCL levels provided when MCL violations occurred. Treatment technique listed as "TT".

b.....Enhanced Surface Water Treatment Rules include Interim Enhanced SWTR (IESWTR) and the Long Term 1 Enhanced SWTR (LT1ESWTR)

APPENDIX C

Summary of Public Water System Violations (By Public Water System Number and County)

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant Code	Contaminant Name	MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
			Number	Name	Population		
Alpine County							
3100	Total Coliform - Non acute MCL	Absence	210003	Caltrans-Caples Lake Maintenance Station	30	1	
Amador County							
3100	Total Coliform - Non acute MCL	Absence	300022	Camp Winton	999	2	
3100	Total Coliform - Non acute MCL	Absence	300074	So. Silver Lake Homeowners	100	1	
0200	SWTR - treatment technique (41)	TT	310002	AWA, City Of Ione	4593	1	
2456	Haloacetic Acids (HAA-5)	0.060	310005	Pine Grove Comm Serv Dist	900	1	
2456	Haloacetic Acids (HAA-5)	0.060	310011	First Mace Meadow # 1	913	1	
2456	Haloacetic Acids (HAA-5)	0.060	310015	Rabb Park Community Ser. Dist.	353	1	
2456	Haloacetic Acids (HAA-5)	0.060	310018	First Mace Meadows Unit No. 2	221	1	
0200	SWTR - treatment technique (41)	TT	310801	Preston Youth Correctional Facility	925	1	
Butte County							
3100	Total Coliform - Non acute MCL	Absence	410008	Thermalito I.D.	8750	1	
0200	SWTR - treatment technique (41)	TT	410018	Del Oro Water Co.-Stirling Bluffs	300	1	
Calaveras County							
3100	Total Coliform - Non acute MCL	Absence	500009	United Parcel Service	75	1	
0200	SWTR - treatment technique (41)	TT	500013	Mountain Ranch Elementary	50	2	
3100	Total Coliform - Non acute MCL	Absence	500027	Lili Valley Water Co.	99	1	
3100	Total Coliform - Non acute MCL	Absence	500068	Dunrovin Mobile Home Village	99	1	
2456	Haloacetic Acids (HAA-5)	0.060	510006	C.C.W.D., Jenny Lind	9702	1	
Contra Costa County							
3100	Total Coliform - Non acute MCL	Absence	706007	Villa De Guadalupe	55	1	
3100	Total Coliform - Non acute MCL	Absence	706027	Orin Allen Youth Rehab Facility	600	1	
3100	Total Coliform - Non acute MCL	Absence	706101	Roddy Ranch Golf Course	75	1	
3100	Coliforms - Acute MCL	Absence	706105	D Anna Yacht Center	30	1	
3100	Coliforms - Acute MCL	Absence	706107	Carson Swim School	35	1	
3100	Coliforms - Acute MCL	Absence	707597	Sandy Point Mobile Home Park	94	1	
3100	Coliforms - Acute MCL	Absence	707603	Clayton Regency Water	305	1	
3100	Total Coliform - Non acute MCL	Absence	707625	Golden Eagle Refinery	600	2	
Del Norte County							
3100	Total Coliform - Non acute MCL	Absence	800605	West Park Properties	60	1	
3100	Total Coliform - Non acute MCL	Absence	800861	Reservation Ranch	50	1	
El Dorado County							
3100	Total Coliform - Non acute MCL	Absence	900112	Candlelight Village Water Syst	35	1	
3100	Coliforms - Acute MCL	Absence	900212	Lotus Park Water System	300	1	
3100	Total Coliform - Non acute MCL	Absence	900502	Pyramid Creek Trailhead	500	1	
3100	Total Coliform - Non acute MCL	Absence	900578	Pistante'S Coyote Den	32	1	
3100	Total Coliform - Non acute MCL	Absence	900655	Rockwater Apts.	50	1	
3100	Total Coliform - Non acute MCL	Absence	900660	Heavenly Ski Resort	1000	1	
3100	Total Coliform - Non acute MCL	Absence	901219	Capps Crossing Campground	25	1	
3100	Total Coliform - Non acute MCL	Absence	901249	Wench Creek Campground	250	1	
Fresno County							
3100	Total Coliform - Non acute MCL	Absence	1000041	Fcwwd #38/Sky Harbour	75	1	
3100	Total Coliform - Non acute MCL	Absence	1000105	Madison Elementary School	900	1	
3100	Total Coliform - Non acute MCL	Absence	1000108	Herndon-Barstow School	350	1	
3100	Total Coliform - Non acute MCL	Absence	1000136	Ufs/Trimmer Ranger Station	60	1	
3100	Total Coliform - Non acute MCL	Absence	1000204	American Union School	250	1	
3100	Total Coliform - Non acute MCL	Absence	1000206	Houghton-Kearney School	310	2	
3100	Total Coliform - Non acute MCL	Absence	1000207	Pershing High School	56	1	
3100	Total Coliform - Non acute MCL	Absence	1000220	Mckinley Elementary School	500	1	
3100	Total Coliform - Non acute MCL	Absence	1000276	Orange Center School	410	1	
3100	Total Coliform - Non acute MCL	Absence	1000304	Sierra Inn	25	2	
2931	Dibromochloropropane (DBCP)	0.0002	1000371	Central Unified/District Office	30	1	
3100	Total Coliform - Non acute MCL	Absence	1000445	Linda Vista Farms	40	1	
3100	Coliforms - Acute MCL	Absence	1000447	E&J Gallo Winery	50	1	
3100	Total Coliform - Non acute MCL	Absence	1000485	Ag Formulators	50	1	

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	1000537	Johnny Quik Food Store #161*	25	1	
3100	Total Coliform - Non acute MCL	Absence	1000553	Trinity Presbyterian Church	450	1	
3100	Total Coliform - Non acute MCL	Absence	1009020	Five Points Ranch	130	1	
3100	Total Coliform - Non acute MCL	Absence	1010026	Pinedale County Water District	8495	1	
3100	Total Coliform - Non acute MCL	Absence	1010028	Riverdale Public Utility District	3000	1	
3100	Total Coliform - Non acute MCL	Absence	1010034	San Joaquin, City Of	3510	1	
3100	Total Coliform - Non acute MCL	Absence	1010042	Malaga County Water District	900	1	
2950	Total Trihalomethanes (TTHMs)	0.080	1010044	Huron, City Of	6306	3	
0200	SWTR - treatment technique (41)	TT	1010044			1	
3100	Total Coliform - Non acute MCL	Absence	1010049	Biola Community Services Dist	1200	2	
2950	Total Trihalomethanes (TTHMs)	0.080	1010051	Fresno Co Water Works Dist 18	891	1	
0300	SWTR - treatment technique (41)	TT	1010051			1	
3100	Total Coliform - Non acute MCL	Absence	1010800	Miramonte Conservation Camp	105	1	
Humboldt County							
0200	SWTR - treatment technique (41)	TT	1200501	Alderpoint County Water	217	1	
3100	Total Coliform - Non acute MCL	Absence	1200541	Phillipsville C.S.D.	300	1	
0200	SWTR - treatment technique (41)	TT	1200544	Redcrest Water Works	95	5	
0200	SWTR - treatment technique (41)	TT	1200553	Weott C.S.D.	305	6	
0200	SWTR - treatment technique (41)	TT	1200566	Orleans Mutual Water Co.	85	1	
3100	Total Coliform - Non acute MCL	Absence	1200583	Forson Water Company	100	2	
0200	SWTR - treatment technique (41)	TT	1200704	Azalea Glen	42	1	
0200	SWTR - treatment technique (41)	TT	1200706	Midway Rv Park	130	1	
3100	Total Coliform - Non acute MCL	Absence	1200765	Redwood Trails Water System	300	1	
0200	SWTR - treatment technique (41)	TT	1200796	Bishop Pine Lodge	25	1	
0200	SWTR - treatment technique (41)	TT	1200831	Larrupin Cafe	340	5	
3100	Total Coliform - Non acute MCL	Absence	1206001	Redwood Empire G&Cc	300	1	
3100	Total Coliform - Non acute MCL	Absence	1210011	Redway C.S.D.	1500	1	
1010	Barium	1	1210023	Loleta C.S.D.	750	1	
0200	SWTR - treatment technique (41)	TT	1210308	Grizzly Creek Sp-State Parks	150	1	
0200	SWTR - treatment technique (41)	TT	1210312	Founders Grove-State Parks	200	1	
0200	SWTR - treatment technique (41)	TT	1210801	High Rock Conservation Camp	500	3	
Imperial County							
0300	ESWTR - turbidity >0.3 NTU (44)	TT	1310012	SCWC, Niland	1204	1	
Inyo County							
3100	Total Coliform - Non acute MCL	Absence	1400013	Bishop Creek Lodge	58	2	
3100	Total Coliform - Non acute MCL	Absence	1400069	Death Valley Junction	200	1	
3100	Total Coliform - Non acute MCL	Absence	1400072	North Lone Pine Water District	70	1	
3100	Total Coliform - Non acute MCL	Absence	1400098	Darwin Community Services District	60	1	
Kern County							
3100	Total Coliform - Non acute MCL	Absence	1500211	Stockdale Annex Mutual Water	260	3	
3100	Total Coliform - Non acute MCL	Absence	1500252	Kern Valley Mutual Water	100	2	
3100	Total Coliform - Non acute MCL	Absence	1500324	Wonder Acres Water System	83	5	
3100	Total Coliform - Non acute MCL	Absence	1500373	Seventh Standard Mutual	25	1	
3100	Total Coliform - Non acute MCL	Absence	1500436	Hungry Gulch Water System	30	1	
3100	Total Coliform - Non acute MCL	Absence	1500452	Riverdale Village	760	2	
3100	Total Coliform - Non acute MCL	Absence	1500461	Fountain Trailer Park Water	45	1	
3100	Total Coliform - Non acute MCL	Absence	1500478	Valley Estates Poa, Inc.	300	1	
3100	Total Coliform - Non acute MCL	Absence	1500493	EI Adobe Poa, Inc.	200	2	
3100	Total Coliform - Non acute MCL	Absence	1500508	Twin Pines Mobilehome Park	92	2	
3100	Total Coliform - Non acute MCL	Absence	1500516	Tut Brothers Farm #96	100	1	
3100	Total Coliform - Non acute MCL	Absence	1500518	Agbayani Village Water System	100	1	
4006	Uranium	0.030	1500561	Round Mountain Water Company	50	1	
3100	Total Coliform - Non acute MCL	Absence	1500561			1	
3100	Total Coliform - Non acute MCL	Absence	1500564	Hometown Water Association	29	1	
3100	Total Coliform - Non acute MCL	Absence	1500585	Oasis Property Owners Association	60	1	
3100	Total Coliform - Non acute MCL	Absence	1502017	Wheeler Farms Headquarters	25	1	

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant Code	Contaminant Name	MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
			Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	1502084	Frazier Woods Conference Center	250	1	
3100	Total Coliform - Non acute MCL	Absence	1502093	Harvest Steakhouse	70	1	
3100	Total Coliform - Non acute MCL	Absence	1502153	Lake Isabella Motel & Trailer Park	60	2	
3100	Total Coliform - Non acute MCL	Absence	1502162	Linns Court Mutual Water	60	1	
3100	Total Coliform - Non acute MCL	Absence	1502244	Semi Tropic School Water System	263	2	
3100	Total Coliform - Non acute MCL	Absence	1502249	Camp St Nicholas Water System	125	1	
3100	Total Coliform - Non acute MCL	Absence	1502307	Camp Condor	75	1	
3100	Total Coliform - Non acute MCL	Absence	1502325	Kern Co P&R-Tehachapi Mt Park Water	350	3	
3100	Total Coliform - Non acute MCL	Absence	1502418	Indian Wells Lodge	40	1	
3100	Total Coliform - Non acute MCL	Absence	1502422	Boron Rest Stop Water System	1000	2	
3100	Total Coliform - Non acute MCL	Absence	1502524	Camp Arev	300	1	
3100	Total Coliform - Non acute MCL	Absence	1502622	Gosford Road Water Company	42	1	
3100	Total Coliform - Non acute MCL	Absence	1502685	USFS - Lk Isabella Office Water System	40	1	
3100	Total Coliform - Non acute MCL	Absence	1502690	Dune Iii Mutual Water Company	70	1	
3100	Total Coliform - Non acute MCL	Absence	1502699	East Wilson Road Water Company	35	2	
3100	Total Coliform - Non acute MCL	Absence	1502826	B&J Land Company	225	1	
3100	Total Coliform - Non acute MCL	Absence	1503209	Superior Mutual Water Company	44	1	
3100	Total Coliform - Non acute MCL	Absence	1503211	DWR-Chrisman Pumping Plant/Wind Gap	130	2	
3100	Total Coliform - Non acute MCL	Absence	1503292	Weatherford U.S., L.P.	50	1	
2950	Total Trihalomethanes (TTHMs)	0.080	1503341	Tejon Ranch-Intst. 5 & Laval Rd.	500	2	
3100	Total Coliform - Non acute MCL	Absence	1503368	South Fork Middle School	204	1	
3100	Total Coliform - Non acute MCL	Absence	1503475	Western Acres Mutual Water Company	290	3	
3100	Total Coliform - Non acute MCL	Absence	1510004	Casa Loma Water Co, Inc.	600	1	
3100	Total Coliform - Non acute MCL	Absence	1510016	Rand Communities CWD - Randsburg	921	2	
3100	Total Coliform - Non acute MCL	Absence	1510023	Lake Of The Woods MWC	968	1	
1040	Nitrate as (NO ₃)	45	1510025	Stallion Springs C.S.D.	4300	1	
3100	Total Coliform - Non acute MCL	Absence	1510032	California City, City Of	11500	1	
2950	Total Trihalomethanes (TTHMs)	0.080	1510053	Antelope Valley E Kern Wtr Agy	0	1	
3100	Total Coliform - Non acute MCL	Absence	1510302	CSP - Tule Elk	100	2	
3100	Total Coliform - Non acute MCL	Absence	1510703	China Lake Naval Air Weapons Station	4500	2	
Kings County							
3100	Total Coliform - Non acute MCL	Absence	1600013	Lakeside Union School	294	1	
3100	Coliforms - Acute MCL	Absence	1600240	Rubalcava Water System	25	1	
2950	Total Trihalomethanes (TTHMs)	0.080	1610001	Armona Community Services Dist	3239	3	
3100	Total Coliform - Non acute MCL	Absence	1610002	Avenal, City Of	16205	2	
3100	Total Coliform - Non acute MCL	Absence	1610005	Lemoore, City Of	21076	1	
2950	Total Trihalomethanes (TTHMs)	0.080	1610700	Lemoore Naval Air Station	10661	1	
3100	Total Coliform - Non acute MCL	Absence	1610700			1	
Lake County							
2950	Total Trihalomethanes (TTHMs)	0.080	1700568	Riviera West Mutual Water Co.	500	1	
2456	Haloacetic Acids (HAA-5)	0.060	1700581	Cache Creek Mobile Home Park	250	2	
2456	Haloacetic Acids (HAA-5)	0.060	1700609	Lazy S Mobile Ranch	73	1	
3100	Total Coliform - Non acute MCL	Absence	1700715	Jack In The Box - Lakeport, Ca	21	1	
3100	Total Coliform - Non acute MCL	Absence	1700717	Legacy School	40	1	
2456	Haloacetic Acids (HAA-5)	0.060	1710011	Buckingham Park Water District	575	1	
Lassen County							
3100	Total Coliform - Non acute MCL	Absence	1800524	Lassen Mobile Home Park	62	1	
3100	Total Coliform - Non acute MCL	Absence	1800599	PNF-Laufman Admin. Site	25	1	
Los Angeles County							
3100	Total Coliform - Non acute MCL	Absence	1900009	Adams Ranch Mutual	300	1	
3100	Total Coliform - Non acute MCL	Absence	1900075	Bleich Flats Mutual	75	1	
3100	Total Coliform - Non acute MCL	Absence	1900100	Mettler Valley Mutual	200	1	
3100	Total Coliform - Non acute MCL	Absence	1900301	Shadow Acres Mutual Water Co	300	1	
3100	Total Coliform - Non acute MCL	Absence	1900868	Rivers End Trailer Park	25	1	
1040	Nitrate as (NO ₃)	45	1910244	Green Valley C.W.D.	1000	1	
Madera County							

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
0300	ESWTR - turbidity >1 NTU (43)	TT	2010300	Millerton SRA Meadow Tank Hill	2500	1	
Marin County							
3100	Total Coliform - Non acute MCL	Absence	2100545	Walker Creek Ranch Educational Center	100	1	
3100	Total Coliform - Non acute MCL	Absence	2100567	Bothin Youth Center	100	1	
2950	Total Trihalomethanes (TTHMs)	0.08	2110001	Inverness Public Utility Dist	1200	1	
2950	Total Trihalomethanes (TTHMs)	0.08	2110005			3	
2456	Haloacetic Acids (HAA-5)	0.06	2110005	Bolinas Community PUD	1500	4	
Mariposa County							
3100	Coliforms - Acute MCL	Absence	2202036	KOA Campground	250	1	
2456	Haloacetic Acids (HAA-5)	0.060	2210001	Mariposa Public Utility Dist	2000	2	
2950	Total Trihalomethanes (TTHMs)	0.080	2210001			2	
0200	SWTR - treatment technique (41)	TT	2210905	Mcclure Boat Club, Inc.	64	1	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	2210905			2	
3100	Total Coliform - Non acute MCL	Absence	2210933	BLM-Briceburg Water System	25	1	
Mendocino County							
3100	Total Coliform - Non acute MCL	Absence	2300503	Sutherland Waterworks	27	1	
2950	Total Trihalomethanes (TTHMs)	0.080	2300541	Heritage House Water System	50	1	
3100	Total Coliform - Non acute MCL	Absence	2300610	Caspar South Service Company	125	1	
2950	Total Trihalomethanes (TTHMs)	0.080	2300832	Hills Ranch Mutual Water Company	60	2	
3100	Total Coliform - Non acute MCL	Absence	2300845	Point Arena Lighthouse Keepers	50	1	
3100	Total Coliform - Non acute MCL	Absence	2300847	Whale Gulch Elementary School	45	1	
3100	Total Coliform - Non acute MCL	Absence	2300892	Covelo Mobile Home Park	30	1	
2456	Haloacetic Acids (HAA-5)	0.060	2310008	Redwood Valley County Water District	3969	2	
2950	Total Trihalomethanes (TTHMs)	0.080	2310008			2	
2456	Haloacetic Acids (HAA-5)	0.060	2310009	Brooktrails Township CSD	3700	1	
Merced County							
2950	Total Trihalomethanes (TTHMs)	0.080	2410950	DWR - San Luis Division O&M	150	2	
Modoc County							
3100	Total Coliform - Non acute MCL	Absence	2500538	MNF-Blue Lake CG	200	2	
3100	Total Coliform - Non acute MCL	Absence	2500811	Sulley'S Trailer Lodge	30	1	
3100	Total Coliform - Non acute MCL	Absence	2500911	I'Sot Well #3 & #15	215	1	
3100	Total Coliform - Non acute MCL	Absence	2510001	City Of Alturas	2982	1	
Monterey County							
3100	Total Coliform - Non acute MCL	Absence	2700509	Oak Manor WS	71	2	
3100	Total Coliform - Non acute MCL	Absence	2700523	Calera Canyon Heights HOA	39	3	
3100	Total Coliform - Non acute MCL	Absence	2700534	Colonial Oaks WC	198	2	
3100	Total Coliform - Non acute MCL	Absence	2700535	Jost Post Wa	60	1	
3100	Total Coliform - Non acute MCL	Absence	2700541	Del Monte Farms Rd WS #03	55	1	
3100	Total Coliform - Non acute MCL	Absence	2700547	Desmond Rd WS #03	55	2	
3100	Total Coliform - Non acute MCL	Absence	2700548	Dolan Rd MWC	120	1	
3100	Total Coliform - Non acute MCL	Absence	2700586	Gabilan WC	454	1	
3100	Total Coliform - Non acute MCL	Absence	2700589	Glenn Ave WS #01	78	1	
3100	Total Coliform - Non acute MCL	Absence	2700592	Harrison Rd WS #01	40	1	
3100	Total Coliform - Non acute MCL	Absence	2700598	Moss Landing School WS	575	1	
3100	Total Coliform - Non acute MCL	Absence	2700622	Outlook Wa	45	3	
3100	Total Coliform - Non acute MCL	Absence	2700663	Murphy Hill WS #02	60	1	
1038	Nitrate + Nitrite (Sum as N)	10	2700665	Oak Heights W & R Co Inc	105	1	
1040	Nitrate as (NO ₃)	45	2700665			2	
3100	Total Coliform - Non acute MCL	Absence	2700669	Orchard Ln WS #02	32	1	
3100	Total Coliform - Non acute MCL	Absence	2700682	Paradise Rd WS #09	250	1	
3100	Total Coliform - Non acute MCL	Absence	2700703	Calvary Church Inc WS	150	3	
3100	Total Coliform - Non acute MCL	Absence	2700713	Rolling Hills Rancho Wa	177	3	
3100	Total Coliform - Non acute MCL	Absence	2700731	Z Ranch MWC	62	3	
3100	Total Coliform - Non acute MCL	Absence	2700733	San Juan Rd WS #01	45	3	
3100	Total Coliform - Non acute MCL	Absence	2700740	San Miguel WS #03	48	1	
3100	Total Coliform - Non acute MCL	Absence	2700771	Springfield MWC	200	1	

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	2700775	Tierra Verde MWC	48	1	
3100	Total Coliform - Non acute MCL	Absence	2700792	Summerhill MHP WS	102	1	
3100	Total Coliform - Non acute MCL	Absence	2700799	Vista Del Toro WS	87	1	
3100	Total Coliform - Non acute MCL	Absence	2700838	Spring Canyon Wa	99	2	
1040	Nitrate as (NO ₃)	45	2700856	Altman Plants WS #01	45	1	
1040	Nitrate as (NO ₃)	45	2701036	Apple Ave WS #03	60	1	
2950	Total Trihalomethanes (TTHMs)	0.08	2701221	Washington School WS	250	1	
3100	Total Coliform - Non acute MCL	Absence	2701570	Los Carneros MWA	105	1	
3100	Total Coliform - Non acute MCL	Absence	2701647	Green Acres Wa	50	1	
1005	Arsenic	0.05	2701670	Langley/Valle Pacifico WS	81	1	
2950	Total Trihalomethanes (TTHMs)	0.08	2701670			1	
3100	Total Coliform - Non acute MCL	Absence	2701800	Tularcitos MWC	85	1	
3100	Total Coliform - Non acute MCL	Absence	2701814	Prunedale Plaza WS	90	2	
3100	Total Coliform - Non acute MCL	Absence	2701837	Meridian Rd WS #09	35	1	
3100	Total Coliform - Non acute MCL	Absence	2701870	Buena Vista WC	550	3	
1040	Nitrate as (NO ₃)	45	2701904	San Jerardo Coop WS	249	1	
3100	Total Coliform - Non acute MCL	Absence	2701918	Lomas Del Sol MWS	93	1	
3100	Total Coliform - Non acute MCL	Absence	2701926	Moro Rd WS #09	210	1	
3100	Total Coliform - Non acute MCL	Absence	2701959	Tierra Vista MWC	57	1	
3100	Total Coliform - Non acute MCL	Absence	2702007	Vierra Estates WS	164	1	
3100	Total Coliform - Non acute MCL	Absence	2702094	Blackie Rd WS #18	60	1	
3100	Total Coliform - Non acute MCL	Absence	2702121	Rosehart Industrial Park WS	75	2	
3100	Total Coliform - Non acute MCL	Absence	2702135	Foothill Wa	28	1	
3100	Total Coliform - Non acute MCL	Absence	2702140	Woodside Wa	78	2	
1025	Fluoride	2.0	2702148	Asoleado MWC	52	2	
3100	Total Coliform - Non acute MCL	Absence	2702163	Hilltop Mwa	100	1	
3100	Total Coliform - Non acute MCL	Absence	2702165	Orchard Ln WS #09	25	1	
3100	Total Coliform - Non acute MCL	Absence	2702202	Growers Company Inc WS	200	3	
3100	Total Coliform - Non acute MCL	Absence	2702209	Big Sur Bazaar WS	100	2	
3100	Total Coliform - Non acute MCL	Absence	2702226	Elkhorn Slough Reserve Water System	375	1	
3100	Total Coliform - Non acute MCL	Absence	2702254	Pacific Valley School WS	55	1	
3100	Total Coliform - Non acute MCL	Absence	2702315	Corral De Tierra Country Club WS	60	1	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	2702322	Captain Cooper School WS	95	1	
3100	Total Coliform - Non acute MCL	Absence	2702336	Monterey Bay Nursery WS	25	2	
3100	Total Coliform - Non acute MCL	Absence	2702368	Prunetree Shopping Center WS	200	1	
3100	Total Coliform - Non acute MCL	Absence	2702370	SPCA WS	50	1	
3100	Total Coliform - Non acute MCL	Absence	2702374	Countryside Estates MWC	73	1	
3100	Total Coliform - Non acute MCL	Absence	2702388	Royal Oak Place WS	60	1	
3100	Total Coliform - Non acute MCL	Absence	2702405	Jensen MHP WS	56	2	
3100	Total Coliform - Non acute MCL	Absence	2702431	Foothill Rd WS #01	25	5	
3100	Total Coliform - Non acute MCL	Absence	2702456	MRWPCA Treatment Plant WS	25	2	
1040	Nitrate as (NO ₃)	45	2702482	Color Spot Nursery WS #02	25	1	
3100	Total Coliform - Non acute MCL	Absence	2702482			2	
3100	Total Coliform - Non acute MCL	Absence	2702486	Bernardo Rd WS #02	25	2	
1005	Arsenic	0.05	2702550	Grange Hall WS	25	3	
3100	Total Coliform - Non acute MCL	Absence	2702551	Loma Vista Inn WS	25	1	
1040	Nitrate as (NO ₃)	45	2702566	Premium Fresh Farms Ws	25	1	
3100	Total Coliform - Non acute MCL	Absence	2702572	Alba WS	70	2	
1015	Cadmium	0.005	2702588	Canada Woods WC	216	1	
3100	Total Coliform - Non acute MCL	Absence	2710850	Correctional Training Facility - Soledad	7300	1	
Napa County							
2456	Haloacetic Acids (HAA-5)	0.060	2810001	Howell Mountain Mutual Water Company	1500	1	
2950	Total Trihalomethanes (TTHMs)	0.080	2810001			1	
2950	Total Trihalomethanes (TTHMs)	0.080	2810005	American Canyon, City Of	15300	1	
2456	Haloacetic Acids (HAA-5)	0.060	2810011	Pleasure Cove Resort	650	2	
2950	Total Trihalomethanes (TTHMs)	0.080	2810011			2	

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant Code	Contaminant Name	MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
			Number	Name	Population		
Nevada County							
3100	Total Coliform - Non acute MCL	Absence	2900529	Sunset Mobile Home Park Water System	60	2	
3100	Total Coliform - Non acute MCL	Absence	2900530	Rough & Ready MHP Water System	200	2	
3100	Total Coliform - Non acute MCL	Absence	2900531	Creekside Village Mobile Home Park	300	1	
3100	Total Coliform - Non acute MCL	Absence	2900567	Diamond Arrow Christian Conference Cpgd	250	1	
3100	Total Coliform - Non acute MCL	Absence	2900601	Bitney Springs Charter High School	125	1	
3100	Total Coliform - Non acute MCL	Absence	2900626	Streeter Plaza Industrial Park Water Sys	35	1	
3100	Total Coliform - Non acute MCL	Absence	2901994	Shady Creek Family Camp And Conf Center	250	1	
3100	Total Coliform - Non acute MCL	Absence	2902392	Penn Valley Shell Water System	100	1	
Orange County							
3100	Coliforms - Acute MCL	Absence	3000759	Canyon Rv Park	300	1	
Placer County							
3100	Total Coliform - Non acute MCL	Absence	3100011	Auburn Valley Community Service Dis	120	1	
3100	Total Coliform - Non acute MCL	Absence	3103259	Penryn Oaks Preschool	50	1	
3100	Total Coliform - Non acute MCL	Absence	3103279	Applegate Inn	34	1	
3100	Coliforms - Acute MCL	Absence	3103294	8200 Water System	1000	1	
3100	Total Coliform - Non acute MCL	Absence	3103664	Kaspian Point Picnic Area	25	1	
3100	Total Coliform - Non acute MCL	Absence	3107126	Weco Aerospace Systems Inc	45	1	
3100	Total Coliform - Non acute MCL	Absence	3110047	Talmont Resort Improvement District	300	2	
Plumas County							
3100	Coliforms - Acute MCL	Absence	3200188	Greenhorn Creek Services District	130	2	
Riverside County							
3100	Total Coliform - Non acute MCL	Absence	3301148	Coachella Valley Public Cemetary	25	2	
3100	Total Coliform - Non acute MCL	Absence	3301241	El Dorado Polo Club	50	1	
3100	Total Coliform - Non acute MCL	Absence	3301359	Kennedy Grocery	450	1	
3100	Total Coliform - Non acute MCL	Absence	3301529	Ramona Water Company	250	1	
3100	Total Coliform - Non acute MCL	Absence	3301990	Amecua Garcia Water	250	1	
3100	Total Coliform - Non acute MCL	Absence	3303026	Granite Construction Company	25	1	
2950	Total Trihalomethanes (TTHMs)	0.08	3310046	Farm Mutual W.C. (The)	2710	3	
3100	Total Coliform - Non acute MCL	Absence	3310800	California Rehabilitation Center - Norco	4800	1	
Sacramento County							
3100	Total Coliform - Non acute MCL	Absence	3400250	Pleasant Grove Elementary School	60	1	
3100	Total Coliform - Non acute MCL	Absence	3400280	Dry Creek Ranch Golf Club	100	1	
3100	Total Coliform - Non acute MCL	Absence	3410003	Golden State Water Co - Arden	6796	1	
3100	Total Coliform - Non acute MCL	Absence	3410015	Golden State Water Co. - Cordova	44657	1	
3100	Total Coliform - Non acute MCL	Absence	3500503	Harmony Hills Water System	60	1	
San Benito County							
1040	Nitrate as (NO ₃)	45	3500526	Arnold Park (O'Bannon's MHP)	28	4	
3100	Total Coliform - Non acute MCL	Absence	3500550	San Justo Mutual Water Company	160	2	
3100	Total Coliform - Non acute MCL	Absence	3500575	Springwood Estates MWC	45	3	
1005	Arsenic	0.05	3500810	Whispering Pines Retire Home (LSWS)	100	5	
3100	Total Coliform - Non acute MCL	Absence	3500810			1	
3100	Total Coliform - Non acute MCL	Absence	3500836	Betabel RV Resort	200	1	
3100	Total Coliform - Non acute MCL	Absence	3500921	Pietra Santa Winery	30	1	
3100	Total Coliform - Non acute MCL	Absence	3500923	Fairview Road Water System	40	1	
San Bernardino County							
3100	Total Coliform - Non acute MCL	Absence	3600172	Moly Corp Inc	172	1	
3100	Total Coliform - Non acute MCL	Absence	3600345	West End Mutual (Willow Wells)	63	1	
3100	Total Coliform - Non acute MCL	Absence	3600377	Echo Lodge	25	1	
3100	Total Coliform - Non acute MCL	Absence	3600452	Lucerne Valley Parks & Rec (CSA 29)	26	1	
1040	Nitrate as (NO ₃)	45	3600456	Prado Regional Park	25	1	
3100	Total Coliform - Non acute MCL	Absence	3601113	SS Hert Trucking , Inc	25	1	
3100	Total Coliform - Non acute MCL	Absence	3601139	Heart Bar Equestrian Group Camp Ground	100	1	
3100	Total Coliform - Non acute MCL	Absence	3610024	Hesperia WD	62099	1	
3100	Total Coliform - Non acute MCL	Absence	3610030	Mariana Ranchos CWD	1048	1	
San Diego County							

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant Code	Contaminant Name	MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
			Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	3700011	Stelzer County Park	25	1	
3100	Total Coliform - Non acute MCL	Absence	3700029	Descanso Fire Station	34	1	
3100	Total Coliform - Non acute MCL	Absence	3700073	H & J Water Company	50	1	
3100	Total Coliform - Non acute MCL	Absence	3700848	Alpine Springs Rv Park	200	1	
1040	Nitrate as (NO ₃)	45	3700912	YMCA Camp Marston/Raintree	300	5	
3100	Total Coliform - Non acute MCL	Absence	3700918	Rancho Santa Teresa MWC	74	1	
3100	Total Coliform - Non acute MCL	Absence	3700922	Live Oak Springs Water & Power	200	1	
3100	Total Coliform - Non acute MCL	Absence	3700923	Lake Morena Oak Shore MWC	600	1	
3100	Total Coliform - Non acute MCL	Absence	3700934	Pauma Valley Mutual Water Company	120	2	
3100	Total Coliform - Non acute MCL	Absence	3700962	Oakvale Park	100	1	
1040	Nitrate as (NO ₃)	45	3700963	Potrero Elementary School	250	1	
3100	Total Coliform - Non acute MCL	Absence	3701184	Butterfield Ranch	25	1	
3100	Total Coliform - Non acute MCL	Absence	3701213	Borrego Springs Park Community Services	35	1	
1040	Nitrate as (NO ₃)	45	3701241	Al Bahr Shrine Camp	150	1	
3100	Total Coliform - Non acute MCL	Absence	3701934	Pine Valley Bible Conference Center	38	1	
3100	Total Coliform - Non acute MCL	Absence	3702237	Banner Small Water Company	175	1	
3100	Total Coliform - Non acute MCL	Absence	3702754	Rancho Corrido Campground	300	1	
3100	Total Coliform - Non acute MCL	Absence	3705005	Boulevard Springs	25	1	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	3710014	Oceanside, City Of	175085	1	
3100	Total Coliform - Non acute MCL	Absence	3710036	Borrego WD	3500	1	
3100	Total Coliform - Non acute MCL	Absence	3710311	Cuyamaca Sp - Paso Picacho	8	1	
3100	Total Coliform - Non acute MCL	Absence	3710706	USN Sere Camp Warner Springs	12	1	
2950	Total Trihalomethanes (TTHMs)	0.080	3710707	Usn San Clemente Island	700	1	
2950	Total Trihalomethanes (TTHMs)	0.080	3710750	Nas North Island & Nab Coronado	4500	2	
San Joaquin County							
3100	Total Coliform - Non acute MCL	Absence	3900505	Farmington Water Company	100	3	
3100	Total Coliform - Non acute MCL	Absence	3900512	Morada Acres Water System	105	1	
3100	Total Coliform - Non acute MCL	Absence	3900523	Morada Manor Water System	109	1	
3100	Total Coliform - Non acute MCL	Absence	3900555	Banta Mutual Water Co #1	81	1	
3100	Total Coliform - Non acute MCL	Absence	3900557	Banta Mutual Water Co #3	75	3	
3100	Total Coliform - Non acute MCL	Absence	3900581	Sj County Housing Authority	500	2	
3100	Total Coliform - Non acute MCL	Absence	3900606	A-1 Winston'S Mobile Home Park	75	1	
3100	Total Coliform - Non acute MCL	Absence	3900666	King Island Marina PWS	1000	3	
3100	Total Coliform - Non acute MCL	Absence	3900682	Lockeford Mobile Home Park	100	2	
3100	Total Coliform - Non acute MCL	Absence	3900701	Currier Estates Water Corp	148	1	
3100	Total Coliform - Non acute MCL	Absence	3900705	Finnlee's Trailer Park	55	1	
3100	Total Coliform - Non acute MCL	Absence	3900713	Delta Island Elementary School	145	1	
3100	Coliforms - Acute MCL	Absence	3900748	Escalon Usd- Collegeville Sch	100	1	
3100	Total Coliform - Non acute MCL	Absence	3900755	Shady Rest Trailer Court	120	2	
3100	Total Coliform - Non acute MCL	Absence	3900797	Escalon Premier Brands	300	2	
3100	Total Coliform - Non acute MCL	Absence	3900798	Franzia Winery	250	3	
3100	Total Coliform - Non acute MCL	Absence	3900807	Whiskey Slough Harbor	200	1	
3100	Total Coliform - Non acute MCL	Absence	3900810	Jr Simplot Co	300	1	
3100	Total Coliform - Non acute MCL	Absence	3900831	Arbor Mobile Home Park	340	1	
3100	Total Coliform - Non acute MCL	Absence	3900839	Mokelumne River School	204	1	
3100	Total Coliform - Non acute MCL	Absence	3900888	South San Joaquin Irr Dist	55	1	
1040	Nitrate as (NO ₃)	45	3900983	Cherry Lane Trailer Park	100	1	
3100	Total Coliform - Non acute MCL	Absence	3901032	Lodi USD-Turner School	200	1	
3100	Total Coliform - Non acute MCL	Absence	3901085	Lodi USD-Davis School	630	1	
3100	Total Coliform - Non acute MCL	Absence	3901116	Navarra Water System	725	1	
3100	Total Coliform - Non acute MCL	Absence	3901121	Morada Shopping Center	100	1	
3100	Total Coliform - Non acute MCL	Absence	3901131	Bay Valley Estates PWS	50	1	
3100	Total Coliform - Non acute MCL	Absence	3901179	Lodi Wine & Business Center	61	1	
3100	Total Coliform - Non acute MCL	Absence	3901196	Mainland Nursery Inc	50	1	
3100	Total Coliform - Non acute MCL	Absence	3901197	Oak Ridge Winery, Llc	50	1	
3100	Total Coliform - Non acute MCL	Absence	3901198	Yosemite Inn - PWS	50	1	

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	3901209	St Marys High School	950	1	
3100	Total Coliform - Non acute MCL	Absence	3901249	3 B'S Truck & Auto Plaza	1000	2	
3100	Total Coliform - Non acute MCL	Absence	3901282	Woodbridge Winery	100	2	
3100	Total Coliform - Non acute MCL	Absence	3901296	Italian Athletic Club	50	1	
3100	Coliforms - Acute MCL	Absence	3901312	Turner Rd Vintners East	100	1	
3100	Total Coliform - Non acute MCL	Absence	3901315	Gaf Materials Co	30	4	
3100	Total Coliform - Non acute MCL	Absence	3901321	J B Golf	75	1	
3100	Total Coliform - Non acute MCL	Absence	3901324	Subway Sandwiches Water Sys	500	1	
3100	Total Coliform - Non acute MCL	Absence	3901330	Cecchini & Giovannoni Water System	50	2	
3100	Total Coliform - Non acute MCL	Absence	3901342	Zuckerman, Roscoe 39-316	30	1	
3100	Total Coliform - Non acute MCL	Absence	3901350	Boething Treeland Farms Inc	30	1	
3100	Total Coliform - Non acute MCL	Absence	3901360	Holiday Harbor Marina	100	2	
3100	Total Coliform - Non acute MCL	Absence	3901361	Backspin Golf Center	1000	2	
3100	Total Coliform - Non acute MCL	Absence	3901369	Basalite Concrete Products Llc	25	1	
3100	Total Coliform - Non acute MCL	Absence	3901371	Lockeford Springs Golf Course	25	2	
1040	Nitrate as (NO ₃)	45	3901377	French Camp Golf Course	25	1	
1040	Nitrate as (NO ₃)	45	3901382	O-G Packing Co	25	1	
3100	Total Coliform - Non acute MCL	Absence	3901388	P G & E-Turner Cut	25	2	
3100	Total Coliform - Non acute MCL	Absence	3901407	Burlington Northern Santa Fe	25	2	
3100	Total Coliform - Non acute MCL	Absence	3901411	Oakmoore Congre Of Jehovah Wit	100	1	
3100	Total Coliform - Non acute MCL	Absence	3901412	Korean Presbyterian Church	25	1	
3100	Total Coliform - Non acute MCL	Absence	3901414	Wastequip Mclaughlin	25	1	
3100	Total Coliform - Non acute MCL	Absence	3901423	Greif Bros Inc	25	1	
3100	Total Coliform - Non acute MCL	Absence	3901437	Lodi Elks Building Association	25	4	
3100	Total Coliform - Non acute MCL	Absence	3901442	Tarditi Rentals Water	25	2	
3100	Total Coliform - Non acute MCL	Absence	3901444	Giannecchini Farms Water System	25	1	
2950	Total Trihalomethanes (TTHMs)	0.080	3910027	Mountain House Community Services Dist	4290	1	
San Luis Obispo County							
3100	Total Coliform - Non acute MCL	Absence	4000221	Laetitia Vineyard & Winery Inc	25	2	
3100	Total Coliform - Non acute MCL	Absence	4000554	Green River Mutual Water Co.	350	3	
3100	Total Coliform - Non acute MCL	Absence	4000656	Santa Margarita Koa	50	2	
3100	Total Coliform - Non acute MCL	Absence	4010026	Nipomo Comm Services Dist	12626	1	
San Mateo County							
0300	SWTR - treatment technique (41)	TT	4100503	Butano Canyon Mutual	276	1	
0200	SWTR - treatment technique (41)	TT	4100512	Loma Mar Mutual	108	2	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	4100512			1	
0200	SWTR - treatment technique (41)	TT	4100533	Skylonda Mutual	431	4	
0200	SWTR - treatment technique (41)	TT	4110011	Coastside County Water District	16900	1	
Santa Barbara County							
3100	Total Coliform - Non acute MCL	Absence	4200514	Cuyama Mutual Water Co.	65	1	
3100	Total Coliform - Non acute MCL	Absence	4200556	Foster Road Mutual Water Co.	150	1	
3100	Total Coliform - Non acute MCL	Absence	4200612	Meadowlark Ranches Os	150	2	
3100	Total Coliform - Non acute MCL	Absence	4200618	Midland School Corporation Os	150	3	
3100	Total Coliform - Non acute MCL	Absence	4200644	San Marcos Baptist Camp	75	1	
3100	Total Coliform - Non acute MCL	Absence	4200647	Community Christian School	80	1	
3100	Total Coliform - Non acute MCL	Absence	4200666	Kinecta Federal Credit Union	40	2	
3100	Total Coliform - Non acute MCL	Absence	4200842	Saint Marie Mobile Home Park	250	2	
3100	Total Coliform - Non acute MCL	Absence	4200903	Sanford Winery	135	1	
3100	Total Coliform - Non acute MCL	Absence	4200925	Santa Barbara Pistachio Co	25	1	
3100	Total Coliform - Non acute MCL	Absence	4200939	Cotton Wood Winery	25	2	
2950	Total Trihalomethanes (TTHMs)	0.080	4210001	Carpinteria Valley Water District	18700	1	
Santa Clara County							
3100	Total Coliform - Non acute MCL	Absence	4300603	Oak Dell Park	100	1	
3100	Coliforms - Acute MCL	Absence	4300985	Ludewig's Christmas Tree Farm	25	1	
Santa Cruz County							
3100	Coliforms - Acute MCL	Absence	4400717	Kennolyn Camp	200	1	

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Coliforms - Acute MCL	Absence	4400750	Aptos High School	1925	1	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	4410001	Big Basin Water Company	1600	1	
3100	Total Coliform - Non acute MCL	Absence	4410016	Forest Lakes MWC	1141	1	
0200	SWTR - treatment technique (41)	TT	4410301	CSP - Big Basin State Park	3000	1	
0300	ESWTR - turbidity >1 NTU (43)	TT	4410301			1	
3100	Total Coliform - Non acute MCL	Absence	4410306	Csp - Rancho Del Oso	200	2	
Shasta County							
3100	Coliforms - Acute MCL	Absence	4500012	Cascade Racquet Club Mutual Water	100	1	
3100	Total Coliform - Non acute MCL	Absence	4500012			1	
3100	Total Coliform - Non acute MCL	Absence	4500017	Moose Camp	50	1	
3100	Total Coliform - Non acute MCL	Absence	4500053	Antlers Resort & Marina	109	1	
3100	Total Coliform - Non acute MCL	Absence	4500061	PG&E - Cassel Campground	80	2	
3100	Total Coliform - Non acute MCL	Absence	4500066	Clear Creek Mobile Park	110	1	
3100	Total Coliform - Non acute MCL	Absence	4500080	Doney Creek Lakeshore Villa RV Park	55	1	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	4500110	Silverthorn Resort	175	2	
3100	Coliforms - Acute MCL	Absence	4500143	Rooster'S Landing	65	1	
3100	Total Coliform - Non acute MCL	Absence	4500224	Basshole	30	1	
3100	Coliforms - Acute MCL	Absence	4500277	USFS Yolla Bolla Corp Yard	120	1	
3100	Total Coliform - Non acute MCL	Absence	4500277			1	
3100	Total Coliform - Non acute MCL	Absence	4500325	Lassen Pines Christian Conference Center	300	1	
3100	Total Coliform - Non acute MCL	Absence	4500327	Jgw RV Park	215	1	
3100	Total Coliform - Non acute MCL	Absence	4510003	Burney Water District	3000	1	
Sierra County							
3100	Total Coliform - Non acute MCL	Absence	4600055	Central Town WS	25	1	
3100	Total Coliform - Non acute MCL	Absence	4600068	TNF-Logger & Stampede Rc	1200	2	
Siskiyou County							
3100	Total Coliform - Non acute MCL	Absence	4700528	Siskiyou Co. Rolling Hills MWC	384	1	
3100	Total Coliform - Non acute MCL	Absence	4700541	Chateau Shasta Mobile Home & RV Park	55	1	
3100	Total Coliform - Non acute MCL	Absence	4700546	Cal Ore Trail Mobile Estates	74	1	
3100	Total Coliform - Non acute MCL	Absence	4700571	Mcbride Springs Campground	80	1	
3100	Total Coliform - Non acute MCL	Absence	4700575	Butte Valley Middle School	55	1	
3100	Total Coliform - Non acute MCL	Absence	4700577	Big Springs Union Elem. School	300	1	
3100	Total Coliform - Non acute MCL	Absence	4700621	Mid River RV Park	40	1	
3100	Total Coliform - Non acute MCL	Absence	4700626	Cove Mobile Villa	210	1	
3100	Total Coliform - Non acute MCL	Absence	4700686	Sun Mountain M.W.C.	55	1	
3100	Total Coliform - Non acute MCL	Absence	4700886	Blue Heron RV Park	25	1	
3100	Total Coliform - Non acute MCL	Absence	4710013	Lake Shastina C.S.D	2400	1	
Sonoma County							
0200	SWTR - treatment technique (41)	TT	4900644	Bridgehaven Park	30	1	
3100	Total Coliform - Non acute MCL	Absence	4900686	KOA - Cloverdale	25	1	
3100	Coliforms - Acute MCL	Absence	4900708	Gravenstein School District-Gravenstein	400	1	
3100	Total Coliform - Non acute MCL	Absence	4900720	Mobile Home Estates	320	1	
3100	Coliforms - Acute MCL	Absence	4900844	Francis Coppola Winery	80	1	
3100	Total Coliform - Non acute MCL	Absence	4900937	Joe's Place	25	1	
3100	Total Coliform - Non acute MCL	Absence	4901025	Johnson's Beach Resort	100	1	
3100	Total Coliform - Non acute MCL	Absence	4901093	Martinelli Ranch	30	2	
0200	SWTR - treatment technique (41)	TT	4901106	Catholic Charities - CYO Camp	25	1	
3100	Coliforms - Acute MCL	Absence	4901176	Sonoma Coast Villa	25	1	
3100	Coliforms - Acute MCL	Absence	4901197	Silver Oak Wine Cellars L.P.	25	3	
3100	Coliforms - Acute MCL	Absence	4901232	La Crema Winery	75	1	
3100	Total Coliform - Non acute MCL	Absence	4901251	Safari West	60	1	
3100	Coliforms - Acute MCL	Absence	4901254	Buena Vista Carneros Production Area	100	1	
3100	Total Coliform - Non acute MCL	Absence	4901284	Mauritson Family Winery	26	1	
3100	Coliforms - Acute MCL	Absence	4901298	Lynmar Winery	8	1	
Stanislaus County							
3100	Total Coliform - Non acute MCL	Absence	5000132	Valley Home School Texas	26	1	

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant Code	Contaminant Name	MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
			Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	5000167	Stan Cnty Honor Farm Water System/Laird	300	1	
1040	Nitrate as (NO ₃)	45	5000208	Neighborhood Church - Modesto Christian	220	1	
3100	Total Coliform - Non acute MCL	Absence	5000271	Buehner Water System - Weber Complex	100	1	
3100	Total Coliform - Non acute MCL	Absence	5000277	Valley Home School Pioneer	26	1	
3100	Total Coliform - Non acute MCL	Absence	5000433	Oid-Oakdale Rural Water System #1	1162	1	
3100	Total Coliform - Non acute MCL	Absence	5000465	Duarte Nursery Inc Water System	75	1	
3100	Total Coliform - Non acute MCL	Absence	5010007	Hillsview Homes	840	1	
3100	Total Coliform - Non acute MCL	Absence	5010014	Oakdale, City Of	17600	1	
2456	Haloacetic Acids (HAA-5)	0.06	5010039	Western Hills Water District/Diablo Grn	3000	4	
2950	Total Trihalomethanes (TTHMs)	0.08	5010039			4	
Sutter County							
3100	Total Coliform - Non acute MCL	Absence	5100109	Wildwood Mutual Water Company	255	2	
3100	Total Coliform - Non acute MCL	Absence	5100159	Verona Marina Launch & R.V.	50	1	
1040	Nitrate as (NO ₃)	45	5100176	Calvary Temple Assembly Of God	250	3	
1040	Nitrate as (NO ₃)	45	5100176			1	
3100	Total Coliform - Non acute MCL	Absence	5103007	Happy Time	40	2	
3100	Total Coliform - Non acute MCL	Absence	5103303	Tierra Buena Tavern	60	1	
3100	Total Coliform - Non acute MCL	Absence	5103335	Live Oak Child Care Center	50	1	
3100	Total Coliform - Non acute MCL	Absence	5105002	Rio La Paz Golf Course	1	1	
3100	Total Coliform - Non acute MCL	Absence	5110002	City Of Yuba City	50782	1	
Tehema County							
3100	Total Coliform - Non acute MCL	Absence	5200014	Wilson Acres Mutual Water	80	1	
3100	Total Coliform - Non acute MCL	Absence	5200529	Siemens Water Technologies Corp	330	1	
3100	Coliforms - Acute MCL	Absence	5200550	Orchard Mobile Home Park	56	1	
3100	Total Coliform - Non acute MCL	Absence	5200550			1	
3100	Total Coliform - Non acute MCL	Absence	5200560	Mira Monte Water Co.	100	1	
3100	Total Coliform - Non acute MCL	Absence	5200570	Surrey Village Water Co., Inc.	130	2	
3100	Total Coliform - Non acute MCL	Absence	5200575	Rancho Colorado WS	36	1	
3100	Coliforms - Acute MCL	Absence	5200579	Wilcox Oaks Golf Club	25	1	
3100	Coliforms - Acute MCL	Absence	5200581	Forest Inn, The	25	1	
3100	Total Coliform - Non acute MCL	Absence	5200581			1	
3100	Total Coliform - Non acute MCL	Absence	5200611	USDA-Lake Red Bluff Rec Area	25	1	
Trinity County							
3100	Total Coliform - Non acute MCL	Absence	5301012	Trinity River Lodge	74	1	
0200	SWTR - treatment technique (41)	TT	5301012			1	
0200	SWTR - treatment technique (41)	TT	5301017	Rush Creek Mutual Water System	80	1	
3100	Total Coliform - Non acute MCL	Absence	5301104	Trinity Lake Forest	50	2	
0200	SWTR - treatment technique (41)	TT	5303005	Indian Creek Lodge	34	2	
3100	Total Coliform - Non acute MCL	Absence	5304006	Big Bar Ranger Station	200	5	
Tulare County							
0200	SWTR - treatment technique (41)	TT	5400506	No. Kaweah Mutual Water Co.	75	2	
1040	Nitrate as (NO ₃)	45	5400507	Visalia - Fresno South KOA	150	1	
1040	Nitrate as (NO ₃)	45	5400541	Paramount Citrus	100	1	
3100	Total Coliform - Non acute MCL	Absence	5400541	Paramount Citrus	100	2	
1040	Nitrate as (NO ₃)	45	5400545	Norseman M.H.P.	70	1	
4006	Uranium	0.03	5400545			1	
1040	Nitrate as (NO ₃)	45	5400548	Kings Inn Motel	130	2	
3100	Total Coliform - Non acute MCL	Absence	5400548			1	
3100	Total Coliform - Non acute MCL	Absence	5400550	Seville Water Co.	400	1	
2931	Dibromochloropropane (DBCP)	0.0002	5400554	Western Sky M.H.P.	108	1	
1040	Nitrate as (NO ₃)	45	5400555	Citrus South Tule School	34	1	
2931	Dibromochloropropane (DBCP)	0.0002	5400558	Saucelito Elem School	75	1	
3100	Total Coliform - Non acute MCL	Absence	5400558			1	
1040	Nitrate as (NO ₃)	45	5400567	Tooleville Water Co.	300	1	
1040	Nitrate as (NO ₃)	45	5400616	Lemon Cove Water Co.	200	1	
3100	Total Coliform - Non acute MCL	Absence	5400631	Linnell Farm Labor Center	896	1	

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
2931	Dibromochloropropane (DBCP)	0.0002	5400634	Lovell School	60	1	
1040	Nitrate as (NO ₃)	45	5400636	Orosi High School	900	1	
0200	SWTR - treatment technique (41)	TT	5400637	Buckeye Tree Lodge	30	1	
3100	Total Coliform - Non acute MCL	Absence	5400638	Sierra School	40	2	
1040	Nitrate as (NO ₃)	45	5400651	Beverly-Grand Mutual Water	108	3	
3100	Total Coliform - Non acute MCL	Absence	5400651			1	
1040	Nitrate as (NO ₃)	45	5400660	Lake Success Mobile Lodge	20	2	
1040	Nitrate as (NO ₃)	45	5400663	Fairways Tract Mutual	250	1	
4006	Uranium	0.03	5400665	River Island Service Terr #1	700	1	
3100	Total Coliform - Non acute MCL	Absence	5400665			1	
1040	Nitrate as (NO ₃)	45	5400670	Triple R Mutual Water Co.	400	2	
3100	Total Coliform - Non acute MCL	Absence	5400699	Kaweah High School	110	3	
3100	Total Coliform - Non acute MCL	Absence	5400704	Three Rivers School	300	1	
3100	Total Coliform - Non acute MCL	Absence	5400709	Sequoia Union School	400	3	
1040	Nitrate as (NO ₃)	45	5400735	Rodriguez Labor Camp	110	1	
3100	Total Coliform - Non acute MCL	Absence	5400735			2	
0200	SWTR - treatment technique (41)	TT	5400747	Sierra Lodge	52	1	
3100	Total Coliform - Non acute MCL	Absence	5400762	Giumarra Vineyards 3 & 4	125	1	
1040	Nitrate as (NO ₃)	45	5400795	Waukena Elementary School	230	3	
3100	Total Coliform - Non acute MCL	Absence	5400797	Tulare Co Correctional Center	300	3	
1040	Nitrate as (NO ₃)	45	5400805	Souls Mutual Water Co.	100	3	
3100	Total Coliform - Non acute MCL	Absence	5400850	Packwood School	30	1	
1040	Nitrate as (NO ₃)	45	5400918	Open Country Flea Mart	300	1	
1040	Nitrate as (NO ₃)	45	5400919	Buena Vista School	130	3	
3100	Total Coliform - Non acute MCL	Absence	5400951	Mooney Grove Park	200	2	
3100	Total Coliform - Non acute MCL	Absence	5401003	East Orosi C.S.D.	106	1	
1040	Nitrate as (NO ₃)	45	5401004	Styrotek	36	2	
3100	Total Coliform - Non acute MCL	Absence	5401026	Deer Meadow Mutual	75	1	
3100	Total Coliform - Non acute MCL	Absence	5401033	A & P Growers	100	2	
3100	Total Coliform - Non acute MCL	Absence	5401040	Moore Wallace Incorporated	208	1	
1040	Nitrate as (NO ₃)	45	5401053	Charlie's	150	3	
0200	SWTR - treatment technique (41)	TT	5401085	Main Fork Bistro	100	1	
3100	Total Coliform - Non acute MCL	Absence	5401093	Doyle Springs Assn.	300	1	
1040	Nitrate as (NO ₃)	45	5401096	Sun Pacific-Woodlake	95	1	
1040	Nitrate as (NO ₃)	45	5402013	Sun Pacific-Exeter	200	1	
1040	Nitrate as (NO ₃)	45	5402022	Traver Valley Farms - Texaco	25	1	
3100	Coliforms - Acute MCL	Absence	5402022			1	
3100	Total Coliform - Non acute MCL	Absence	5402022			2	
1040	Nitrate as (NO ₃)	45	5402024	Kings River Market	25	1	
1040	Nitrate as (NO ₃)	45	5402025	Lakeside Minnit Mart	25	1	
3100	Total Coliform - Non acute MCL	Absence	5402039	Seville Market	100	1	
1040	Nitrate as (NO ₃)	45	5402041	Penny Wise Motel	25	1	
1040	Nitrate as (NO ₃)	45	5402043	Monson Market	25	1	
1040	Nitrate as (NO ₃)	45	5402046	Wii Liquidation Inc	225	1	
1040	Nitrate as (NO ₃)	45	5402047	Gleanings For The Hungry	31	1	
3100	Total Coliform - Non acute MCL	Absence	5402048	River Island Service Terr #2	87	2	
1040	Nitrate as (NO ₃)	45	5402056	Peoples Grocery	25	2	
1040	Nitrate as (NO ₃)	45	5403010	Golden State Citrus Packers	75	1	
3100	Total Coliform - Non acute MCL	Absence	5403011	Rj'S Super Stop & Liquor	25	1	
1040	Nitrate as (NO ₃)	45	5403013	Prince Mart	25	1	
3100	Total Coliform - Non acute MCL	Absence	5403031	Sun Pacific-Tulare	250	1	
3100	Total Coliform - Non acute MCL	Absence	5403032	Monrovia Nursery - Nursery	400	1	
1040	Nitrate as (NO ₃)	45	5403043	Yettem Water System	350	1	
1040	Nitrate as (NO ₃)	45	5403046	Tri County Citrus	80	1	
3100	Total Coliform - Non acute MCL	Absence	5403051	Friends Rv Park	24	1	
1040	Nitrate as (NO ₃)	45	5403076	Central Cal Tristeza Erad	25	4	

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	5403086	Martella Livestock Auction	50	1	
1040	Nitrate as (NO ₃)	45	5403106	Lo Bue Bros.	99	1	
1040	Nitrate as (NO ₃)	45	5403110	Sierra Mutual Water Co.	39	2	
3100	Total Coliform - Non acute MCL	Absence	5403113	South Fork Estates Mutual Water Co	76	2	
3100	Total Coliform - Non acute MCL	Absence	5403114	Foster Farms - Traver Feedmill	40	1	
3100	Total Coliform - Non acute MCL	Absence	5410002	Dinuba, City Of	18369	2	
2456	Haloacetic Acids (HAA-5)	0.06	5410007	LSID - Tonyville	400	3	
2950	Total Trihalomethanes (TTHMs)	0.08	5410007			3	
0300	ESWTR - turbidity >0.3 NTU (44)	TT	5410011	Springville Pud	1500	3	
3100	Total Coliform - Non acute MCL	Absence	5410019	Ivanhoe Public Utility Dist	4474	2	
3100	Total Coliform - Non acute MCL	Absence	5410021	Earlimart PUD	7100	4	
2456	Haloacetic Acids (HAA-5)	0.06	5410037	LSID-Page Moore System	550	4	
2950	Total Trihalomethanes (TTHMs)	0.08	5410037			4	
2456	Haloacetic Acids (HAA-5)	0.06	5410038	Terra Bella Irrigation District - Tbt	2340	2	
2456	Haloacetic Acids (HAA-5)	0.06	5410503	SNP-Wolverton	2900	4	
2950	Total Trihalomethanes (TTHMs)	0.08	5410503			4	
Tuolumne County							
3100	Coliforms - Acute MCL	Absence	5500102	Red Barn	25	1	
3100	Coliforms - Acute MCL	Absence	5500132	Marble Quarry Resort	250	1	
3100	Total Coliform - Non acute MCL	Absence	5500152	Curtis Creek Elementary School	595	1	
3100	Total Coliform - Non acute MCL	Absence	5500258	Christian Heights	50	1	
3100	Total Coliform - Non acute MCL	Absence	5500259	Hatler Industrial Park	26	1	
3100	Coliforms - Acute MCL	Absence	5500363	Mdwc:Wards Ferry Ranches	45	2	
2456	Haloacetic Acids (HAA-5)	0.06	5510007	Conlin Strawberry Water Company	165	2	
2950	Total Trihalomethanes (TTHMs)	0.08	5510008	Lake Don Pedro C S D	3200	1	
2456	Haloacetic Acids (HAA-5)	0.06	5510009	Groveland Community Serv Dist	3400	1	
2950	Total Trihalomethanes (TTHMs)	0.08	5510009			1	
3100	Total Coliform - Non acute MCL	Absence	5510016	Odd Fellows Sierra Rec Assoc	200	1	
2920	Total Organic Carbon (TOC)	TT	5510852	Baseline Conservation Camp	150	2	
Ventura County							
0200	SWTR - treatment technique (41)	TT	5601134	Elkins Ranch	150	1	
3100	Total Coliform - Non acute MCL	Absence	5601716	USFS - Wheeler Gorge Campground	500	1	
0200	SWTR - treatment technique (41)	TT	5601716			1	
3100	Total Coliform - Non acute MCL	Absence	5610005	Meiners Oaks Cwd	4000	1	
3100	Total Coliform - Non acute MCL	Absence	5610014	Golden State Water Company - Ojai	8200	1	
2950	Total Trihalomethanes (TTHMs)	0.08	5610702	U.S.N., San Nicolas Island	350	1	
Yolo County							
3100	Total Coliform - Non acute MCL	Absence	5700509	Clarksburg Elem School	400	2	
3100	Total Coliform - Non acute MCL	Absence	5700532	Yolo Bypass Wildlife Area	25	2	
3100	Total Coliform - Non acute MCL	Absence	5700537	Campbell Soup Supply Co Llc - Water	40	2	
3100	Total Coliform - Non acute MCL	Absence	5700543	Yolo Fruit Stand	30	2	
3100	Total Coliform - Non acute MCL	Absence	5700551	Bill & Kathy'S	550	1	
3100	Total Coliform - Non acute MCL	Absence	5700552	Pilot Travel Center #168 - Water	700	1	
3100	Total Coliform - Non acute MCL	Absence	5700554	Campers Inn - Rv & Golf Course	120	1	
3100	Total Coliform - Non acute MCL	Absence	5700560	Dunnigan 76 Gas & Mini - Water	50	2	
3100	Total Coliform - Non acute MCL	Absence	5700565	Rose Valley Group Inc	25	2	
3100	Total Coliform - Non acute MCL	Absence	5700568	River Garden Farms #1	26	1	
3100	Total Coliform - Non acute MCL	Absence	5700584	Reynolds Resorts - Sacramento Llc	300	1	
3100	Total Coliform - Non acute MCL	Absence	5700588	Sacramento Yacht Club	25	1	
3100	Total Coliform - Non acute MCL	Absence	5700600	Fast & Easy Mart #54 - Water	100	1	
3100	Total Coliform - Non acute MCL	Absence	5700608	Canyon Creek Resort	200	1	
3100	Total Coliform - Non acute MCL	Absence	5700636	Pacific Coast Producers	1100	1	
3100	Total Coliform - Non acute MCL	Absence	5700707	Rolling Acres Wat Mutual	33	2	
3100	Total Coliform - Non acute MCL	Absence	5700713	Cache Creek Canyon-Middle Site	100	3	
3100	Total Coliform - Non acute MCL	Absence	5700729	Reyes, Javier Ceja	75	1	
3100	Total Coliform - Non acute MCL	Absence	5700741	United Petroleum Truck Stop	200	2	

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform - Non acute MCL	Absence	5700752	Chevron #92597 - Woodland	71	4	
1040	Nitrate as (NO ₃)	45	5700757	Yolo Bowmens Club	50	1	
3100	Total Coliform - Non acute MCL	Absence	5700767	Woodland Aviation - Wldd Airport	32	1	
1040	Nitrate as (NO ₃)	45	5700817	Jehovah'S Witnesses - Kingdom Hall	245	1	
1040	Nitrate as (NO ₃)	45	5700827	Pioneer Hi-Bred International	25	1	
3100	Total Coliform - Non acute MCL	Absence	5700828	R H Phillips Winery - Water	30	2	
3100	Total Coliform - Non acute MCL	Absence	5710001	City Of Davis	67740	1	
3100	Total Coliform - Non acute MCL	Absence	5710007	Esparto C.S.D.	1858	4	
3100	Total Coliform - Non acute MCL	Absence	5710008	Valhalla Mobile Home Park	400	3	
Yuba County							
3100	Total Coliform - Non acute MCL	Absence	5800001	Browns Valley One Stop	50	1	
3100	Total Coliform - Non acute MCL	Absence	5800002	North Yuba Little League	30	2	
3100	Total Coliform - Non acute MCL	Absence	5800004	Mariani Packing Company Inc.	65	1	
3100	Total Coliform - Non acute MCL	Absence	5800201	Prune Tree	25	1	
3100	Total Coliform - Non acute MCL	Absence	5800805	Lake Francis Mutual Water	60	1	
3100	Total Coliform - Non acute MCL	Absence	5800820	River Highlands Com.Serv.Dist	100	1	
3100	Total Coliform - Non acute MCL	Absence	5800823	Country Air Mobile Home Park	70	1	
3100	Total Coliform - Non acute MCL	Absence	5800824	Country Village Mobile Hm Prk	30	1	
3100	Total Coliform - Non acute MCL	Absence	5800826	Quail Ridge	60	3	
3100	Total Coliform - Non acute MCL	Absence	5800844	Browns Valley School	135	2	
3100	Total Coliform - Non acute MCL	Absence	5800845	Dobbins School	149	1	
3100	Total Coliform - Non acute MCL	Absence	5800851	Feather River Manor	35	1	
3100	Total Coliform - Non acute MCL	Absence	5800853	Sycamore Ranch RV Park	40	1	
3100	Total Coliform - Non acute MCL	Absence	5800856	Christopher Sims Rentals	30	1	
Counts / Totals				608	819314	921	
Amador County							
3100	Total Coliform-routine monitoring		300007	Stockton Municipal Family Camp	999		1
3100	Total Coliform-routine monitoring		300028	Amador Harvest Inn	40		1
3100	Total Coliform-routine monitoring		300036	Bear River Lake Resort	250		1
3100	Total Coliform-routine monitoring		300043	O. K. Corral	200		2
3100	Total Coliform-routine monitoring		300055	Sunset West Water Company	150		4
3100	Total Coliform-routine monitoring		300062	Hope Foundation/Moriah Heights	300		2
3100	Total Coliform-followup monitoring		300062				1
3100	Total Coliform-routine monitoring		300077	Spinetta Vineyards - Inactive	25		1
3100	Total Coliform-routine monitoring		300518	Oro Madre Moose Lodge 1761	300		1
3100	Total Coliform-routine monitoring		300627	Amador Station	20		1
3100	Total Coliform-routine monitoring		300649	Rancho Cicada	50		1
2456	Haloacetic Acids (HAA-5)		310004	Plymouth, City Of	941		1
2950	Total Trihalomethanes (TTHMs)		310004				1
2456	Haloacetic Acids (HAA-5)		310006	River Pines Pud	498		1
2950	Total Trihalomethanes (TTHMs)		310006				1
3100	Total Coliform-routine monitoring		310013	Sunset Heights C.S.D.	103		1
Calaveras County							
3100	Total Coliform-routine monitoring		500009	United Parcel Service	75		1
0200	SWTR-filtered sys-monitoring (36)		500013	Mountain Ranch Elementary	50		1
3100	Total Coliform-routine monitoring		500021	Sky High Ranch HOA	94		1
3100	Total Coliform-routine monitoring		500026	Camp Lodestar	150		1
3100	Total Coliform-routine monitoring		500037	Tamarack Lodge	50		1
2950	Total Trihalomethanes (TTHMs)		500091	Rite Of Passage/Sierra Ridge	150		1
3100	Total Coliform-followup monitoring		500096	Valley Springs Driving Range	100		1
3100	Total Coliform-routine monitoring		500097	Cusd District Office	100		1
Contra Costa County							
3100	Total Coliform-routine monitoring		706015	Docs Marina	35		1
3100	Total Coliform-routine monitoring		706018	Cruiser Haven Marina	75		2
3100	Total Coliform-followup monitoring		706059	Blue Star Gas Mart	120		2
3100	Total Coliform-routine monitoring		706101	Roddy Ranch Golf Course	75		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-followup monitoring		706107	Carson Swim School	35		1
3100	Total Coliform-followup monitoring		707515	Church Of Jesus Christ	200		1
3100	Total Coliform-followup monitoring		707521	Byron Corners	90		1
3100	Total Coliform-routine monitoring		707542	Concord Mt Diablo Trailride Assoc.	14		2
3100	Total Coliform-followup monitoring		707580	Baldocchi Water System	90		1
3100	Total Coliform-followup monitoring		707581	Riverview Marina SWS	40		1
3100	Total Coliform-routine monitoring		707585	Moraga Heights Mutual Water	60		1
3100	Total Coliform-followup monitoring		707591	Blue Tip Trailer Park Water	35		1
3100	Total Coliform-routine monitoring		707623	Mc Cosker Ranch	90		1
3100	Total Coliform-routine monitoring		707630	Willowest Marina WS	30		1
3100	Total Coliform-followup monitoring		708004	Pacific Ranch	45		1
3100	Total Coliform-routine monitoring		708006	Cecchini Water	35		2
2456	Haloacetic Acids (HAA-5)		710004	City Of Brentwood	21000		1
2950	Total Trihalomethanes (TTHMs)		710004				1
Del Norte County							
3100	Total Coliform-routine monitoring		800548	Klamath C.S.D.	100		1
3100	Total Coliform-followup monitoring		800552	Northcrest Trailer City	250		1
3100	Total Coliform-followup monitoring		800700	Las Palmas Mobile Home Park	120		1
3100	Total Coliform-followup monitoring		800800	Pine Grove Trailer Park	100		1
El Dorado County							
3100	Total Coliform-routine monitoring		900104	Pioneer Bible Church Water System	250		2
3100	Total Coliform-routine monitoring		900106	Indian Diggings School	45		2
3100	Total Coliform-routine monitoring		900107	Gray's Mart & Gas (Health)	100		1
3100	Total Coliform-routine monitoring		900118	Pearl's Little Place - Restaur	50		1
3100	Total Coliform-routine monitoring		900206	Camp Chiquita Campground (Health)	50		1
3100	Total Coliform-routine monitoring		900304	Silverfork School (Health)	25		4
3100	Total Coliform-routine monitoring		900311	Mountain Camp li	140		1
3100	Total Coliform-routine monitoring		900423	Whitewater Voyages	100		2
3100	Total Coliform-routine monitoring		900502	Pyramid Creek Trailhead	500		2
3100	Total Coliform-routine monitoring		900508	Sierra Nevada Building	150		1
3100	Total Coliform-routine monitoring		900517	Lone Pine Lodge	40		1
3100	Total Coliform-routine monitoring		900519	Crystal Range Motel	30		1
3100	Total Coliform-routine monitoring		900536	Tahoe Chalet Inn .	100		1
3100	Total Coliform-routine monitoring		900542	Bayview Campground	100		1
3100	Total Coliform-routine monitoring		900555	Matterhorn Motel	50		1
3100	Total Coliform-routine monitoring		900557	Emerald Pines Resort Cabins	25		1
3100	Total Coliform-routine monitoring		900576	Alpine Inn & Spa	25		1
3100	Total Coliform-routine monitoring		900578	Pistante'S Coyote Den	32		1
3100	Total Coliform-routine monitoring		900582	Alpenrose Inn	40		1
3100	Total Coliform-routine monitoring		900585	Sky Lake Lodge	25		1
3100	Total Coliform-routine monitoring		900646	Al Tahoe Elem/Stms (Water Sys)	1300		1
3100	Total Coliform-routine monitoring		900648	Tahoe Valley Elementary School	700		1
3100	Total Coliform-routine monitoring		900649	South Shore Recreation Area	3300		1
3100	Total Coliform-routine monitoring		900650	Echo Lake Camp	150		1
3100	Total Coliform-routine monitoring		900651	Sierra Pines Camp	25		1
3100	Total Coliform-routine monitoring		900654	Baldwin Beach	200		2
3100	Total Coliform-routine monitoring		900665	Heavenly Valley Gondola	500		1
3100	Total Coliform-routine monitoring		901219	Capps Crossing Campground	25		1
3100	Total Coliform-routine monitoring		901222	China Flat Campground	75		1
3100	Total Coliform-routine monitoring		901239	Sand Flat Campground	75		2
3100	Total Coliform-routine monitoring		901243	Silverfork Campground	75		1
3100	Total Coliform-routine monitoring		901244	Stumpy MeadoWS Campground	100		2
Fresno County							
3100	Total Coliform-routine monitoring		1000247	Sherwood Forest MHP	100		3
3100	Total Coliform-followup monitoring		1000365	Ponderosa Trailer Park	156		1
3100	Total Coliform-routine monitoring		1000482	Wolf Lakes Park	500		2
5000	LCR - Routine&followup monitoring		1000484	Fcsa #34/Brighton Crest	140		1
3100	Total Coliform-routine monitoring		1000524	Auberry Seventh Day Adventist Chrch	25		3

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
5000	LCR - Routine&followup monitoring		1010006	Fowler, City Of	4729		1
0999	Stage 1 - DBP (Chlorine)		1010018	Kerman, City Of	11455		1
2456	Haloacetic Acids (HAA-5)		1010027	Reedley, City Of	22460		1
2950	Total Trihalomethanes (TTHMs)		1010027				1
1040	Nitrate as (NO ₃)		1010028	Riverdale Public Utility District	3000		1
2456	Haloacetic Acids (HAA-5)		1010028				1
2950	Total Trihalomethanes (TTHMs)		1010028				1
5000	LCR - Routine&followup monitoring		1010052	Sierra Cedars Csd	300		1
5000	LCR - Routine&followup monitoring		1010053	Shaver Lake Heights MWC	350		1
5000	LCR - Initial monitoring		1010055	Fresno Csa No. 47 (Quail Lake Estates)	1265		1
Humboldt County							
3100	Total Coliform-routine monitoring		1200517	Kimtu MeadoWS MWC	30		1
0200	SWTR-unfiltered sys-monitoring (31)		1200517				1
3100	Total Coliform-routine monitoring		1200588	Seawood Estates Mutual Water	30		2
3100	Total Coliform-routine monitoring		1200675	Stafford R V Park	100		1
3100	Total Coliform-routine monitoring		1200704	Azalea Glen	42		1
3100	Total Coliform-routine monitoring		1200718	Waddington W.W.	75		1
3100	Total Coliform-routine monitoring		1200728	Sounds Of The Seas W. S.	30		1
3100	Total Coliform-routine monitoring		1200772	Ocean Grove Lodge	50		1
3100	Total Coliform-routine monitoring		1200778	Bridgeville Elem. School	300		1
3100	Total Coliform-routine monitoring		1200792	Patrick'S Point Inn	25		1
3100	Total Coliform-routine monitoring		1210800	Eel River Conservation Camp	2000		1
Inyo County							
3100	Total Coliform-routine monitoring		1400004	Charles Brown Water Company	330		1
3100	Total Coliform-routine monitoring		1400063	Tecopa Francis Elementary School	50		1
3100	Total Coliform-routine monitoring		1400069	Death Valley Junction	200		1
3100	Total Coliform-routine monitoring		1400088	Delight'S Hot Springs Resort	55		1
3100	Total Coliform-routine monitoring		1400096	Tecopa Hot Springs Park	100		1
3100	Total Coliform-routine monitoring		1400133	Tecopa Palms Rv Park	50		2
3100	Total Coliform-routine monitoring		1400526	Eastern Sierra College Center - Bishop	100		1
Kern County							
3100	Total Coliform-routine monitoring		1500313	Mitchell'S Water System	30		1
3100	Total Coliform-routine monitoring		1500364	KrvWC - Kernvale Mutual Water Co	52		3
3100	Total Coliform-routine monitoring		1500398	Frontier Trail Homeowners Assoc, Inc.	40		1
3100	Total Coliform-routine monitoring		1500448	Hillview Acres Mutual Water Company	35		1
3100	Total Coliform-routine monitoring		1500455	William Fisher Memorial Water Company	80		2
3100	Total Coliform-routine monitoring		1500461	Fountain Trailer Park Water	45		2
3100	Total Coliform-routine monitoring		1500462	James Water System	40		2
3100	Total Coliform-routine monitoring		1500517	Stoco Mutual Water Company	2500		1
3100	Total Coliform-followup monitoring		1500517				1
3100	Total Coliform-routine monitoring		1500553	Ranchos Del Rio	63		1
3100	Total Coliform-routine monitoring		1500571	Rosamond Mutual Water Company	60		1
3100	Total Coliform-routine monitoring		1500578	Long Canyon Water Company Corp.	197		1
3100	Total Coliform-routine monitoring		1502004	AndreWS Ag., Inc	50		1
3100	Total Coliform-routine monitoring		1502008	Jones Auction	120		1
3100	Total Coliform-routine monitoring		1502012	Heck Cellars Water System	60		1
3100	Total Coliform-routine monitoring		1502034	California Portland Cement	200		1
3100	Total Coliform-routine monitoring		1502044	Camp Tecuya Water System	180		1
3100	Total Coliform-routine monitoring		1502084	Frazier Woods Conference Center	250		1
3100	Total Coliform-routine monitoring		1502093	Harvest Steakhouse	70		1
3100	Total Coliform-routine monitoring		1502142	Kern Valley Golf Course	500		1
3100	Total Coliform-routine monitoring		1502163	Linns Valley School	100		2
3100	Total Coliform-routine monitoring		1502194	Sierra Vista Restaurant	250		2
3100	Total Coliform-routine monitoring		1502260	South Fork School Water System	154		1
3100	Total Coliform-routine monitoring		1502383	Nord Road Water Association	47		1
3100	Total Coliform-routine monitoring		1502622	Gosford Road Water Company	42		1
3100	Total Coliform-routine monitoring		1502666	Wilcox Water System	27		2
3100	Total Coliform-routine monitoring		1502699	East Wilson Road Water Company	35		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		1502750	Riverview Homeowners Association	60		1
3100	Total Coliform-routine monitoring		1502756	Kern Valley Courts Complex	290		1
2456	Haloacetic Acids (HAA-5)		1502759	Paramount Farms - Hwy 33 Facility	695		1
2950	Total Trihalomethanes (TTHMs)		1502759				1
3100	Total Coliform-routine monitoring		1503093	Grimmway Enterprises-Malaga Water System	1500		1
3100	Total Coliform-routine monitoring		1503214	No. 1 Golf Driving Range	100		1
3100	Total Coliform-routine monitoring		1503231	Four Winds Water System	30		2
3100	Total Coliform-routine monitoring		1503256	Kids Kountry Preschool	70		2
3100	Total Coliform-followup monitoring		1503274	Ed Oakley Hall	45		1
3100	Total Coliform-routine monitoring		1503292	Weatherford U.S., L.P.	50		1
3100	Total Coliform-followup monitoring		1503341	Tejon Ranch-Intst. 5 & Laval Rd.	500		1
3100	Total Coliform-routine monitoring		1503368	South Fork Middle School	204		1
3100	Total Coliform-routine monitoring		1503378	Wind Wolves Preserve	30		2
3100	Total Coliform-routine monitoring		1503392	Four Twenty 420 Club	150		1
3100	Total Coliform-routine monitoring		1503537	Cemex Construction Materials Lp	45		1
2456	Haloacetic Acids (HAA-5)		1510013	Mcfarland MWC	9837		1
2950	Total Trihalomethanes (TTHMs)		1510013				1
2456	Haloacetic Acids (HAA-5)		1510014	Mojave Pud	3900		1
2950	Total Trihalomethanes (TTHMs)		1510014				1
2456	Haloacetic Acids (HAA-5)		1510022	West Kern Cwd	16800		1
2456	Haloacetic Acids (HAA-5)		1510027	Desert Lake Comm Serv Dist	860		1
2950	Total Trihalomethanes (TTHMs)		1510027				1
2456	Haloacetic Acids (HAA-5)		1510046	Lost Hills Utility District	1900		1
2950	Total Trihalomethanes (TTHMs)		1510046				1
3100	Total Coliform-routine monitoring		1510301	CSP - Fort Tejon	150		1
3100	Total Coliform-followup monitoring		1510701	Edwards Afb - Main Base	17066		1
Kings County							
2920	Total Organic Carbon (TOC)		1610002	Avenal, City Of	16205		1
2950	Total Trihalomethanes (TTHMs)		1610005	Lemoore, City Of	21076		1
3100	Total Coliform-routine monitoring		1610007	Home Garden CSD	1850		1
Lake County							
2456	Haloacetic Acids (HAA-5)		1700508	Glenhaven Mutual Water Company	300		1
2950	Total Trihalomethanes (TTHMs)		1700508				1
3100	Total Coliform-routine monitoring		1700511	Harbin Hot Springs	170		1
2456	Haloacetic Acids (HAA-5)		1700519	Crescent Bay Improvement Company	18		1
2950	Total Trihalomethanes (TTHMs)		1700519				1
2456	Haloacetic Acids (HAA-5)		1700526	Pine Grove Water System	304		1
2950	Total Trihalomethanes (TTHMs)		1700526				1
2456	Haloacetic Acids (HAA-5)		1700536	Sunrise Shore Mutual Water Company	45		1
2950	Total Trihalomethanes (TTHMs)		1700536				1
2456	Haloacetic Acids (HAA-5)		1700574	Lake County Csa 18 - Starview	338		1
2950	Total Trihalomethanes (TTHMs)		1700574				1
3100	Total Coliform-routine monitoring		1700589	Blue Lakes Mobile Home Park	50		1
2456	Haloacetic Acids (HAA-5)		1700589				1
2950	Total Trihalomethanes (TTHMs)		1700589				1
2456	Haloacetic Acids (HAA-5)		1700674	Walnut Cove Mobile Estates	10		1
2950	Total Trihalomethanes (TTHMs)		1700674				1
3100	Total Coliform-routine monitoring		1700686	Harbor Restaurant And Lounge	25		1
3100	Total Coliform-routine monitoring		1700712	Lakeport Theatre	500		1
Lassen County							
3100	Total Coliform-routine monitoring		1800531	Caltrans-Honey Lake Rest Stop	350		1
Los Angeles County							
3100	Total Coliform-routine monitoring		1900514	Llano Farms Water Company- Community	40		1
3100	Total Coliform-followup monitoring		1900563	Sundale Mutual Water Company 'A', 'B'	350		1
3100	Total Coliform-routine monitoring		1900677	Oasis Park Mobile Home Park	100		1
2456	Haloacetic Acids (HAA-5)		1900803	El Dorado Mutual Water Co.	648		1
2950	Total Trihalomethanes (TTHMs)		1900803				1
3100	Total Coliform-routine monitoring		1900946	Palmdale Trailer Park	104		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
2456	Haloacetic Acids (HAA-5)		1910048	Castaic Lake Water Agency	0		1
Madera County							
2950	Total Trihalomethanes (TTHMs)		2010001	Chowchilla City Water Dept	9000		1
Marin County							
2456	Haloacetic Acids (HAA-5)		2110001	Inverness Public Utility Dist	1200		1
2950	Total Trihalomethanes (TTHMs)		2110001				1
2456	Haloacetic Acids (HAA-5)		2110008	Lawson's Landing	3100		1
2950	Total Trihalomethanes (TTHMs)		2110008				1
Mariposa County							
5000	LCR - Initial monitoring		2210515	NPS-Yosemite-EI Portal	635		2
5000	LCR - Initial monitoring		2210925	Yosemite Westlake Mobile Estates	30		2
Mendocino County							
3100	Total Coliform-routine monitoring		2300503	Sutherland Waterworks	27		2
2456	Haloacetic Acids (HAA-5)		2300503				1
2950	Total Trihalomethanes (TTHMs)		2300503				1
3100	Total Coliform-routine monitoring		2300506	Meadow Estates Mutual	85		1
3100	Total Coliform-followup monitoring		2300519	Coast Motel	25		1
3100	Total Coliform-routine monitoring		2300609	Seafair Road And Water Company	50		1
2456	Haloacetic Acids (HAA-5)		2300610	Caspar South Service Company	125		1
2950	Total Trihalomethanes (TTHMs)		2300610				1
3100	Total Coliform-routine monitoring		2300663	Harwood Water System	100		1
2456	Haloacetic Acids (HAA-5)		2300663				2
2950	Total Trihalomethanes (TTHMs)		2300663				2
2456	Haloacetic Acids (HAA-5)		2300705	Little Lake Mobile Home Park	52		1
2950	Total Trihalomethanes (TTHMs)		2300705				1
2456	Haloacetic Acids (HAA-5)		2300708	Ridgewood Water System	200		1
3100	Total Coliform-routine monitoring		2300736	Caspar Beach RV Park	25		1
2456	Haloacetic Acids (HAA-5)		2300829	Round Valley Schools	400		1
2950	Total Trihalomethanes (TTHMs)		2300829				1
3100	Total Coliform-routine monitoring		2310010	Hopland Public Utility District	1020		1
2456	Haloacetic Acids (HAA-5)		2310010				1
2950	Total Trihalomethanes (TTHMs)		2310010				1
2456	Haloacetic Acids (HAA-5)		2310011	Laytonville County Water District	1301		1
2950	Total Trihalomethanes (TTHMs)		2310011				1
Merced County							
5000	LCR - Routine&followup monitoring		2410001	Atwater, City Of	26515		1
Mono County							
3100	Total Coliform-routine monitoring		2600557	Tioga Pass Market/Rest.	100		1
3100	Total Coliform-routine monitoring		2600568	Edna Beaman Elementary School	90		1
3100	Total Coliform-routine monitoring		2600572	Mcgee Creek Mobile Home Park	20		1
3100	Total Coliform-routine monitoring		2600614	June Mtn. Ski Area, Stew Pot Slim'S	50		1
3100	Total Coliform-routine monitoring		2600615	June Mtn. Ski Area, Stew Pot Slim'S	500		2
3100	Total Coliform-routine monitoring		2600621	White Mountain Estates	50		2
Monterey County							
3100	Total Coliform-routine monitoring		2700509	Oak Manor WS	71		1
4000	Gross Alpha		2700511	Normco WC	868		1
3100	Total Coliform-routine monitoring		2700511				1
3100	Total Coliform-routine monitoring		2700518	Watsonville Produce WS	100		1
3100	Total Coliform-followup monitoring		2700518				1
3100	Total Coliform-routine monitoring		2700534	Colonial Oaks WC	198		1
3100	Total Coliform-followup monitoring		2700534				1
1005	Arsenic		2700552	Echo Valley School WS	400		1
3100	Total Coliform-followup monitoring		2700575	El Camino Real WS #16	29		1
3100	Total Coliform-followup monitoring		2700592	Harrison Rd WS #01	40		1
3100	Total Coliform-routine monitoring		2700594	Hidden Valley Wa	51		1
3100	Total Coliform-followup monitoring		2700594				1
3100	Total Coliform-routine monitoring		2700606	Hidden VieWS MHP WS	75		1
3100	Total Coliform-followup monitoring		2700613	Lagunita School WS	60		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
1040	Nitrate as (NO ₃)		2700634	Chetmoore Acres Wa	50		1
3100	Total Coliform-routine monitoring		2700636	Royal Oaks Park WS	25		1
3100	Total Coliform-followup monitoring		2700638	Maher Rd WS #05	51		2
3100	Total Coliform-followup monitoring		2700662	Murphy Hill WS #01	65		1
3100	Total Coliform-followup monitoring		2700674	Paradise Lake MWC	180		1
3100	Total Coliform-routine monitoring		2700702	Prunedale MWC	252		3
3100	Total Coliform-followup monitoring		2700703	Calvary Church Inc WS	150		1
1040	Nitrate as (NO ₃)		2700713	Rolling Hills Rancho Wa	177		1
3100	Total Coliform-routine monitoring		2700771	Springfield MWC	200		2
3100	Total Coliform-followup monitoring		2700772	Struve Rd WS #02	166		1
3100	Total Coliform-routine monitoring		2700792	Summerhill MHP WS	102		1
1040	Nitrate as (NO ₃)		2700856	Altman Plants Ws #01	45		2
3100	Total Coliform-routine monitoring		2700856				2
3100	Total Coliform-followup monitoring		2700856				2
3100	Total Coliform-routine monitoring		2700875	Pajaro Valley Greenhouse WS	110		1
3100	Total Coliform-routine monitoring		2700998	Bud Antle Marina WS	150		1
3100	Total Coliform-routine monitoring		2701040	Mccoys Rd WS #05	72		2
3100	Total Coliform-followup monitoring		2701040				1
3100	Total Coliform-followup monitoring		2701063	River Rd WS #25	65		1
1040	Nitrate as (NO ₃)		2701153	Growers Transplanting WS	50		1
3100	Total Coliform-routine monitoring		2701153				1
1025	Fluoride		2701232	Old Natividad Rd WS #01	25		1
2991	Toluene		2701232				1
3100	Total Coliform-routine monitoring		2701254	Carmel Riviera MWC	555		1
3100	Total Coliform-followup monitoring		2701355	Princes Camp Resort WS	126		1
3100	Total Coliform-routine monitoring		2701498	Harbor View Wa	75		1
3100	Total Coliform-routine monitoring		2701553	Pond-Derosa Oaks WC	216		1
3100	Total Coliform-routine monitoring		2701589	Sunny Acres MWS	45		1
3100	Total Coliform-routine monitoring		2701630	Prunedale Chevron WS	25		1
3100	Total Coliform-followup monitoring		2701647	Green Acres Wa	50		1
3100	Total Coliform-routine monitoring		2701658	Arroyo Center WC	130		1
1040	Nitrate as (NO ₃)		2701701	Bradley-Lockwood Rd WS	39		1
3100	Total Coliform-routine monitoring		2701726	Spence Rd WS #05	25		1
3100	Total Coliform-routine monitoring		2701731	Brandon Creek MWS	41		3
3100	Total Coliform-followup monitoring		2701731				1
0200	SWTR-unfiltered sys-monitoring (31)		2701731				1
3100	Total Coliform-routine monitoring		2701800	Tularcitos MWC	85		1
1040	Nitrate as (NO ₃)		2701876	Mushroom Farms WS	75		1
3100	Total Coliform-routine monitoring		2701876				1
3100	Total Coliform-followup monitoring		2701918	Lomas Del Sol MWS	93		1
3100	Total Coliform-followup monitoring		2701942	Vierra Canyon WS #29	25		1
0200	SWTR-unfiltered sys-monitoring (31)		2701945	Big Sur Campground WS	100		1
3100	Total Coliform-routine monitoring		2701946	Hoson Produce WS	60		2
1040	Nitrate as (NO ₃)		2702007	Vierra Estates WS	164		1
3100	Total Coliform-routine monitoring		2702009	Laguna Seca Recreation WS	500		1
3100	Total Coliform-routine monitoring		2702030	Cypress Community Church WS	200		1
3100	Total Coliform-routine monitoring		2702073	San Miguel WS #22	93		1
3100	Total Coliform-routine monitoring		2702110	Delany WC	60		1
3100	Total Coliform-followup monitoring		2702140	Woodside Wa	78		1
3100	Total Coliform-routine monitoring		2702163	Hilltop MWA	100		1
3100	Total Coliform-routine monitoring		2702165	Orchard Ln WS #09	25		1
3100	Total Coliform-followup monitoring		2702165				1
3100	Total Coliform-routine monitoring		2702172	Stonepine Resort WS	100		1
3100	Total Coliform-routine monitoring		2702180	Graves School WS	56		1
3100	Total Coliform-routine monitoring		2702254	Pacific Valley School WS	55		1
3100	Total Coliform-routine monitoring		2702255	All Saints Campground WS	25		1
0200	SWTR-filtered sys-monitoring (36)		2702266	Coast Gallery WS	100		1
1040	Nitrate as (NO ₃)		2702293	Rod Mclellan Botanicals WS	45		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
0200	SWTR-unfiltered sys-monitoring (31)		2702373	Phenegar Creek WS	48		1
3100	Total Coliform-routine monitoring		2702374	Countryside Estates MWC	73		1
3100	Total Coliform-routine monitoring		2702396	River Rd WS #26	25		1
1040	Nitrate as (NO ₃)		2702409	El Camino WC Inc	90		1
3100	Total Coliform-followup monitoring		2702409				1
0999	Stage 1 - DBP (Chlorine)		2702412	Dole Fresh Vegetables WS	80		1
3100	Total Coliform-routine monitoring		2702431	Foothill Rd WS #01	25		1
3100	Total Coliform-routine monitoring		2702475	Free Will Baptist Church WS	80		1
3100	Total Coliform-routine monitoring		2702486	Bernardo Rd WS #02	25		1
1005	Arsenic		2702550	Grange Hall WS	25		1
3100	Total Coliform-routine monitoring		2702551	Loma Vista Inn WS	25		1
3100	Total Coliform-followup monitoring		2702551				1
3100	Total Coliform-routine monitoring		2702566	Premium Fresh Farms WS	25		2
3100	Total Coliform-routine monitoring		2702575	Tree Bones Resort WS	25		1
3100	Total Coliform-routine monitoring		2702613	Estancia Winery WS	25		1
3100	Total Coliform-followup monitoring		2702615	Esperanza Rd WS	160		1
3100	Total Coliform-routine monitoring		2702616	Altman Plants WS #02	25		2
3100	Total Coliform-followup monitoring		2702616				3
3100	Total Coliform-routine monitoring		2702620	Harrington Rd WS #07	25		1
3100	Total Coliform-routine monitoring		2702643	Cypress Center WS	40		2
3100	Total Coliform-routine monitoring		2702784	Spreckels Rd WS #04	25		1
0999	Stage 1 - DBP (Chlorine)		2710004	Cal Am Water Company - Monterey	92115		1
0999	Stage 1 - DBP (Chlorine)		2710007	Gonzales, City Of	8374		1
1040	Nitrate as (NO ₃)		2710010	CWSC Salinas	127750		1
0999	Stage 1 - DBP (Chlorine)		2710011	Soledad, City Of	14543		1
1040	Nitrate as (NO ₃)		2710021	Toro Water Service	1340		1
Napa County							
3100	Total Coliform-routine monitoring		2800031	Signorello Winery	25		1
3100	Total Coliform-routine monitoring		2800736	Domaine Chandon	200		1
3100	Total Coliform-routine monitoring		2801020	Clemmer Trust, The	30		1
3100	Total Coliform-routine monitoring		2801026	Opus One Winery	100		1
3100	Total Coliform-routine monitoring		2801046	St. Supery Winery	40		1
2456	Haloacetic Acids (HAA-5)		2810009	Berryessa Pines Water System	200		1
2950	Total Trihalomethanes (TTHMs)		2810009				1
2456	Haloacetic Acids (HAA-5)		2810012	Pacific Union College	3000		1
2456	Haloacetic Acids (HAA-5)		2810014	Spanish Flat Water District	460		1
2950	Total Trihalomethanes (TTHMs)		2810014				1
Nevada County							
3100	Total Coliform-routine monitoring		2900529	Sunset Mobile Home Park Water System	60		1
3100	Total Coliform-routine monitoring		2900540	Forest Lake Christian School Water System	150		1
3100	Total Coliform-routine monitoring		2900547	Rollins Lakeside Inn Water System	35		1
3100	Total Coliform-routine monitoring		2900572	Five-Mile House Restaurant Water System	150		1
3100	Total Coliform-routine monitoring		2900578	Grizzly Hill School Water System	125		1
3100	Total Coliform-routine monitoring		2900587	Milhou Children Services Water System	50		1
3100	Total Coliform-routine monitoring		2900593	Oak Tree School Water System	120		2
3100	Total Coliform-routine monitoring		2902326	Dew Drop Inn Water System	50		1
3100	Total Coliform-routine monitoring		2902363	Mission Beth'El Church Water System	60		1
3100	Total Coliform-routine monitoring		2902391	North Gold Senior Mountaineers Water Sys	50		1
Orange County							
0999	Stage 1 - DBP (Chlorine)		3000515	Harding Water Users	100		1
0999	Stage 1 - DBP (Chlorine)		3000803	Northrop Grumman Capistrano Test Site	120		1
0999	Stage 1 - DBP (Chlorine)		3000811	Crescent Water Association	300		2
Placer County							
3100	Total Coliform-routine monitoring		3100001	Timber Hills Mutual Water Co	100		1
3100	Total Coliform-routine monitoring		3100058	Dutch Flat Mutual	250		1
3100	Total Coliform-routine monitoring		3100072	Live Oak Waldorf School	220		1
3100	Total Coliform-routine monitoring		3103195	Applegate Station	25		1
3100	Total Coliform-routine monitoring		3103234	Everybody's Inn	25		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		3104519	Caltrans-Whitmore Maint. Station	25		1
3100	Total Coliform-routine monitoring		3107311	Summit Deck & Grill- Northstar	2000		1
3100	Total Coliform-routine monitoring		3107315	Tahoe Vistana	50		1
5000	LCR - Initial monitoring		3110031	Ward Well Water Company	375		1
Plumas County							
3100	Total Coliform-routine monitoring		3200009	Caltrans-Massack Rest Stop	350		1
3100	Total Coliform-routine monitoring		3200020	Caltrans-L.T. Davis Reststop	200		1
3100	Total Coliform-routine monitoring		3200022	Caltrans-Chester Safety Rest Stop	120		1
3100	Total Coliform-routine monitoring		3200072	Buck'S Lakeshore Resort	200		1
3100	Total Coliform-routine monitoring		3200078	FRCCSD-Old Mill Mutual	16		1
3100	Total Coliform-routine monitoring		3200103	FRCCSD-Belden Town	25		1
3100	Total Coliform-followup monitoring		3200103				1
3100	Total Coliform-routine monitoring		3200105	FRCCSD-Tobin	25		1
3100	Total Coliform-followup monitoring		3200105				1
0200	SWTR-filtered sys-monitoring (36)		3210001	Ivcsd-Greenville	3000		1
Riverside County							
7000	Consumer Confidence Report		3301011	Stone Creek Water Co.	50		1
7000	Consumer Confidence Report		3301018	Anza Pines Mobile Home Park	150		1
7000	Consumer Confidence Report		3301031	Banning Hts. Mutual Water Co.	350		1
7000	Consumer Confidence Report		3301040	Bermuda Palms Mobile Estates	300		1
7000	Consumer Confidence Report		3301045	Blythe Mobile Home Estates	30		1
7000	Consumer Confidence Report		3301046	Boe Del Heights Mutual Water	250		1
7000	Consumer Confidence Report		3301055	Village Of Child Help	100		1
7000	Consumer Confidence Report		3301058	Country Hills Rv Park	50		1
7000	Consumer Confidence Report		3301107	Carver Tract Mutual Water Company	300		1
7000	Consumer Confidence Report		3301114	Cherry Valley Water Company	200		1
7000	Consumer Confidence Report		3301115	Chiriaco Summit Water Dist.	400		1
7000	Consumer Confidence Report		3301147	CvUSD Facilities/M&O	50		1
7000	Consumer Confidence Report		3301149	CvUSD, Cv High School	2025		1
7000	Consumer Confidence Report		3301152	CvUSD, Oasis School	750		2
7000	Consumer Confidence Report		3301153	CvUSD, Westside School	975		1
7000	Consumer Confidence Report		3301155	College Of The Desert	4000		1
7000	Consumer Confidence Report		3301169	Murrieta Palms Mobile Home Park	150		1
7000	Consumer Confidence Report		3301180	Anza Mutual Water Company	200		1
7000	Consumer Confidence Report		3301209	Desert View Trailer Park	50		1
7000	Consumer Confidence Report		3301220	Double 'R' Trailer Park	90		1
3100	Total Coliform-routine monitoring		3301241	El Dorado Polo Club	50		1
7000	Consumer Confidence Report		3301247	Elms Mobile Park	80		1
7000	Consumer Confidence Report		3301267	Fisherman's Retreat	100		1
7000	Consumer Confidence Report		3301276	Fuller Mutual Water Company	100		1
3100	Total Coliform-routine monitoring		3301280	Golden Era Productions	500		1
7000	Consumer Confidence Report		3301280				1
7000	Consumer Confidence Report		3301283	Glen Eden Sun Club	200		1
7000	Consumer Confidence Report		3301294	Glen Ivy Hot Springs	750		1
3100	Total Coliform-routine monitoring		3301305	California Redi Date, Llc	27		1
7000	Consumer Confidence Report		3301305				1
3100	Total Coliform-routine monitoring		3301308	Cottonwood School	300		1
7000	Consumer Confidence Report		3301308				1
7000	Consumer Confidence Report		3301309	Hamilton School	950		1
7000	Consumer Confidence Report		3301330	Indian Oaks Trailer Park	50		1
3100	Total Coliform-routine monitoring		3301359	Kennedy Grocery	450		1
7000	Consumer Confidence Report		3301372	La Quinta Ridge Mobile Estates	350		1
7000	Consumer Confidence Report		3301380	Saint Anthony Trailer Park	250		1
7000	Consumer Confidence Report		3301381	Riverside County Service Area #51	350		1
7000	Consumer Confidence Report		3301385	Jojoba Hills Skp Resort, Inc.	154		1
7000	Consumer Confidence Report		3301388	Desert Dunes Golf Club Llc	90		1
7000	Consumer Confidence Report		3301445	Mountain View Mobile Home Park	200		1
7000	Consumer Confidence Report		3301476	Ibarra/Spates Families Water	45		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
7000	Consumer Confidence Report		3301491	Alpine Village	130		1
7000	Consumer Confidence Report		3301494	Palm Springs Aerial Tramway	1000		1
7000	Consumer Confidence Report		3301502	Paradise Valley MWC	30		1
7000	Consumer Confidence Report		3301511	Pinyon Crest Hoa	200		1
7000	Consumer Confidence Report		3301529	Ramona Water Company	250		1
7000	Consumer Confidence Report		3301535	Rancho Carrillo MWC	168		1
7000	Consumer Confidence Report		3301541	Reche Canyon MWC	150		1
7000	Consumer Confidence Report		3301577	Riverside County Service Area #62	700		1
7000	Consumer Confidence Report		3301588	Royal Carrizo Hoa	25		1
3100	Total Coliform-routine monitoring		3301643	Spring Crest Water & Power	30		2
7000	Consumer Confidence Report		3301643				1
7000	Consumer Confidence Report		3301676	Thomas Mountain Water Company	75		1
3100	Total Coliform-routine monitoring		3301682	Trails End Mutual Water Company	75		1
7000	Consumer Confidence Report		3301682				1
3100	Total Coliform-routine monitoring		3301690	Twin Pines Boys Ranch	70		1
7000	Consumer Confidence Report		3301717	Valley View Trailer Park	100		1
7000	Consumer Confidence Report		3301734	Vista Dunes Mobilehome Park	180		1
7000	Consumer Confidence Report		3301735	Waller Tract Water District	200		1
7000	Consumer Confidence Report		3301746	Whispering Sands Mobile Home Park	37		1
7000	Consumer Confidence Report		3301755	Sunbird MHP, C/O Hawkeye Asset.Mgmt	258		1
7000	Consumer Confidence Report		3301756	Kkottongnae Retreat Camp	75		1
7000	Consumer Confidence Report		3301775	High Valleys Water District	300		1
7000	Consumer Confidence Report		3301803	Castro Trailer Park	180		1
3100	Total Coliform-routine monitoring		3301850	Delara Rentals	25		1
7000	Consumer Confidence Report		3301850				1
7000	Consumer Confidence Report		3301863	Trinity - Anza	75		1
7000	Consumer Confidence Report		3301877	Block 77 Water Company	50		1
7000	Consumer Confidence Report		3301935	Coachella Valley Citrus - Dunlap	250		1
3100	Total Coliform-routine monitoring		3301937	Mesquite Mutual Water Company	25		1
7000	Consumer Confidence Report		3301937				1
3100	Total Coliform-routine monitoring		3301947	Morning Sky School	50		1
7000	Consumer Confidence Report		3301947				1
7000	Consumer Confidence Report		3301980	Desert Hills Premium Outlets	7250		1
7000	Consumer Confidence Report		3301990	Amezcu Garcia Water	250		1
7000	Consumer Confidence Report		3302008	Sanchez Water Well	50		1
7000	Consumer Confidence Report		3302009	Sam's Fence	50		1
7000	Consumer Confidence Report		3302019	Bundy Canyon Christian School	400		1
3100	Total Coliform-routine monitoring		3302045	Rancho San Miguel Labor Camp	25		1
7000	Consumer Confidence Report		3302045				1
7000	Consumer Confidence Report		3302065	Imperial Irrigation Dist. La Quinta	100		2
3100	Total Coliform-routine monitoring		3302069	La Pena Housing Facility	100		1
7000	Consumer Confidence Report		3302069				1
3100	Total Coliform-routine monitoring		3302079	Aida Aguirre & Dimicio Sampagan	50		1
7000	Consumer Confidence Report		3302079				1
7000	Consumer Confidence Report		3302081	Perez Water	30		1
3100	Total Coliform-routine monitoring		3302088	Rancho La Mesa Rica	40		1
7000	Consumer Confidence Report		3302088				1
7000	Consumer Confidence Report		3302093	County Water Company	180		1
3100	Total Coliform-routine monitoring		3303002	Oasis Palms Rv Park	25		1
7000	Consumer Confidence Report		3303003	Galindo Housing Facility	50		1
3100	Total Coliform-routine monitoring		3303026	Granite Construction Company	25		1
7000	Consumer Confidence Report		3303026				1
7000	Consumer Confidence Report		3303028	Shady Acres	45		1
7000	Consumer Confidence Report		3303035	Benjamin Hernandez Housing	50		1
7000	Consumer Confidence Report		3303048	Manuela Garcia Water	50		1
7000	Consumer Confidence Report		3303071	PGA Of So. Ca Golf Club Oak Vly	300		1
7000	Consumer Confidence Report		3303072	Goose Creek Golf Club	300		1
7000	Consumer Confidence Report		3303081	Idyllwild Arts Academy	275		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		3303085	Hits Desert Horse Park	900		1
2456	Haloacetic Acids (HAA-5)		3310033	Santa Ana River Water Company	8020		1
2950	Total Trihalomethanes (TTHMs)		3310033				1
1040	Nitrate as (NO ₃)		3310036	Western MWD - Murrieta Division	7200		3
Sacramento County							
3100	Total Coliform-routine monitoring		3400161	Tahoe Lodge	40		1
3100	Total Coliform-routine monitoring		3400204	Red Phoenix/Beau's	50		1
1040	Nitrate as (NO ₃)		3400284	Foothill Golf Center	200		3
3100	Total Coliform-routine monitoring		3400284				2
San Benito County							
0999	Stage 1 - DBP (Chlorine)		3500503	Harmony Hills Water System	60		1
3100	Total Coliform-routine monitoring		3500505	Thousand Trails San Benito Preserve	1750		1
3100	Total Coliform-routine monitoring		3500507	Bitterwater-Tully School WS	45		1
0999	Stage 1 - DBP (Chlorine)		3500507				1
3100	Total Coliform-routine monitoring		3500509	Tres Pinos CWD	500		1
0400	Stage 1 - DBP (Monitoring Plan)		3500509				2
3100	Total Coliform-routine monitoring		3500510	Mcmahon Road Mutual Water Company	100		1
0999	Stage 1 - DBP (Chlorine)		3500510				1
3100	Total Coliform-routine monitoring		3500511	Casa De Fruta Orchards	81		1
0999	Stage 1 - DBP (Chlorine)		3500511				1
3100	Total Coliform-routine monitoring		3500521	Southside Elementary School	250		1
3100	Total Coliform-routine monitoring		3500526	Arnold Park (O'Bannon's MHP)	28		1
0999	Stage 1 - DBP (Chlorine)		3500526				1
3100	Total Coliform-routine monitoring		3500527	Valenzuela Water System	55		1
0999	Stage 1 - DBP (Chlorine)		3500527				1
3100	Total Coliform-routine monitoring		3500547	Cedar House Restaurant	25		1
3100	Total Coliform-routine monitoring		3500549	Rosa Morada Mutual Water Company	50		1
3100	Total Coliform-routine monitoring		3500552	Venture Estates MWC	55		1
0999	Stage 1 - DBP (Chlorine)		3500552				1
2456	Haloacetic Acids (HAA-5)		3500552				1
2950	Total Trihalomethanes (TTHMs)		3500552				1
0400	Stage 1 - DBP (Monitoring Plan)		3500556	Mission Farm R.V. Park	110		2
0999	Stage 1 - DBP (Chlorine)		3500556				2
7000	Consumer Confidence Report		3500556				1
1040	Nitrate as (NO ₃)		3500563	Mccormick Selph, Inc.	350		1
3100	Total Coliform-routine monitoring		3500565	Fairview Child Develop Center	70		1
0999	Stage 1 - DBP (Chlorine)		3500565				1
3100	Total Coliform-routine monitoring		3500570	B&R Farms	25		1
3100	Total Coliform-routine monitoring		3500571	San Benito High School	2700		1
3100	Total Coliform-routine monitoring		3500575	Springwood Estates MWC	45		1
3100	Total Coliform-routine monitoring		3500576	Aromas Hills Mutual Water Association	60		1
3100	Total Coliform-routine monitoring		3500577	Cole Rd MWC	29		2
3100	Total Coliform-routine monitoring		3500578	Los Madrones MWC	40		1
0999	Stage 1 - DBP (Chlorine)		3500578				1
0999	Stage 1 - DBP (Chlorine)		3500581	Rancho San Joaquin MWC	100		1
3100	Total Coliform-routine monitoring		3500801	Willow Grove Union Elem School	60		1
0999	Stage 1 - DBP (Chlorine)		3500801				1
3100	Total Coliform-routine monitoring		3500804	Seminis Vegetables Seeds, Inc.	30		1
3100	Total Coliform-routine monitoring		3500806	Blossom Hill Winery	60		1
3100	Total Coliform-routine monitoring		3500807	Denice & Filice Llc	200		1
3100	Total Coliform-routine monitoring		3500810	Whispering Pines Retire Home (LSWS)	100		1
3100	Total Coliform-routine monitoring		3500816	Quintero Labor Camp #2	35		1
1040	Nitrate as (NO ₃)		3500817	Lico Labor Camp	49		1
3100	Total Coliform-routine monitoring		3500817				1
0999	Stage 1 - DBP (Chlorine)		3500817				1
0999	Stage 1 - DBP (Chlorine)		3500830	Hernandez Labor Camp	70		1
3100	Total Coliform-routine monitoring		3500903	San Juan Oaks Golf Club	450		1
0999	Stage 1 - DBP (Chlorine)		3500903				1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		3500906	Haydon Family Farm & Park	150		1
3100	Total Coliform-routine monitoring		3500912	Comstock Mutual Water Company	100		1
3100	Total Coliform-routine monitoring		3500913	Earthbound Farms	900		1
0400	Stage 1 - DBP (Monitoring Plan)		3500913	Earthbound Farms	900		2
3100	Total Coliform-routine monitoring		3500920	Paicines Water System	50		1
3100	Total Coliform-routine monitoring		3500924	El Modeno Nursery Inc.	150		1
3100	Total Coliform-routine monitoring		3500925	Paicines Ranch	45		1
3100	Total Coliform-routine monitoring		3510006	Mission Oaks Mobile Home Park	500		1
0999	Stage 1 - DBP (Chlorine)		3510006				1
3100	Total Coliform-routine monitoring		3510300	CSP-Fremont Peak	50		1
San Bernardino County							
3100	Total Coliform-routine monitoring		3600394	New Beginnings	150		1
3100	Total Coliform-routine monitoring		3600504	Knoll Enterprises Inc	500		1
San Diego County							
1040	Nitrate as (NO ₃)		3700003	Whispering Winds Conference Center	160		1
3100	Total Coliform-routine monitoring		3700003				1
3100	Total Coliform-routine monitoring		3700008	Volcan Mountain Hunting Club	70		1
1040	Nitrate as (NO ₃)		3700011	Stelzer County Park	25		1
1040	Nitrate as (NO ₃)		3700013	Descanso Junction	50		1
3100	Total Coliform-routine monitoring		3700015	Heller Ford Mitsubishi Suzuki	160		1
3100	Total Coliform-routine monitoring		3700018	Campo Elementary School	300		1
3100	Total Coliform-routine monitoring		3700023	Coleman Creek Village	50		1
3100	Total Coliform-routine monitoring		3700030	Fry Creek Observatory	300		1
3100	Total Coliform-routine monitoring		3700041	Barrett Lake Mobilehome Park	150		4
7000	Consumer Confidence Report		3700041				1
1040	Nitrate as (NO ₃)		3700042	Lakeland Resort	25		1
3100	Total Coliform-routine monitoring		3700042				1
3100	Total Coliform-routine monitoring		3700047	T.C. Worthy Cash & Carry, Inc.	25		1
1040	Nitrate as (NO ₃)		3700049	Potrero General Store	800		1
3100	Total Coliform-routine monitoring		3700049	Potrero General Store	800		2
1040	Nitrate as (NO ₃)		3700063	Freedom Ranch	50		1
3100	Total Coliform-routine monitoring		3700065	South Bay Rod & Gun Club	8000		1
3100	Total Coliform-routine monitoring		3700071	Heavenly Oaks	300		3
1040	Nitrate as (NO ₃)		3700072	William Heise County Park	850		1
3100	Total Coliform-routine monitoring		3700073	H & J Water Company	50		1
7000	Consumer Confidence Report		3700073				1
1040	Nitrate as (NO ₃)		3700074	Cuyamaca Water District	200		1
3100	Total Coliform-routine monitoring		3700074				1
7000	Consumer Confidence Report		3700074				1
3100	Total Coliform-routine monitoring		3700118	Campo Alternative School	25		1
3100	Total Coliform-routine monitoring		3700149	Wynola Bible Conference	100		1
1040	Nitrate as (NO ₃)		3700174	Diamond Jacks Rv Ranch	120		1
1040	Nitrate as (NO ₃)		3700195	Outdoor World Retreat	300		1
3100	Total Coliform-routine monitoring		3700195				1
1040	Nitrate as (NO ₃)		3700276	Oak Knoll Campground	500		1
1040	Nitrate as (NO ₃)		3700277	Sunrise Estates Mutual Water Company	200		1
3100	Total Coliform-routine monitoring		3700277				3
7000	Consumer Confidence Report		3700277				1
7000	Consumer Confidence Report		3700422	Stuart Water Company	250		1
1040	Nitrate as (NO ₃)		3700846	Agua Caliente County Park	400		1
1040	Nitrate as (NO ₃)		3700847	Lake Hodges Boat Facility	100		1
1040	Nitrate as (NO ₃)		3700848	Alpine Springs RV Park	200		1
3100	Total Coliform-routine monitoring		3700848				2
3100	Total Coliform-routine monitoring		3700858	Shady Oaks Trailer Ranch	25		1
3100	Total Coliform-routine monitoring		3700859	Rancho Del Campo Water System	290		3
1040	Nitrate as (NO ₃)		3700865	Lake Cuyamaca Park & Rec.	600		1
1040	Nitrate as (NO ₃)		3700895	El Monte County Park	25		1
3100	Total Coliform-routine monitoring		3700906	Camp Stevens	50		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		3700909	Julian Community Services District	578		1
1040	Nitrate as (NO ₃)		3700911	Whispering Oaks Program Center	120		1
1040	Nitrate as (NO ₃)		3700912	Ymca Camp Marston/Raintree	300		1
3100	Total Coliform-routine monitoring		3700913	Apple Tree Inn	300		1
7000	Consumer Confidence Report		3700922	Live Oak Springs Water & Power	200		2
7000	Consumer Confidence Report		3700923	Lake Morena Oak Shore Mw Co.	600		1
3100	Total Coliform-routine monitoring		3700924	Lake Morena VieWS Mw Co.	350		5
7000	Consumer Confidence Report		3700924	Lake Morena Views MWC	350		1
1040	Nitrate as (NO ₃)		3700931	Vallecito County Park	145		1
1040	Nitrate as (NO ₃)		3700933	Palomar Mountain Mutual Water Co.	70		1
3100	Total Coliform-routine monitoring		3700933				1
3100	Total Coliform-routine monitoring		3700934	Pauma Valley Mutual Water Company	120		1
7000	Consumer Confidence Report		3700934				1
3100	Total Coliform-routine monitoring		3700936	Rancho Estates Mutual Water Co.	220		2
1040	Nitrate as (NO ₃)		3700959	Warner Springs Ranch Owners Assoc.	155		1
3100	Total Coliform-routine monitoring		3700962	Oakvale Park	100		2
1040	Nitrate as (NO ₃)		3700964	Swallows Sun Island Club	50		1
3100	Total Coliform-routine monitoring		3700964				1
7000	Consumer Confidence Report		3700964				1
1040	Nitrate as (NO ₃)		3700968	San Pasqual Academy	150		1
3100	Total Coliform-routine monitoring		3700968				1
3100	Total Coliform-routine monitoring		3700970	Yoga Center Retreat	50		1
3100	Total Coliform-routine monitoring		3701005	Spencer Valley School District	51		2
1040	Nitrate as (NO ₃)		3701010	Warner Unified School District	400		1
1040	Nitrate as (NO ₃)		3701070	Pinecrest Community Center	70		1
3100	Total Coliform-routine monitoring		3701070				1
3100	Total Coliform-routine monitoring		3701184	Butterfield Ranch	25		3
7000	Consumer Confidence Report		3701184				1
3100	Total Coliform-routine monitoring		3701213	Borrego Springs Park Community Services	35		1
1040	Nitrate as (NO ₃)		3701217	Camp Virginia	25		1
3100	Total Coliform-routine monitoring		3701217				1
3100	Total Coliform-routine monitoring		3701240	Yoga Center Mother's Kitchen	98		1
3100	Total Coliform-routine monitoring		3701241	Al Bahr Shrine Camp	150		1
1040	Nitrate as (NO ₃)		3701341	Butterfield Oaks Mobile Home Park	80		1
3100	Total Coliform-routine monitoring		3701341				3
7000	Consumer Confidence Report		3701341				1
1040	Nitrate as (NO ₃)		3701380	R & B Wholesale Distributors	50		1
1040	Nitrate as (NO ₃)		3701390	Lux Inn	100		1
1040	Nitrate as (NO ₃)		3701407	Angels Landing Country Inn And Resort	30		1
3100	Total Coliform-routine monitoring		3701407				1
1040	Nitrate as (NO ₃)		3701476	Indian Hills Camp	160		1
3100	Total Coliform		3701478	Phoenix Academy	65		1
3100	Total Coliform-routine monitoring		3701478				1
3100	Total Coliform-followup monitoring		3701478				1
1040	Nitrate as (NO ₃)		3701518	Narconon Southern California	40		1
1040	Nitrate as (NO ₃)		3701588	Jacumba Valley Ranch Water Company	25		1
3100	Total Coliform-routine monitoring		3701594	Featherstone Canyon Christian Camp	50		1
1040	Nitrate as (NO ₃)		3701780	Richardson Beardsley Inc.	38		1
3100	Total Coliform-routine monitoring		3701780				3
7000	Consumer Confidence Report		3701793	Twin Lakes Resort	200		1
3100	Total Coliform-routine monitoring		3701837	Wynola Water District	120		3
1040	Nitrate as (NO ₃)		3701934	Pine Valley Bible Conference Center	38		1
1040	Nitrate as (NO ₃)		3701982	Palomar Christian Conference Center	325		1
3100	Total Coliform-routine monitoring		3701983	Dudley'S Bakery	100		1
1040	Nitrate as (NO ₃)		3701988	Alpine Oaks Mobile Estates	125		1
7000	Consumer Confidence Report		3701988				1
1040	Nitrate as (NO ₃)		3701995	Willowside Terrace Water Association	100		1
3100	Total Coliform-routine monitoring		3702059	Skyline Ranch Campgrounds & RV Park	38		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
1040	Nitrate as (NO ₃)		3702181	K.Q. Ranch Camping Resort	650		1
1040	Nitrate as (NO ₃)		3702235	Mobiland Camper Park	320		1
3100	Total Coliform-routine monitoring		3702235				1
3100	Total Coliform-routine monitoring		3702236	Palomar Observatory	25		1
1040	Nitrate as (NO ₃)		3702253	Dulzura Cafe	50		1
3100	Total Coliform-routine monitoring		3702283	Mt. Laguna Improv. Assn.	100		2
3100	Total Coliform-routine monitoring		3702302	Desert Ironwoods Resort Inc.	25		1
1040	Nitrate as (NO ₃)		3702319	Camp Winacka	250		1
1040	Nitrate as (NO ₃)		3702349	Rancho L'Abri	25		1
3100	Total Coliform-routine monitoring		3702349				1
3100	Total Coliform-routine monitoring		3702420	Stagecoach Trails Resort	695		1
1040	Nitrate as (NO ₃)		3702459	Camp Oliver	70		1
1040	Nitrate as (NO ₃)		3702479	Ranch Feed & Supply	50		1
3100	Total Coliform-routine monitoring		3702479				1
3100	Total Coliform-routine monitoring		3702494	Chef's Hat Restaurant	250		1
3100	Total Coliform-routine monitoring		3702530	Camp Cedar Glen	100		1
3100	Total Coliform-routine monitoring		3702703	De Anza Springs Resort	300		1
3100	Total Coliform-routine monitoring		3702706	Highland East Trailer Park	25		1
1040	Nitrate as (NO ₃)		3702754	Rancho Corrido Campground	300		1
3100	Total Coliform-routine monitoring		3702757	Barrett Junction Cafe, Inc.	25		1
1040	Nitrate as (NO ₃)		3705026	Erreca'S Associates	25		1
3100	Total Coliform-routine monitoring		3705046	Amerimex Market	50		1
3100	Total Coliform-routine monitoring		3710302	Anza Borrego Sp - Palm Canyon	18		1
3100	Total Coliform-routine monitoring		3710306	Anza Borrego Sp - Tamarisk Grove	146		1
San Joaquin County							
7000	Consumer Confidence Report		3900511	Sjc Micke Grove Park	1000		1
7000	Consumer Confidence Report		3900555	Banta Mutual Water Co #1	81		1
7000	Consumer Confidence Report		3900556	Banta Mutual Water Co #2	42		1
3100	Total Coliform-routine monitoring		3900557	Banta Mutual Water Co #3	75		1
7000	Consumer Confidence Report		3900557				1
7000	Consumer Confidence Report		3900559	Wine Country Apartments	40		1
7000	Consumer Confidence Report		3900561	Lodi Lake Mobile Home Park	104		1
7000	Consumer Confidence Report		3900568	Caribou Mobile Park PWS	180		1
3100	Total Coliform-routine monitoring		3900575	Donald'S	36		2
7000	Consumer Confidence Report		3900579	Century Mobile Home Park	50		1
7000	Consumer Confidence Report		3900586	Sycamore Mobile Home Park	50		1
3100	Total Coliform-routine monitoring		3900592	Town & Country Inn	55		1
7000	Consumer Confidence Report		3900602	Tahama Village Mobile Home Prk	200		1
7000	Consumer Confidence Report		3900603	Leisure Manor	100		1
3100	Total Coliform-routine monitoring		3900607	Country Squire Mobile Estates	64		1
3100	Total Coliform-routine monitoring		3900616	Windmill Cove Marina & RV Park	50		2
7000	Consumer Confidence Report		3900624	West Lane Mobile Home Park	160		1
7000	Consumer Confidence Report		3900649	Glenwood Mobile Home Park	100		1
3100	Total Coliform-routine monitoring		3900651	Lost Isle Resort	25		1
7000	Consumer Confidence Report		3900661	Mapache Trailer Park	275		1
3100	Total Coliform-routine monitoring		3900666	King Island Marina PWS	1000		2
7000	Consumer Confidence Report		3900701	Currier Estates Water Corp	148		1
7000	Consumer Confidence Report		3900705	Finnlee'S Trailer Park	55		1
7000	Consumer Confidence Report		3900711	A & J Mobil Park	75		1
7000	Consumer Confidence Report		3900719	Mokelumne MeadoWS Trailer Park	55		1
7000	Consumer Confidence Report		3900721	Woodbridge Mobile Estates	110		1
7000	Consumer Confidence Report		3900726	Bentley Trailer Court	84		1
7000	Consumer Confidence Report		3900732	V & P Trailer Court	35		1
7000	Consumer Confidence Report		3900733	Country Club Vista	75		1
7000	Consumer Confidence Report		3900742	J-M Manufacturing Co Inc	100		1
7000	Consumer Confidence Report		3900755	Shady Rest Trailer Court	120		1
7000	Consumer Confidence Report		3900762	Riverside Mobile Home Park	55		1
7000	Consumer Confidence Report		3900763	Wimpy'S Marina	70		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
7000	Consumer Confidence Report		3900768	Paradise Point Marina	200		1
7000	Consumer Confidence Report		3900779	Sj County Mental Retardation Ctr	65		1
7000	Consumer Confidence Report		3900796	Btqc-Escalon	110		1
7000	Consumer Confidence Report		3900805	Morehead Park	300		1
7000	Consumer Confidence Report		3900825	Owens Brockway	280		1
7000	Consumer Confidence Report		3900835	Wayside Apartments	70		1
7000	Consumer Confidence Report		3900837	Lodi Homes	39		1
7000	Consumer Confidence Report		3900839	Mokelumne River School	204		1
7000	Consumer Confidence Report		3900846	Oak View Union Elementary Sch	350		1
7000	Consumer Confidence Report		3900848	Lodi Usd-Tokay Colony School	166		1
7000	Consumer Confidence Report		3900849	Lodi Usd-Live Oak School	100		1
7000	Consumer Confidence Report		3900850	Lodi Usd-Houston School*	405		1
7000	Consumer Confidence Report		3900907	Bel Air Mobile Estate	150		1
7000	Consumer Confidence Report		3900921	Cardoza Villa Corp	30		1
7000	Consumer Confidence Report		3900964	Sahara Mobile Court	300		1
7000	Consumer Confidence Report		3900972	Lodi Usd-Elkhorn School	200		1
7000	Consumer Confidence Report		3900983	Cherry Lane Trailer Park	100		1
7000	Consumer Confidence Report		3900991	La Torres Park	40		1
7000	Consumer Confidence Report		3900993	New Jerusalem School	210		1
7000	Consumer Confidence Report		3901032	Lodi Usd-Turner School	200		1
7000	Consumer Confidence Report		3901035	Lodi Usd-Henderson School	200		1
7000	Consumer Confidence Report		3901074	Twin Oaks Mobile Park	255		1
7000	Consumer Confidence Report		3901080	Alpine Packing Co	270		1
7000	Consumer Confidence Report		3901081	Mobile Villas Trailer Park	130		1
7000	Consumer Confidence Report		3901085	Lodi Usd-Davis School	630		1
7000	Consumer Confidence Report		3901109	Lodi Usd-Morada Middle School	435		1
7000	Consumer Confidence Report		3901121	Morada Shopping Center	100		1
7000	Consumer Confidence Report		3901167	Escalon Usd-Van Allen School	200		1
7000	Consumer Confidence Report		3901179	Lodi Wine & Business Center	61		1
7000	Consumer Confidence Report		3901181	Ameron International	100		1
7000	Consumer Confidence Report		3901194	Valimet Inc	60		1
7000	Consumer Confidence Report		3901196	Mainland Nursery Inc	50		1
7000	Consumer Confidence Report		3901197	Oak Ridge Winery, Llc	50		1
3100	Total Coliform-routine monitoring		3901198	Yosemite Inn - PWS	50		2
7000	Consumer Confidence Report		3901204	Diamond Pet Food	35		1
7000	Consumer Confidence Report		3901209	St Marys High School	950		1
7000	Consumer Confidence Report		3901215	San Juan Vista	100		1
3100	Total Coliform-routine monitoring		3901238	Mokelumne Beach Rv Park	30		1
7000	Consumer Confidence Report		3901245	California Fruit Processors	150		1
3100	Total Coliform-routine monitoring		3901249	3 B'S Truck & Auto Plaza	1000		3
3100	Total Coliform-routine monitoring		3901252	Waterloo California Restaurant	25		1
3100	Total Coliform-followup monitoring		3901252				1
7000	Consumer Confidence Report		3901256	South San Joaquin Education Center	100		1
7000	Consumer Confidence Report		3901278	Color Spot, Lodi	30		1
7000	Consumer Confidence Report		3901281	First Baptist Church Of Stkn	200		1
7000	Consumer Confidence Report		3901286	Victorian Park Water Service	30		1
7000	Consumer Confidence Report		3901290	Fisher Nursery	50		1
3100	Total Coliform-routine monitoring		3901296	Italian Athletic Club	50		1
7000	Consumer Confidence Report		3901309	Pacific Triple E Ltd	50		1
7000	Consumer Confidence Report		3901319	International Paper	40		1
3100	Total Coliform-routine monitoring		3901341	Raudel Delgado Water System	50		1
7000	Consumer Confidence Report		3901347	Ripon Farm Service	26		1
7000	Consumer Confidence Report		3901349	Sierra Hills Packing	40		1
7000	Consumer Confidence Report		3901354	Pearce, Jeff H 39-40	30		1
3100	Total Coliform-routine monitoring		3901361	Backspin Golf Center	1000		1
3100	Total Coliform-followup monitoring		3901361				1
7000	Consumer Confidence Report		3901368	The Scotts/Hyponex Co	50		1
7000	Consumer Confidence Report		3901374	Holt Union Esd-Holt School	100		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
7000	Consumer Confidence Report		3901375	Pilkington North America, Inc	25		1
7000	Consumer Confidence Report		3901378	San-I-Pak Inc	25		1
7000	Consumer Confidence Report		3901382	O-G Packing Co	25		1
7000	Consumer Confidence Report		3901387	Stockton Baptist Church	25		1
7000	Consumer Confidence Report		3901392	Enviroplex, Inc	25		1
3100	Total Coliform-followup monitoring		3901394	Calva Products Co Inc	30		1
3100	Total Coliform-routine monitoring		3901396	Beneto Water System	30		1
7000	Consumer Confidence Report		3901405	Insulair, Inc	25		1
7000	Consumer Confidence Report		3901407	Burlington Northern Santa Fe	25		1
7000	Consumer Confidence Report		3901414	Wastequip Mclaughlin	25		1
3100	Total Coliform-routine monitoring		3901418	Austin Industrial Park	25		1
7000	Consumer Confidence Report		3901421	Viejo Ltd	163		1
3100	Total Coliform-routine monitoring		3901422	St Michael'S Water System	25		1
7000	Consumer Confidence Report		3901422				1
7000	Consumer Confidence Report		3901425	Morada Produce Water System	25		1
3100	Total Coliform-routine monitoring		3901427	Buon Giardino	25		1
3100	Total Coliform-routine monitoring		3901446	Amorosa Inn & Gardens Llc	25		1
3100	Total Coliform-routine monitoring		3901447	Old River Golf Course	25		2
5000	LCR - Routine&followup monitoring		3910015	City Of Lathrop	12427		1
San Luis Obispo County							
3100	Total Coliform-routine monitoring		4000203	Irish Hills Mutual Water Co	10		1
3100	Total Coliform-routine monitoring		4000211	Greenheart Farms	50		1
3100	Total Coliform-routine monitoring		4000213	Toyota San Luis Obispo	35		1
7000	Consumer Confidence Report		4000214	Baron Canyon Mutual Water Co.	25		1
3100	Total Coliform-routine monitoring		4000215	Williams Water Co	30		1
7000	Consumer Confidence Report		4000216	Tank Farm Business Park	45		1
3100	Total Coliform-routine monitoring		4000219	Links At Vista Del Hombre, The	25		1
3100	Total Coliform-routine monitoring		4000221	Laetitia Vineyard & Winery Inc	25		1
3100	Total Coliform-routine monitoring		4000226	Pacific Dunes Ranch	40		1
3100	Total Coliform-routine monitoring		4000300	Arciero Winery	28		2
7000	Consumer Confidence Report		4000555	Guadalupe Cooling Company	35		1
7000	Consumer Confidence Report		4000563	Higuera Apartments	30		1
3100	Total Coliform-routine monitoring		4000568	San Simeon Csd	499		1
3100	Total Coliform-routine monitoring		4000590	Water World Resorts-Lake Nacimiento	1000		2
7000	Consumer Confidence Report		4000590				1
7000	Consumer Confidence Report		4000598	Cuyama Lane Water Company	25		1
3100	Total Coliform-routine monitoring		4000637	Country Hills Estates	60		1
7000	Consumer Confidence Report		4000637				1
3100	Total Coliform-routine monitoring		4000643	Black Mountain R.V. Resort	35		1
7000	Consumer Confidence Report		4000665	Morro Bay Mutual Water Co	100		1
3100	Total Coliform-routine monitoring		4000673	Jack Ranch Cafe	30		1
3100	Total Coliform-routine monitoring		4000705	Laguna Negra Mutual Water Co.	80		2
3100	Total Coliform-routine monitoring		4000730	Holdgrafer & Associates	30		2
3100	Total Coliform-routine monitoring		4000741	H2O, Inc	60		1
3100	Total Coliform-routine monitoring		4000744	Afuera De Chorro Water Company	75		1
3100	Total Coliform-routine monitoring		4000749	Terra De Oro Water Company	35		2
3100	Total Coliform-routine monitoring		4000750	Rim Rock Water Company	55		1
3100	Total Coliform-routine monitoring		4000751	Ernie Ball, Inc	300		1
3100	Total Coliform-routine monitoring		4000757	Cerro Alto Campground	30		1
3100	Total Coliform-routine monitoring		4000765	Varian Ranch	120		1
3100	Total Coliform-routine monitoring		4000771	Rancho Nipomo Water Company	65		1
7000	Consumer Confidence Report		4000771				1
3100	Total Coliform-routine monitoring		4000781	Meridian Vineyards	30		1
3100	Total Coliform-routine monitoring		4000804	Whispering MeadoWS - Butterfly Lane	45		1
San Mateo County							
3100	Total Coliform-routine monitoring		4100504	Webb Ranch	25		1
3100	Total Coliform-routine monitoring		4100512	Loma Mar Mutual	108		1
5000	LCR - Routine&followup monitoring		4100517	Menlo College	1500		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
1040	Nitrate as (NO ₃)		4100532	Cutter Scout Reservation	25		1
0200	SWTR-filtered sys-monitoring (36)		4100533	Skylonda Mutual	431		2
5000	LCR - Initial monitoring		4100537	Silva Wholesale Florist	30		1
2456	Haloacetic Acids (HAA-5)		4100546	Woodside Mutual	195		1
2950	Total Trihalomethanes (TTHMs)		4100546				1
1040	Nitrate as (NO ₃)		4100555	Portola Improvement Association	74		1
2218	Trichlorofluoromethane		4100555				1
2378	1,2,4-Trichlorobenzene		4100555				1
2380	Cis-1,2-Dichloroethylene		4100555				1
2413	1,3-Dichloropropene (Total)		4100555				1
2904	1,1,2-Trichloro-1,2,2-Trifluoroethane		4100555				1
2955	Xylenes (Total)		4100555				1
2964	Dichloromethane		4100555				1
2967	1,2-Dichlorobenzene		4100555				1
2969	1,4-Dichlorobenzene		4100555				1
2976	Vinyl Chloride		4100555				1
2977	1,1-Dichloroethylene		4100555				1
2978	1,1-Dichloroethane		4100555				1
2979	Trans-1,2-Dichloroethylene		4100555				1
2980	1,2-Dichloroethane		4100555				1
2981	1,1,1-Trichloroethane		4100555				1
2982	Carbon Tetrachloride		4100555				1
2983	1,2-Dichloropropane		4100555				1
2984	Trichloroethylene		4100555				1
2985	1,1,2-Trichloroethane		4100555				1
2987	Tetrachloroethylene		4100555				1
2988	1,1,2,2-Tetrachloroethane		4100555				1
2989	Monochlorobenzene		4100555				1
2990	Benzene		4100555				1
2991	Toluene		4100555				1
2992	Ethylbenzene		4100555				1
2996	Styrene		4100555				1
3100	Total Coliform-routine monitoring		4100603	Costanoa Campground	25		2
Santa Barbara County							
7000	Consumer Confidence Report		4210003	Guadalupe Water Department	5659		1
3100	Total Coliform-followup monitoring		4210018	Buellton Water Department	4000		1
Santa Clara County							
3100	Total Coliform-routine monitoring		4300808	O'Connor Hospital	2500		1
2456	Haloacetic Acids (HAA-5)		4310800	AgneWS Dev. Center - East Campus	1830		1
2950	Total Trihalomethanes (TTHMs)		4310800				1
Santa Cruz County							
3100	Total Coliform-routine monitoring		4400502	Mar Vista Water Company Inc	584		1
3100	Total Coliform-routine monitoring		4400526	Big Redwood Park Water	215		1
3100	Total Coliform-routine monitoring		4400528	Laurel Community League	69		1
3100	Total Coliform-routine monitoring		4400530	Land Of Medicine Buddha	75		1
3100	Total Coliform-routine monitoring		4400570	Mountain Summit Mutual Water System	30		1
3100	Total Coliform-routine monitoring		4400582	Pine Tree Lane Mutual Water Co	40		1
3100	Total Coliform-routine monitoring		4400597	La Madrona Swim & Racquet Club	100		1
3100	Total Coliform-routine monitoring		4400605	Crestwood Heights Water Assn	142		1
3100	Total Coliform-routine monitoring		4400613	Las Colinas Road & Water Assn	69		1
3100	Total Coliform-routine monitoring		4400624	Rancho Corralitos	50		1
3100	Total Coliform-routine monitoring		4400631	Las Cumbres Mutual Water Co	250		1
3100	Total Coliform-routine monitoring		4400645	Hidden Meadow Mutual Water Co	37		1
3100	Total Coliform-followup monitoring		4400652	Cathedral Hills MWC, Inc	50		1
3100	Total Coliform-routine monitoring		4400659	Potbelly Beach Club	60		1
3100	Total Coliform-followup monitoring		4400665	Meadowridge Mutual Water Co	25		2
3100	Total Coliform-followup monitoring		4400701	Quaker Center	65		1
3100	Total Coliform-routine monitoring		4400707	Camp Lindblad	125		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		4400711	Camp Chesebrough	150		1
3100	Total Coliform-routine monitoring		4400721	Skylark Ranch Girl Scout Camp	99		1
3100	Total Coliform-routine monitoring		4400723	Mission Springs Conference Center	564		1
3100	Total Coliform-routine monitoring		4400807	Mount Madonna Inn Restaurant	100		1
3100	Total Coliform-followup monitoring		4400823	Spring Hills Golf Course	55		1
0999	Stage 1 - DBP (Chlorine)		4410001	Big Basin Water Company	1600		1
4000	Gross Alpha		4410002	Cal-Am Water Company - Felton	4340		1
2984	Trichloroethylene		4410014	San Lorenzo Valley Water Dist	19000		1
0999	Stage 1 - DBP (Chlorine)		4410016	Forest Lakes MWC	1141		1
3100	Total Coliform-routine monitoring		4410800	Ben Lomond Camp	110		1
0999	Stage 1 - DBP (Chlorine)		4410800				1
Shasta County							
3100	Total Coliform-routine monitoring		4500011	Andreini Business Park Water System	130		1
3100	Total Coliform-routine monitoring		4500035	Siskiyou Forest Products	75		1
3100	Total Coliform-followup monitoring		4500061	Pg&E - Cassel Campground	80		1
3100	Total Coliform-routine monitoring		4500076	E & G Resort	35		2
3100	Total Coliform-routine monitoring		4500083	Pg&E - Mccumber Campground	60		3
3100	Total Coliform-routine monitoring		4500086	Pg&E - Northshore Campground	75		3
3100	Total Coliform-routine monitoring		4500098	Shady Hill Mobile Home Park	35		1
3100	Total Coliform-routine monitoring		4500100	Shasta Marina Resort	235		1
3100	Total Coliform-routine monitoring		4500110	Silverthorn Resort	175		1
3100	Total Coliform-routine monitoring		4500136	Klub Klondike	35		1
3100	Total Coliform-routine monitoring		4500153	Shasta District Fair	10200		1
3100	Total Coliform-routine monitoring		4500213	Jolly Giant Flea Market	75		1
3100	Total Coliform-routine monitoring		4500214	West Valley High School	1100		1
3100	Total Coliform-routine monitoring		4500224	Basshole	30		1
3100	Total Coliform-routine monitoring		4500227	Crystal Creek Regional Boy's Camp	75		1
3100	Total Coliform-routine monitoring		4500283	Caltrans-Hillcrest SRRA	2500		1
3100	Total Coliform-routine monitoring		4500289	Caltrans-Shingletown SRRA	270		1
3100	Total Coliform-routine monitoring		4500325	Lassen Pines Christian Conference Center	300		1
3100	Total Coliform-routine monitoring		4500333	Airport Planet Water	35		1
3100	Total Coliform-routine monitoring		4500334	Rainbow'S End Mobile Home Park	38		1
Sierra County							
3100	Total Coliform-routine monitoring		4600058	Coyoteville	65		1
Siskiyou County							
3100	Total Coliform-routine monitoring		4700521	Siskiyou Co.Service Area #5/Carrick	142		1
3100	Total Coliform-routine monitoring		4700539	Macdoel Waterworks	35		1
3100	Total Coliform-routine monitoring		4700569	Willow Creek School	100		1
3100	Total Coliform-routine monitoring		4700585	Junction Elementary School	40		1
3100	Total Coliform-routine monitoring		4700591	Delphic Elementary School	50		1
3100	Total Coliform-routine monitoring		4700663	Weed Golf Club, Inc.	110		1
3100	Total Coliform-routine monitoring		4700847	Quartz Valley School	60		1
3100	Total Coliform-routine monitoring		4710009	City Of Weed	2963		1
Sonoma County							
3100	Total Coliform-followup monitoring		4900107	Alexander Valley Store/Bar	25		1
2456	Haloacetic Acids (HAA-5)		4900536	Occidental Community Services District	150		1
2950	Total Trihalomethanes (TTHMs)		4900536				1
2456	Haloacetic Acids (HAA-5)		4900548	Holland Heights Mutual Water Company	300		1
2950	Total Trihalomethanes (TTHMs)		4900548				1
2456	Haloacetic Acids (HAA-5)		4900551	Melita Heights Mutual Water Company	60		1
2950	Total Trihalomethanes (TTHMs)		4900551				1
3100	Total Coliform-routine monitoring		4900552	Michele Mutual Water Company	170		1
2456	Haloacetic Acids (HAA-5)		4900553	Park Royal Mutual Water	75		1
2950	Total Trihalomethanes (TTHMs)		4900553				1
3100	Total Coliform-routine monitoring		4900568	Valley Ford Water Association	40		1
2456	Haloacetic Acids (HAA-5)		4900568				1
2950	Total Trihalomethanes (TTHMs)		4900568				1
2456	Haloacetic Acids (HAA-5)		4900570	Palomino Lakes Mutual Water Co.	340		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
2950	Total Trihalomethanes (TTHMs)		4900570				1
2456	Haloacetic Acids (HAA-5)		4900587	Brand Water Company	100		1
2950	Total Trihalomethanes (TTHMs)		4900587				1
2456	Haloacetic Acids (HAA-5)		4900620	Austin Acres Mutual Water Company	78		1
2950	Total Trihalomethanes (TTHMs)		4900620				1
3100	Total Coliform-routine monitoring		4900640	Sonoma County Mutual Water Company	40		1
3100	Total Coliform-routine monitoring		4900702	Pacific Christian Academy	84		1
2456	Haloacetic Acids (HAA-5)		4900702				1
2950	Total Trihalomethanes (TTHMs)		4900702				1
2456	Haloacetic Acids (HAA-5)		4900707	Twin Hills School Dist-Twin Hills School	440		1
2950	Total Trihalomethanes (TTHMs)		4900707				1
2456	Haloacetic Acids (HAA-5)		4900710	Twin Hills School Dist-Apple Blossom Sch	600		1
2950	Total Trihalomethanes (TTHMs)		4900710				1
3100	Total Coliform-routine monitoring		4900720	Mobile Home Estates	320		1
5000	LCR - Initial monitoring		4900720				1
7000	Consumer Confidence Report		4900720				1
2456	Haloacetic Acids (HAA-5)		4900786	Rancho Santa Rosa MHP	175		1
2950	Total Trihalomethanes (TTHMs)		4900786				1
2456	Haloacetic Acids (HAA-5)		4900788	El Crystal Mobile Home Park	130		1
2950	Total Trihalomethanes (TTHMs)		4900788				1
3100	Total Coliform-routine monitoring		4900791	Western Mobile Home Park	225		1
2456	Haloacetic Acids (HAA-5)		4900791				1
2950	Total Trihalomethanes (TTHMs)		4900791				1
2456	Haloacetic Acids (HAA-5)		4900797	North Star Mobile Home Park	75		1
2950	Total Trihalomethanes (TTHMs)		4900797				1
3100	Total Coliform-routine monitoring		4900799	El Portal Mobile Estates	200		2
2456	Haloacetic Acids (HAA-5)		4900799				1
2950	Total Trihalomethanes (TTHMs)		4900799				1
2456	Haloacetic Acids (HAA-5)		4900800	Mark West Estates	60		1
2950	Total Trihalomethanes (TTHMs)		4900800				1
2456	Haloacetic Acids (HAA-5)		4900815	Days Inn	300		1
2950	Total Trihalomethanes (TTHMs)		4900815				1
3100	Total Coliform-routine monitoring		4900905	Mark West Meadows Mutual Water	70		1
2456	Haloacetic Acids (HAA-5)		4900907	Summerfield Waldorf School	400		1
2950	Total Trihalomethanes (TTHMs)		4900907				1
3100	Total Coliform-routine monitoring		4900911	Blackstone Winery	50		1
2456	Haloacetic Acids (HAA-5)		4900918	Sonoma Mission Apartments	100		1
2950	Total Trihalomethanes (TTHMs)		4900918				1
3100	Total Coliform-routine monitoring		4900940	Petaluma Mushroom Farm, Inc.	40		1
2456	Haloacetic Acids (HAA-5)		4901005	Todd Road Mutual Water Company	25		1
2950	Total Trihalomethanes (TTHMs)		4901005				1
3100	Total Coliform-routine monitoring		4901101	Mount Gilead Bible Conference	85		1
3100	Total Coliform-routine monitoring		4901120	Roche Winery	25		2
3100	Total Coliform-routine monitoring		4901129	Viansa Winery	200		1
3100	Total Coliform-routine monitoring		4901151	Schug Cellars	25		1
3100	Total Coliform-followup monitoring		4901162	Quivira Vineyards	60		1
3100	Total Coliform-routine monitoring		4901179	Redwood Empire Sawmill	80		1
3100	Total Coliform-routine monitoring		4901193	Schellville Grill	50		1
3100	Total Coliform-followup monitoring		4901218	Groskopf Warehouse, Inc.	30		1
3100	Total Coliform-followup monitoring		4901253	Belvedere Vineyards & Winery	28		1
2456	Haloacetic Acids (HAA-5)		4901257	Capital Lumber Company	50		1
2950	Total Trihalomethanes (TTHMs)		4901257				1
3100	Total Coliform-routine monitoring		4901262	Ravenswood (Quarry) Winery	25		1
2456	Haloacetic Acids (HAA-5)		4910002	Cloverdale, City Of	8200		1
2950	Total Trihalomethanes (TTHMs)		4910002				1
2456	Haloacetic Acids (HAA-5)		4910006	Petaluma, City Of	55900		1
2456	Haloacetic Acids (HAA-5)		4910026	Odd Fellows Recreation Club	103		1
2950	Total Trihalomethanes (TTHMs)		4910026				1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		4910701	U.S. Coast Guard Training Center	1350		1
Stanislaus County							
3100	Total Coliform-routine monitoring		5000106	City Of Oakdale Airport Water System	25		1
1040	Nitrate as (NO ₃)		5000109	Ceres Unified/Westport School	100		1
3100	Total Coliform-routine monitoring		5000139	Durango'S/Owner: Leonardo Lopez	26		1
3100	Total Coliform-routine monitoring		5000272	City Of Oakdale - Kerr Park	26		1
5000	LCR - Routine&followup monitoring		5000427	Covanta Stanislaus, Inc (Stan. Waste Ene	25		1
3100	Total Coliform-routine monitoring		5000430	City Of Oakdale Treatment Plant-Water Qu	25		1
7000	Consumer Confidence Report		5010039	Western Hills Water District/Diablo Gran	3000		1
Sutter County							
1040	Nitrate as (NO ₃)		5100117	National American Corp. Lp-Lake Minden	1000		1
3100	Total Coliform-routine monitoring		5100120	Roll-A-Home Mobile H.P.	150		1
3100	Total Coliform-routine monitoring		5101007	Country Village North MHP	26		2
1040	Nitrate as (NO ₃)		5103325	South Ridge Golf Course	25		1
Tehama County							
7000	Consumer Confidence Report		5200521	Antelope Creek MHP	90		1
3100	Total Coliform-routine monitoring		5200534	Paskenta Comm. Services Dist.	120		1
3100	Total Coliform-routine monitoring		5200606	Tehama Co.-Cone Grove Park	25		1
3100	Total Coliform-routine monitoring		5200608	Tehama Co.-River Park	25		1
3100	Total Coliform-routine monitoring		5200642	Tehama Co.-Ridgeway Park	25		1
3100	Total Coliform-routine monitoring		5200653	Tehama Co.-Mill Creek Park	25		1
7000	Consumer Confidence Report		5201137	Millstream Mobile Home Park	53		1
Trinity County							
3100	Total Coliform-routine monitoring		5301018	Trinity Alps Marina	75		3
3100	Total Coliform-followup monitoring		5301103	Covington Mill - A	55		1
3100	Total Coliform-followup monitoring		5301104	Trinity Lake Forest	50		2
3100	Total Coliform-followup monitoring		5301201	Seymour's Mutual Water System	25		1
3100	Total Coliform-followup monitoring		5301205	Coffee Creek Ranch	50		1
3100	Total Coliform-routine monitoring		5304502	Salyer Heights W.S., Inc	82		3
Tulare County							
3100	Total Coliform-routine monitoring		5400509	Panorama Heights Prop Owners	100		1
2931	Dibromochloropropane (DBCP)		5400526	Enns Packing Co	50		3
3100	Total Coliform-routine monitoring		5400529	Shady Grove M.H.P.	137		4
3100	Total Coliform-routine monitoring		5400536	Kings River Estates	100		1
7000	Consumer Confidence Report		5400536				1
1040	Nitrate as (NO ₃)		5400542	Ducor C.S.D.	500		1
3100	Total Coliform-routine monitoring		5400552	Stoney Creek	42		1
3100	Total Coliform-routine monitoring		5400553	Traver Water Llc	500		2
7000	Consumer Confidence Report		5400553				1
3100	Total Coliform-routine monitoring		5400555	Citrus South Tule School	34		1
3100	Total Coliform-routine monitoring		5400563	Country Manor M.H.P.	250		1
3100	Total Coliform-routine monitoring		5400567	Tooleville Water Co.	300		1
3100	Total Coliform-routine monitoring		5400581	Spear Creek Cabin Owners Assoc	52		1
3100	Total Coliform-routine monitoring		5400611	Porterville Trailer Park	80		3
1040	Nitrate as (NO ₃)		5400628	Lemon Cove-Sequoia Camp	100		1
3100	Total Coliform-routine monitoring		5400634	Lovell School	60		3
3100	Total Coliform-routine monitoring		5400636	Orosi High School	900		3
3100	Total Coliform-routine monitoring		5400638	Sierra School	40		2
0200	SWTR-filtered sys-monitoring (36)		5400644	Sequoia Village Inn	35		1
1040	Nitrate as (NO ₃)		5400660	Lake Success Mobile Lodge	20		1
1040	Nitrate as (NO ₃)		5400666	Watertek - Grandview Gardens	350		1
3100	Total Coliform-routine monitoring		5400687	Orange Blossom Junction	100		1
3100	Total Coliform-routine monitoring		5400695	Army Corps Engs-South Camp	100		1
3100	Total Coliform-routine monitoring		5400696	Army Corps Engs-North Camp	25		1
3100	Total Coliform-routine monitoring		5400699	Kaweah High School	110		2
1040	Nitrate as (NO ₃)		5400709	Sequoia Union School	400		1
1040	Nitrate as (NO ₃)		5400711	Sierra View Jr Academy	160		2
3100	Total Coliform-routine monitoring		5400722	Sugarloaf Mutual Water Co.	38		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
3100	Total Coliform-routine monitoring		5400724	Panorama Park Fire Pro. Co.	90		1
3100	Total Coliform-routine monitoring		5400761	Lake Elowin Resort	40		1
3100	Total Coliform-routine monitoring		5400778	Scicon	21		2
1040	Nitrate as (NO ₃)		5400795	Waukena Elementary School	230		1
3100	Total Coliform-routine monitoring		5400797	Tulare Co Correctional Center	300		1
1040	Nitrate as (NO ₃)		5400810	Akal Travel Plaza	200		1
3100	Total Coliform-routine monitoring		5400816	Bedel Mutual Water Co.	155		1
7000	Consumer Confidence Report		5400816				1
3100	Total Coliform-routine monitoring		5400819	Mountain View M.H.P.	44		2
3100	Total Coliform-routine monitoring		5400824	Sultana C.S.D.	650		3
3100	Total Coliform-routine monitoring		5400850	Packwood School	30		1
7000	Consumer Confidence Report		5400886	Columbine School	160		1
1040	Nitrate as (NO ₃)		5400918	Open Country Flea Mart	300		2
1040	Nitrate as (NO ₃)		5400931	Truckers Mini Mart	25		1
3100	Total Coliform-routine monitoring		5400931				1
0200	SWTR-filtered sys-monitoring (36)		5400968	Improvement Dist #1	480		1
3100	Total Coliform-routine monitoring		5400975	The Seafood Cafe	50		1
3100	Total Coliform-routine monitoring		5400985	Bob's Tiny Mart	25		1
1040	Nitrate as (NO ₃)		5400986	Deer Creek Lodge	46		1
3100	Total Coliform-routine monitoring		5400986				2
1040	Nitrate as (NO ₃)		5400987	Fountain Springs El Tapatio	25		1
3100	Total Coliform-routine monitoring		5401001	Sequoia Cider Mill	30		2
1040	Nitrate as (NO ₃)		5401003	East Orosi C.S.D.	106		3
3100	Total Coliform-routine monitoring		5401003				1
7000	Consumer Confidence Report		5401006	Uc Davis-Vet School	40		1
1040	Nitrate as (NO ₃)		5401038	Akin Water Co.	50		2
3100	Total Coliform-routine monitoring		5401039	Tulare County Civic Center	300		1
0200	SWTR-filtered sys-monitoring (36)		5401071	Silver City Water Co.	128		2
3100	Total Coliform-routine monitoring		5401074	Bob Wiley Detention Facility	575		1
7000	Consumer Confidence Report		5401082	Ventura Coastal Corp.	35		1
0200	SWTR-filtered sys-monitoring (36)		5401085	Main Fork Bistro	100		1
3100	Total Coliform-routine monitoring		5401096	Sun Pacific-Woodlake	95		3
7000	Consumer Confidence Report		5401096				1
3100	Total Coliform-routine monitoring		5402008	Hot Springs School	42		2
3100	Total Coliform-routine monitoring		5402013	Sun Pacific-Exeter	200		3
7000	Consumer Confidence Report		5402013				1
1040	Nitrate as (NO ₃)		5402024	Kings River Market	25		2
1040	Nitrate as (NO ₃)		5402025	Lakeside Minnit Mart	25		1
7000	Consumer Confidence Report		5402027	Tulare County Road Yard #2	60		1
3100	Total Coliform-routine monitoring		5402037	Three Rivers Library	80		1
7000	Consumer Confidence Report		5402046	Sun Pacific-Tulare	225		1
1040	Nitrate as (NO ₃)		5402047	Gleanings For The Hungry	31		2
3100	Total Coliform-routine monitoring		5402055	Camp Keep Sierra	110		1
1040	Nitrate as (NO ₃)		5402056	Peoples Grocery	25		1
1040	Nitrate as (NO ₃)		5403013	Prince Mart	25		1
3100	Total Coliform-routine monitoring		5403013				1
3100	Total Coliform-routine monitoring		5403023	Delft Colony Water	400		1
1040	Nitrate as (NO ₃)		5403030	Foothill Fruit Co.	50		2
7000	Consumer Confidence Report		5403031	Kraft - Tulare So.	250		1
3100	Total Coliform-routine monitoring		5403043	Yetterm Water System	350		1
3100	Total Coliform-routine monitoring		5403053	NS Mini Mart	140		2
0200	SWTR-filtered sys-monitoring (36)		5403061	River View Restaurant	50		2
3100	Total Coliform-routine monitoring		5403072	Rogers Camp Homeowners Assn.	25		1
7000	Consumer Confidence Report		5403074	Kraft - Tulare So.	130		1
3100	Total Coliform-routine monitoring		5403084	Fairway Mutual Water Co	53		1
4006	Uranium		5403103	Tract 327 Mutual Water Co.	24		3
3100	Total Coliform-followup monitoring		5403103				1
1040	Nitrate as (NO ₃)		5403106	Lo Bue Bros.	99		1

Appendix C

State Of California 2005 Annual Compliance Report

Table C

Contaminant		MCL ^(a) (mg/L)	Public Water System			No. of MCL Violations	No. of Monitoring Violations
Code	Name		Number	Name	Population		
2456	Haloacetic Acids (HAA-5)		5410007	Lsid - Tonyville	400		1
2950	Total Trihalomethanes (TTHMs)		5410007				1
3100	Total Coliform-routine monitoring		5410033	Pratt Mutual Water Co	1600		3
2456	Haloacetic Acids (HAA-5)		5410033				1
2950	Total Trihalomethanes (TTHMs)		5410033				1
2456	Haloacetic Acids (HAA-5)		5410039	Plainview Mutual Water Company	1000		1
2950	Total Trihalomethanes (TTHMs)		5410039				1
2456	Haloacetic Acids (HAA-5)		5410502	SNP-Lodgepole	35		1
2950	Total Trihalomethanes (TTHMs)		5410502				1
Tuolumne County							
3100	Total Coliform-followup monitoring		5500145	San Jose Family Camp	200		1
3100	Total Coliform-followup monitoring		5500363	MDWC:Wards Ferry Ranches	45		1
0300	ESWTR-filtered sys-monitoring (38)		5510006	Mi-Wuk Village Mut Wtr Co	2200		1
3100	Total Coliform-routine monitoring		5510021	Tud-Peaceful Pines Water System	71		1
2456	Haloacetic Acids (HAA-5)		5510023	Sonora Meadows Mutual Wtr Co	1435		1
2950	Total Trihalomethanes (TTHMs)		5510023				1
5000	LCR - Routine&followup monitoring		5510852	Baseline Conservation Camp	150		1
Ventura County							
3100	Total Coliform-routine monitoring		5601104	Casitas Mutual Water Company	229		1
3100	Total Coliform-routine monitoring		5602406	Rio School Dist/Rio Del Valle School	820		1
3100	Total Coliform-routine monitoring		5602516	Well-Pict Berries WS	50		4
3100	Total Coliform-routine monitoring		5603117	Santa Clara Resources	200		1
Yuba County							
3100	Total Coliform-routine monitoring		5800854	Spring Valley School	100		1
3100	Total Coliform-routine monitoring		5805001	Plumas Lake	3300		1
3100	Total Coliform-routine monitoring		5810003	Olivehurst Public U.D.	12200		1
Counts / Totals					913	784783	1285

Footnotes:

a.....State MCL levels provided when MCL violations occurred. Treatment technique listed as "TT".

APPENDIX D

Local Primacy Agencies

**(Counties with delegated authority for small
public water systems)**

Appendix D

Local Primacy Agencies (Counties with delegated regulatory authority for small public water systems)

1. Alpine
2. Amador
3. Butte
4. Calaveras
5. Contra Costa
6. El Dorado
7. Fresno
8. Imperial
9. Inyo
10. Kings
11. Los Angeles
12. Madera
13. Marin
14. Merced
15. Mono
16. Monterey
17. Napa
18. Nevada
19. Placer
20. Plumas
21. Riverside
22. Sacramento
23. San Bernardino
24. San Diego
25. San Joaquin
26. San Luis Obispo
27. San Mateo
28. Santa Barbara
29. Santa Cruz
30. Shasta
31. Stanislaus
32. Tehama
33. Tulare
34. Tuolumne
35. Yolo
36. Yuba